
## DIVISION OF AIR QUALITY Ambient Monitoring Section 217 West Jones Street / 1641 Mail Service Center Raleigh, NC 27699-1641

## 3/16/2022



 Brad Newland, Wilmington Regional Office Air Quality Supervisor
 DocuSigned by8/3/2022

 Brad Newland, Wilmington Regional Office Air Quality Supervisor
 Brad Newland

 From Regional Office Air Quality Supervisor
 8/3/2022

 From:
 Travis Funderburk, Environmental Chemist, Projects and Procedures Branch
 DocuSigned by: BD060579E9314CD...

## SUBJECT: BAM 1020 Shelter Temperature Control

The BAM 1020 is sensitive to rapid fluctuations in temperature, which is one reason why NC DAQ required the shelter temperature in the freestanding Ekto configuration be maintained at 28-32 °C. However, it is in the best interest of DAQ to relax the shelter temperature to an achievable goal of 20-30 °C with hourly variations no more than ± 2°C per hour. This change is a good compromise of the BAM 1020 manual specifications (0-50°C). Also, data quality will remain good, HVAC wear and tear will be reduced, and the hours involved in data review will be reduced.

Replace and Discard Original	
Add Material to Document	
Retain this bulleting until further notice	$\boxtimes$
Discard this bulleting after noting contents	
This bulleting will be invalid after:	Click or tap to enter a date.
This bulletin will be incorporated into the PM QAPP, Northampton	
QAPP, Background QAPP, Near Road QAPP and NCORE QAPP and	
associated BAM 1020 SOPs by	9/30/2022