

Arsenic concentrations at 36-inch stormwater pipe at Dan River facility

	Arsenic	DENR Test Results
36 SW Outlet	Total	140 ug/L
	Dissolved	97
36 SW Inlet	Total	<2
	Dissolved	<2

**Water quality standard for arsenic is 10 ug/L, based on total metals*