

**FLUOROMONOMERS
MANUFACTURING PROCESS
VE SOUTH STACK
EMISSIONS TEST REPORT
TEST DATE: 09 JANUARY 2019**

**THE CHEMOURS COMPANY
FAYETTEVILLE, NORTH CAROLINA**

Prepared for:



THE CHEMOURS COMPANY
22828 NC Hwy 87 W
Fayetteville, North Carolina 28306

Prepared by:



WESTON SOLUTIONS, INC.
1400 Weston Way
P.O. Box 2653
West Chester, Pennsylvania 19380

21 February 2019

W.O. No. 15418.002.009

TABLE OF CONTENTS

Section	Page
1. INTRODUCTION.....	1
1.1 FACILITY AND BACKGROUND INFORMATION	1
1.2 TEST OBJECTIVES	1
1.3 TEST PROGRAM OVERVIEW	1
2. SUMMARY OF TEST RESULTS	4
3. PROCESS DESCRIPTIONS	5
3.1 FLUOROMONOMERS	5
3.2 PROCESS OPERATIONS AND PARAMETERS	5
4. DESCRIPTION OF TEST LOCATIONS.....	6
4.1 VE SOUTH STACK.....	6
5. SAMPLING AND ANALYTICAL METHODS.....	8
5.1 STACK GAS SAMPLING PROCEDURES	8
5.1.1 Pre-Test Determinations	8
5.2 STACK PARAMETERS.....	8
5.2.1 EPA Method 0010.....	8
5.2.2 EPA Method 0010 Sample Recovery	10
5.2.3 EPA Method 0010 Sample Analysis.....	13
5.3 GAS COMPOSITION	14
6. DETAILED TEST RESULTS AND DISCUSSION	16
APPENDIX A PROCESS OPERATIONS DATA	
APPENDIX B RAW AND REDUCED TEST DATA	
APPENDIX C LABORATORY ANALYTICAL REPORT	
APPENDIX D SAMPLE CALCULATIONS	
APPENDIX E EQUIPMENT CALIBRATION RECORDS	
APPENDIX F LIST OF PROJECT PARTICIPANTS	

LIST OF FIGURES

Title	Page
Figure 4-1 VE South Stack Test Port and Traverse Point Location	7
Figure 5-1 EPA Method 0010 Sampling Train.....	9
Figure 5-2 HFPO Dimer Acid Sample Recovery Procedures for Method 0010	12
Figure 5-3 WESTON Sampling System.....	15

LIST OF TABLES

Title	Page
Table 1-1 Sampling Plan for VE South Stack	3
Table 2-1 Summary of HFPO Dimer Acid Test Results	4
Table 6-1 Summary of HFPO Dimer Acid Test Data and Test Results VE South Stack.....	17

1. INTRODUCTION

1.1 FACILITY AND BACKGROUND INFORMATION

The Chemours Fayetteville Works (Chemours) is located in Bladen County, North Carolina, approximately 10 miles south of the city of Fayetteville. The Chemours operating areas on the site include the Fluoromonomers, IXM and Polymer Processing Aid (PPA) manufacturing areas, Wastewater Treatment, and Powerhouse.

Chemours contracted Weston Solutions, Inc. (Weston) to perform HFPO Dimer Acid emission testing on the Vinyl Ethers (VE) South Stack. Testing was performed on 09 January 2019 and generally followed the “Emissions Test Protocol” reviewed and approved by the North Carolina Department of Environmental Quality (NCDEQ). This report provides the results from the emission test program.

1.2 TEST OBJECTIVES

The specific objectives for this test program were as follows:

- Measure the emissions concentrations and mass emissions rates of HFPO Dimer Acid from the VE South stack which is located in the Fluoromonomers process area.
- Monitor and record process data in conjunction with the test program.
- Provide representative emissions data.

1.3 TEST PROGRAM OVERVIEW

During the emissions test program, the concentrations and mass emissions rates of HFPO Dimer Acid were measured on the VE South Stack.

Table 1-1 provides a summary of the test locations and the parameters that were measured along with the sampling/analytical procedures that were followed. Section 2 provides a summary of test results. A description of the processes is provided in Section 3. Section 4 provides a description of the test locations. The sampling and analytical procedures are provided in Section 5. Detailed test results and discussion are provided in Section 6.

Appendix C includes the summary reports for the laboratory analytical results. The full laboratory data packages are provided in electronic format and on CD with each hard copy.

**Table 1-1
Sampling Plan for VE South Stack**

Sampling Point & Location	VE South Stack				
Number of Tests:	3				
Parameters To Be Tested:	HFPO Dimer Acid (HFPO-DA)	Volumetric Flow Rate and Gas Velocity	Carbon Dioxide	Oxygen	Water Content
Sampling or Monitoring Method	EPA M-0010	EPA M1, M2, M3A, and M4 in conjunction with M-0010 tests	EPA M3A		EPA M4 in conjunction with M-0010 tests
Sample Extraction/ Analysis Method(s):	LC/MS/MS	NA ⁶	NA		NA
Sample Size	> 1m ³	NA	NA	NA	NA
Total Number of Samples Collected ¹	3	3	3	3	3
Reagent Blanks (Solvents, Resins) ¹	1 set	0	0	0	0
Field Blank Trains ¹	1 per source	0	0	0	0
Proof Blanks ¹	1 per train	0	0	0	0
Trip Blanks ^{1,2}	1 set	0	0	0	
Lab Blanks	1 per fraction ³	0	0	0	0
Laboratory or Batch Control Spike Samples (LCS)	1 per fraction ³	0	0	0	0
Laboratory or Batch Control Spike Sample Duplicate (LCSD)	1 per fraction ³	0	0	0	0
Media Blanks	1 set ⁴	0	0	0	0
Isotope Dilution Internal Standard Spikes	Each sample	0	0	0	0
Total No. of Samples	7 ⁵	3	3	3	3

Key:

¹ Sample collected in field.

² Trip blanks include one XAD-2 resin module and one methanol sample per sample shipment.

³ Lab blank and LCS/LCSD includes one set per analytical fraction (front half, back half and condensate).

⁴ One set of media blank archived at laboratory at media preparation.

⁵ Actual number of samples collected in field.

⁶ Not applicable.

2. SUMMARY OF TEST RESULTS

Three tests were performed on the VE South stack. Table 2-1 provides a summary of the HFPO Dimer Acid emission test results. Detailed test results summaries are provided in Section 6.

It is important to note that emphasis is being placed on the characterization of the emissions based on the stack test results. Research conducted in developing the protocol for stack testing HFPO Dimer Acid Fluoride, HFPO Dimer Acid Ammonium Salt and HFPO Dimer Acid realized that the resulting testing, including collection of the air samples and extraction of the various fraction of the sampling train, would result in all three compounds being expressed as simply the HFPO Dimer Acid. However, it should be understood that the total HFPO Dimer Acid results provided on Table 2-1 and in this report include a percentage of each of the three compounds.

Table 2-1

Summary of HFPO Dimer Acid Test Results

Source	Run No.	Emission Rates	
		lb/hr	g/sec
VE South Stack	1	5.20E-03	6.55E-04
	2	6.81E-03	8.58E-04
	3	5.11E-03	6.44E-04
	Average	5.71E-03	7.19E-04

3. PROCESS DESCRIPTIONS

The Fluoromonomers area is included in the scope of this test program.

3.1 FLUOROMONOMERS

These facilities produce a family of fluorocarbon compounds used to produce Chemours products such as Teflon® Polymers and Viton®, as well as sales to outside customers.

The VE South Waste Gas Scrubber is vented to a process stack (NEP-Hdr2). In addition, the following building air systems are vented to this stack:

- Permeators
- RV Catch Pots
- Tower HVAC
- Nitrogen Supply to Catch Tanks
- Catalyst Feed Tank Pot Charge Vent

3.2 PROCESS OPERATIONS AND PARAMETERS

Source	Operation/Product	Batch or Continuous
VE South	PMVE/PEVE	Semi-continuous – Condensation is continuous, Two Agitated Bed Reactors are batch for 30-40 mins at end of each run, Refining (ether column) is batch

During the test program, the following parameters were monitored by Chemours and are included in Appendix A.

- Fluoromonomers Processes
 - VE South Waste Gas Scrubber
 - Caustic recirculation flow rate

4. DESCRIPTION OF TEST LOCATIONS


4.1 VE SOUTH STACK

Two 6-inch ID test ports are installed on the 42-inch ID steel stack. The ports are placed 150 inches (3.6 diameters) from the location where the waste gas scrubber vent enters the stack and 20 feet (5.7 diameters) from the stack exit.

Per EPA Method 1, a total of 24 traverse points (12 per axis) were used for M0010 isokinetic sampling. It should be noted that near the port locations are a number of small ducts leading to the stack. These are catch pots which, under normal operation, do not discharge to the stack. They are used to vent process gas to the stack in the event of a process upset. For the purpose of test port location, and given the fact that there is no flow from these catch pots, they are not considered a flow contributor or a disturbance.

See Figure 4-1 for a schematic of the test port and traverse point locations.

Note: All measurements at the test location were confirmed prior to sampling.



**FIGURE 4-1
VE SOUTH STACK TEST PORT
AND TRAVERSE POINT LOCATION**

5. SAMPLING AND ANALYTICAL METHODS

5.1 STACK GAS SAMPLING PROCEDURES

The purpose of this section is to describe the stack gas emissions sampling train and to provide details of the stack sampling and analytical procedures utilized during the emissions test program.

5.1.1 Pre-Test Determinations

Preliminary test data were obtained at the test location. Stack geometry measurements were measured and recorded, and traverse point distances verified. A preliminary velocity traverse was performed utilizing a calibrated S-type pitot tube and an inclined manometer to determine velocity profiles. Flue gas temperatures were observed with a calibrated direct readout panel meter equipped with a chromel-alumel thermocouple. Preliminary water vapor content was estimated by wet bulb/dry bulb temperature measurements.

A check for the presence or absence of cyclonic flow was previously conducted at the test location. The cyclonic flow check was negative ($< 20^\circ$) verifying that the source was acceptable for testing.

Preliminary test data was used for nozzle sizing and sampling rate determinations for isokinetic sampling procedures.

Calibration of probe nozzles, pitot tubes, metering systems, and temperature measurement devices was performed as specified in Section 5 of EPA Method 5 test procedures.

5.2 STACK PARAMETERS

5.2.1 EPA Method 0010

The sampling train utilized to perform the HFPO Dimer Acid sampling was an EPA Method 0010 train (see Figure 5-1). The Method 0010 consisted of a borosilicate nozzle that attached directly to a heated borosilicate probe. In order to minimize possible thermal degradation of the HFPO Dimer Acid, the probe and particulate filter were heated above stack temperature to minimize water vapor condensation before the filter. The probe was connected directly to a heated borosilicate filter holder containing a solvent extracted glass fiber filter.




FIGURE 5-1
EPA METHOD 0010 SAMPLING TRAIN

A section of borosilicate glass (or flexible polyethylene) tubing connected the filter holder exit to a Graham (spiral) type ice water-cooled condenser, an ice water-jacketed sorbent module containing approximately 40 grams of XAD-2 resin. The XAD-2 resin tube was equipped with an inlet temperature sensor. The XAD-2 resin trap was followed by a condensate knockout impinger and a series of two impingers that each contained 100 milliliters of high purity distilled water. The train also included a second XAD-2 resin trap behind the impinger section to evaluate possible sampling train breakthrough. Each XAD-2 resin trap was connected to a 1-liter condensate knockout trap. The final impinger contained 300 grams of dry pre-weighed silica gel. All impingers and the condensate traps were maintained in an ice bath. Ice water was continuously circulated in the condenser and both XAD-2 modules to maintain method-required temperature. A control console with a leakless vacuum pump, a calibrated orifice, and dual inclined manometers was connected to the final impinger via an umbilical cord to complete the sample train.

HFPO Dimer Acid Fluoride (CAS No. 2062-98-8) that was present in the stack gas was captured in the sampling train along with HFPO Dimer Acid (CAS No. 13252-13-6). HFPO Dimer Acid Fluoride underwent hydrolysis instantaneously in water in the sampling train and during the sample recovery step, and was converted to HFPO Dimer Acid such that the amount of HFPO Dimer Acid emissions represented a combination of both HFPO Dimer Acid Fluoride and HFPO Dimer Acid.

During sampling, gas stream velocities were measured by attaching a calibrated S-type pitot tube into the gas stream adjacent to the sampling nozzle. The velocity pressure differential was observed immediately after positioning the nozzle at each traverse point, and the sampling rate adjusted to maintain isokineticity at $100\% \pm 10$. Flue gas temperature was monitored at each point with a calibrated panel meter and thermocouple. Isokinetic test data was recorded at each traverse point during all test periods, as appropriate. Leak checks were performed on the sampling apparatus according to reference method instructions, prior to and following each run, component change (if required), or during midpoint port changes.

5.2.2 EPA Method 0010 Sample Recovery

At the conclusion of each test, the sampling train was dismantled, the openings sealed, and the components transported to the field laboratory trailer for recovery.


A consistent procedure was employed for sample recovery:

1. The two XAD-2 covered (to minimize light degradation) sorbent modules (1 and 2) were sealed and labeled.
2. The glass fiber filter(s) were removed from the holder with tweezers and placed in a polyethylene container along with any loose particulate and filter fragments.
3. The particulate adhering to the internal surfaces of the nozzle, probe and front half of the filter holder were rinsed with a solution of methanol and ammonium hydroxide into a polyethylene container while brushing a minimum of three times until no visible particulate remained. Particulate adhering to the brush was rinsed with methanol/ammonium hydroxide into the same container. The container was sealed.
4. The volume of liquid collected in the first condensate trap was measured, the value recorded, and the contents poured into a polyethylene container.
5. All train components between the filter exit and the first condensate trap were rinsed with methanol/ammonium hydroxide. The solvent rinse was placed in a separate polyethylene container and sealed.
6. The volume of liquid in impingers one and two, and the second condensate trap, were measured, the values recorded, and the sample was placed in the same container as Step 4 above, then sealed.
7. The two impingers, condensate trap, and connectors were rinsed with methanol/ammonium hydroxide. The solvent sample was placed in a separate polyethylene container and sealed.
8. The silica gel in the final impinger was weighed and the weight gain value recorded.
9. Site (reagent) blank samples of the methanol/ammonium hydroxide, XAD resin, filter and distilled water were retained for analysis.

Each container was labeled to clearly identify its contents. The height of the fluid level was marked on the container of each liquid sample to provide a reference point for a leakage check during transport. All samples were maintained cool.

During each test campaign, an M-0010 blank train was set up near the test location, leak checked and recovered along with the respective sample train. Following sample recovery, all samples were transported to TestAmerica Laboratories, Inc. (TestAmerica) for sample extraction and analysis.

See Figure 5-2 for a schematic of the M-0010 sample recovery process.



**FIGURE 5-2
HFPO DIMER ACID SAMPLE RECOVERY PROCEDURES FOR METHOD 0010**

5.2.3 EPA Method 0010 – Sample Analysis

The Method 0010 sampling trains resulted in four separate analytical fractions for HFPO Dimer Acid analysis according to SW-846 Method 3542:

- Front-Half Composite—comprised of the particulate filter, and the probe, nozzle, and front-half of the filter holder solvent rinses;
- Back-Half Composite—comprised of the first XAD-2 resin material and the back-half of the filter holder with connecting glassware solvent rinses;
- Condensate Composite—comprised of the aqueous condensates and the contents of impingers one and two with solvent rinses;
- Breakthrough XAD-2 Resin Tube—comprised of the resin tube behind the series of impingers.

The second XAD-2 resin material was analyzed separately to evaluate any possible sampling train HFPO-DA breakthrough.

The front-half and back-half composites and the second XAD-2 resin material were placed in polypropylene wide-mouth bottles and tumbled with methanol containing 5% NH₄OH for 18 hours. Portions of the extracts were processed analytically for the HFPO dimer acid by liquid chromatography and dual mass spectroscopy (HPLC/MS/MS). The condensate composite was concentrated onto a solid phase extraction (SPE) cartridge followed by desorption from the cartridge using methanol. Portions of those extracts were also processed analytically by HPLC/MS/MS.

Samples were spiked with isotope dilution internal standard (IDA) at the commencement of their preparation to provide accurate assessments of the analytical recoveries. Final data was corrected for IDA standard recoveries.


5.3 GAS COMPOSITION

The Weston mobile laboratory equipped with instrumental analyzers was used to measure carbon dioxide (CO₂) and oxygen (O₂) concentrations. A diagram of the Weston sampling system is presented in Figure 5-3.

Each analyzer was set up and calibrated internally by introduction of calibration gas standards directly to the analyzer from a calibration manifold. The calibration manifold is designed with an atmospheric vent to release excess calibration gas and maintained the calibration at ambient pressure. The direct calibration sequence consisted of alternate injections of zero and mid-range gases with appropriate adjustments until the desired responses were obtained. The high-range standards were then introduced in sequence without further adjustment.

The sample line integrity was verified by performing a bias test before and after each test period. The sampling system bias test consisted of introducing the zero gas and one up-range calibration standard in excess to the valve at the probe end when the system was sampling normally. The excess calibration gas flowed out through the probe to maintain ambient sampling system pressure. Calibration gas supply was regulated to maintain constant sampling rate and pressure. Instrument bias check response was compared to internal calibration responses to ensure sample line integrity and to calculate a bias correction factor after each run using the ratio of the measured concentration of the bias gas certified by the calibration gas supplier.

The oxygen and carbon dioxide content of each stack gas was measured according to EPA Method 3A procedures which incorporate the latest updates of EPA Method 7E. A Servomex Model 4900 analyzer (or equivalent) was used to measure oxygen content. A Servomex Model 4900 analyzer (or equivalent) was used to measure carbon dioxide content of the stack gas. Both analyzers were calibrated with EPA Protocol gases prior to the start of the test program and performance was verified by sample bias checks before and after each test run.



**FIGURE 5-3
WESTON SAMPLING SYSTEM**

6. DETAILED TEST RESULTS AND DISCUSSION

Preliminary testing and the associated analytical results required significant sample dilution to bring the HFPO Dimer Acid concentration within instrument calibration; therefore, sample times and sample volumes were reduced for the formal test program. This was approved by the North Carolina Department of Environmental Quality (NCDEQ).

Each test was a minimum of 96 minutes in duration. A total of three test runs were performed on the VE South stack.

Table 6-1 provides detailed test data and test results for the VE South stack.

The Method 3A sampling during all tests indicated that the O₂ and CO₂ concentrations were at ambient air levels (20.9% O₂, 0% CO₂), therefore, 20.9% O₂ and 0% CO₂ values were used in all calculations.

TABLE 6-1
CHEMOURS - FAYETTEVILLE, NC
SUMMARY OF HFPO DIMER ACID TEST DATA AND TEST RESULTS
VE SOUTH STACK

Test Data

	1	2	3
Run number			
Location	VE South Stack	VE South Stack	VE South Stack
Date	01/09/19	01/09/19	01/09/19
Time period	0840-1032	1140-1328	1408-1558

SAMPLING DATA:

Sampling duration, min.	96.0	96.0	96.0
Nozzle diameter, in.	0.300	0.300	0.300
Cross sectional nozzle area, sq.ft.	0.000491	0.000491	0.000491
Barometric pressure, in. Hg	29.94	29.94	29.94
Avg. orifice press. diff., in H ₂ O	1.31	1.51	1.41
Avg. dry gas meter temp., deg F	50.3	55.9	57.0
Avg. abs. dry gas meter temp., deg. R	510	516	517
Total liquid collected by train, ml	28.2	20.2	30.8
Std. vol. of H ₂ O vapor coll., cu.ft.	1.3	1.0	1.5
Dry gas meter calibration factor	0.9915	0.9915	0.9915
Sample vol. at meter cond., dcf	62.591	65.028	63.392
Sample vol. at std. cond., dscf ⁽¹⁾	64.436	66.252	64.430
Percent of isokinetic sampling	109.5	100.9	100.2

GAS STREAM COMPOSITION DATA:

CO ₂ , % by volume, dry basis	0.0	0.0	0.0
O ₂ , % by volume, dry basis	20.9	20.9	20.9
N ₂ , % by volume, dry basis	79.1	79.1	79.1
Molecular wt. of dry gas, lb/lb mole	28.84	28.84	28.84
H ₂ O vapor in gas stream, prop. by vol.	0.020	0.014	0.022
Mole fraction of dry gas	0.980	0.986	0.978
Molecular wt. of wet gas, lb/lb mole	28.62	28.68	28.60

GAS STREAM VELOCITY AND VOLUMETRIC FLOW DATA:

Static pressure, in. H ₂ O	0.50	0.50	0.50
Absolute pressure, in. Hg	29.98	29.98	29.98
Avg. temperature, deg. F	77	79	79
Avg. absolute temperature, deg.R	537	539	539
Pitot tube coefficient	0.84	0.84	0.84
Total number of traverse points	24	24	24
Avg. gas stream velocity, ft./sec.	21.6	24.0	23.7
Stack/duct cross sectional area, sq.ft.	9.62	9.62	9.62
Avg. gas stream volumetric flow, wacf/min.	12447	13852	13699
Avg. gas stream volumetric flow, dscf/min.	12014	13410	13134

⁽¹⁾ Standard conditions = 68 deg. F. (20 deg. C.) and 29.92 in Hg (760 mm Hg)

**TABLE 6-1 (cont.)
CHEMOURS - FAYETTEVILLE, NC
SUMMARY OF HFPO DIMER ACID TEST DATA AND TEST RESULTS
VE SOUTH STACK OUTLET**

TEST DATA			
Run number	1	2	3
Location	VE South Stack	VE South Stack	VE South Stack
Date	1/09/19	1/09/19	1/09/19
Time period	0840-1032	1140-1328	1408-1558
LABORATORY REPORT DATA, ug.			
HFPO Dimer Acid	210.8818	254.4730	189.6000
EMISSION RESULTS, ug/dscm.			
HFPO Dimer Acid	115.55	135.61	103.90
EMISSION RESULTS, lb/dscf.			
HFPO Dimer Acid	7.22E-09	8.47E-09	6.49E-09
EMISSION RESULTS, lb/hr.			
HFPO Dimer Acid	5.20E-03	6.81E-03	5.11E-03
EMISSION RESULTS, g/sec.			
HFPO Dimer Acid	6.55E-04	8.58E-04	6.44E-04

APPENDIX A
PROCESS OPERATIONS DATA

Date 1/9/2019

Time	800			900			1000			1100			1200			1300			1400			1500		
Stack Testing				RUN 1 - 0840-1032									RUN 2 - 1140-1328						RUN 3 - 1408-1558					
VES Product	PMPE																							
VES Precursor																								
VES Condensation (HFPO)																								
VES ABR																								
VES Refining																								
VES WGS Recirculation Flow	18500 kg/h																							
Dimer ISO venting																								

APPENDIX B
RAW AND REDUCED TEST DATA

CHEMOURS - FAYETTEVILLE, NC
INPUTS FOR HFPO DIMER ACID CALCULATIONS
VE SOUTH STACK

Test Data

	1	2	3
Run number			
Location	VE South Stack	VE South Stack	VE South Stack
Date	01/09/19	01/09/19	01/09/19
Time period	0840-1032	1140-1328	1408-1558
Operator	AS	AS/SR	AS

Inputs For Calcs.

Sq. rt. delta P	0.37963	0.42228	0.41666
Delta H	1.3051	1.5054	1.4100
Stack temp. (deg.F)	76.8	78.5	79.4
Meter temp. (deg.F)	50.3	55.9	57.0
Sample volume (act.)	62.591	65.028	63.392
Barometric press. (in.Hg)	29.94	29.94	29.94
Volume H ₂ O imp. (ml)	10.0	-6.0	10.0
Weight change sil. gel (g)	18.2	26.2	20.8
% CO ₂	0.0	0.0	0.0
% O ₂	20.9	20.9	20.9
% N ₂	79.1	79.1	79.1
Area of stack (sq.ft.)	9.620	9.620	9.620
Sample time (min.)	96.0	96.0	96.0
Static pressure (in.H ₂ O)	0.50	0.50	0.50
Nozzle dia. (in.)	0.300	0.300	0.300
Meter box cal.	0.9915	0.9915	0.9915
Cp of pitot tube	0.84	0.84	0.84
Traverse points	24	24	24

ISOKINETIC FIELD DATA SHEET

Method 0010 HFPO Dimer Acid

Client	Chemours	Stack Conditions	
W.O.#	15418.002.009.0001	Assumed	Actual
Project ID	Chemours	3	
Mode/Source ID	VE South		1.82
Samp. Loc. ID	STK		18.2
Run No. ID	1	0	0.2
Test Method ID	M 0010 HFPO Dimer Acid	21	20.9
Date ID	9JAN2019	80	
Source/Location	VE South Stack	860	
Sample Date	1-9-19	0.5	0.5
Baro. Press (in Hg)	29.94		
Operator	29.94 AS	47	

Meter Box ID	21
Meter Box Y	0.9915 ✓
Meter Box Del H	2.0089 ✓
Probe ID / Length	694 / 5'
Probe Material	Boro
Pitot / Thermocouple ID	694 / 694
Pitot Coefficient	0.84
Nozzle ID	0.300
Avg Nozzle Dia (in)	0.300 ✓
Area of Stack (ft²)	9.620 ✓
Sample Time	96 ✓
Total Traverse Pts	24 ✓

K Factor	8.95	
Initial	Mid-Point	Final
0.010	0.040	0.000
15" ✓	11" ✓	7" ✓
yes / no	yes / no	yes / no
Orsat good	Orsat good	Orsat good
Temp Check	Pre-Test Set	Post-Test Set
Meter Box Temp	47	50
Reference Temp	46.9	50.5
Pass/Fail (+/- 2°)	Pass / Fail	Pass / Fail
Temp Change Response	yes / no	yes / no

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Delta P (in H2O)	ORIFICE PRESSURE Delta H (in H2O)	DRY GAS METER READING (ft³)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VAC (in Hg)	XAD TEMP	COMMENTS
	0	9:40			244.333									
A1	4		0.15	1.34	247.0	71		48	100	101	49	5	49	
2	8		0.17	1.52	249.8	78		49	100	107	47	5	47	
3	12		0.18	1.61	252.6	78		49	100	105	47	6	47	
4	16		0.17	1.52	255.3	78		49	100	110	45	5	46	
5	20		0.18	1.61	258.1	78		49	100	104	47	6	46	
6	24		0.17	1.52	260.8	78		49	100	107	47	6	43	
7	28		0.15	1.34	263.4	78		49	100	102	47	6	42	
8	32		0.15	1.34	266.0	78		49	100	104	48	6	41	
9	36		0.13	1.16	268.7	78		49	100	106	47	6	40	
10	40		0.13	1.16	271.8	76		50	100	100	47	6	41	
11	44		0.10	.90	274.7	78		50	100	100	47	6	40	
12	48	9:28	0.10 ✓	.90 ✓	276.836	73 ✓		50 ✓	100	106	47	6	40	
B1	52	9:44	0.15	1.34	279.6	72		50	100	101	48	6	40	276.944
2	56		0.17	1.52	282.3	77		51	100	104	48	6	43	- .108
3	60		0.17	1.52	285.2	77		51	100	102	47	6	42	
4	64		0.18	1.61	287.9	78		50	100	102	47	6	43	
5	68		0.14	1.61	290.7	77		51	100	106	48	6	42	
6	72		0.18	1.61	293.5	77		51	100	106	48	6	41	
7	76		0.16	1.432	296.1	78		51	100	109	49	6	43	
8	80		0.13	1.16	298.5	78		51	100	106	49	6	46	
9	84		0.10	.90	300.6	78		52	100	104	49	6	47	
10	88		0.10	.90	302.7	77		53	100	102	50	6	48	
11	92		0.10	.90	305.0	77		53	100	104	50	6	46	
12	96	10:32	0.10 ✓	.90 ✓	307.032	75 ✓		53 ✓	100	106	50	6	48	

Avg Sqrt Delta P	Avg Delta H	Total Volume	Avg Ts	Avg Tm	Min/Max	Min/Max	Max Temp	Max Vac	Max Temp
0.340 ✓	1.30500 ✓	62.591 ✓	76.79 ✓	50.29 ✓	100/100	100/106	50	6	49
0.37963 ✓	Avg Sqrt Del H	Comments:							
0.146 ✓	1.136 ✓								
0.14585	1.13579 ✓								



ISOKINETIC FIELD DATA SHEET

Method 0010 HFPO Dimer Acid

Client	Chemours	Stack Conditions	
W.O.#	15418.002.009.0001	Assumed	Actual
Project ID	Chemours	3	
Mode/Source ID	VE South		6
Samp. Loc. ID	STK		26.2
Run No. ID	2	0	90
Test Method ID	M 0010 HFPO Dimer Acid	21	20A
Date ID	9JAN2019	80	
Source/Location	VE South Stack	60	
Sample Date	1-9-19	.5	0.5
Baro. Press (in Hg)	29.94		
Operator	AS/SL		50

Meter Box ID	21
Meter Box Y	9915 ✓
Meter Box Del H	20089 ✓
Probe ID / Length	694 6 ✓
Probe Material	Boro
Pitot / Thermocouple ID	694 694
Pitot Coefficient	0.84
Nozzle ID	300
Avg Nozzle Dia (in)	300 ✓
Area of Stack (ft²)	9620 ✓
Sample Time	96 ✓
Total Traverse Pts	24 ✓

K Factor	8.95 8.055		
Initial	Mid-Point	Final	
.003	.006	.007	
15"	10"	8"	
yes / no	yes / no	yes / no	
yes / no	yes / no	yes / no	
Pre-Test Set		Post-Test Set	
53		57	
53.6		56.5	
Pass / Fail		Pass / Fail	
yes / no		yes / no	

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Delta P (in H2O)	ORIFICE PRESSURE Delta H (in H2O)	DRY GAS METER READING (ft³)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (F)	IMPING EXIT TEMP (°F)	SAMPLE TRAIN VAC (in Hg)	4AD Temp	COMMENTS
	0	11:40			307.332									
A1	4		.18	1.61	310.1	71		55	100	105	56	6	48	
2	8		.19	1.70	313.2	78		56	100	100	52	6	48	
3	12		.20	1.79	316.0	79		56	100	102	52	6	49	
4	16		.20	1.79	318.9	80		55	100	102	54	6	49	
5	20		.20	1.79	321.8	79		55	100	104	57	6	48	
6	24		.20	1.79	324.8	79		55	100	102	58	6	49	
7	28		.20	1.79	327.7	79		55	100	103	60	6	44	
8	32		.18	1.61	330.6	79		55	100	103	61	6	55	
9	36		.17	1.52	333.3	79		55	100	106	62	6	56	
10	40		.15	1.21	335.8	78		56	100	108	62	6	56	
11	44		.15	1.21	338.1	78		55	100	100	61	6	56	
12	48	12:28	.13 ✓	1.05 ✓	340.365	78 ✓		55 ✓	100	106	61	6	56	340.489 -.124
B1	52	12:40	.19	1.53	343.4	72		55	101	100	56	6	55	
2	56		.20	1.61	346.0	79		55	100	103	58	6	55	
3	60		.21	1.69	348.9	80		55	100	102	59	6	56	
4	64		.20	1.61	351.7	80		56	100	104	59	6	57	
5	68		.20	1.61	354.6	80		56	100	101	62	6	60	
6	72		.19	1.53	357.3	80		57	100	103	57	6	53	
7	76		.20	1.61	360.0	80		57	100	105	45	6	53	
8	80		.17	1.36	362.6	81		57	100	102	45	6	59	
9	84		.16	1.29	365.1	80		57	100	105	45	6	56	
10	88		.15	1.20	367.6	79		57	100	103	47	6	54	
11	92		.14	1.12	370.0	78		58	100	103	47	6	54	
12	96	13:28	.14 ✓	1.12	372.484	78 ✓		58 ✓	100	103	47	6	55	

Avg Sqrt Delta P	Avg Delta H	Total Volume	Avg Ts	Avg Tm	Min/Max	Min/Max	Max Temp	Max Vac	Max Temp
.4228	1.5054	65.025	78.5	55.88	100/101	103/108	62	6	60

1.17917 ✓
 Avg Sqrt Del H 1.22 ✓
 1.22282 ✓



ISOKINETIC FIELD DATA SHEET

Method 0010 HFPO Dimer Acid

Client: Chemours
 W.O.#: 15418.002.009.0001
 Project ID: Chemours
 Mode/Source ID: VE South
 Samp. Loc. ID: STK
 Run No. ID: 3
 Test Method ID: M 0010 HFPO Dimer Acid
 Date ID: 9JAN2019
 Source/Location: VE South Stack
 Sample Date: 1-9-19
 Baro. Press (in Hg): 29.94
 Operator: AS

Stack Conditions

Assumed	Actual
3	30
	20.0
0	20
21	20.9
80	
60	
.5	0.5
	50

Meter Box ID: 21
 Meter Box Y: 1915
 Meter Box Del H: 2.0089
 Probe ID / Length: 694 / 6
 Probe Material: Boro
 Pitot / Thermocouple ID: 694 / 694
 Pitot Coefficient: 0.84
 Nozzle ID: .300
 Avg Nozzle Dia (in): .300
 Area of Stack (ft²): 9.620
 Sample Time: 96
 Total Traverse Pts: 24

Leak Checks

Sample Train (ft³):
 Leak Check @ (in Hg):
 Pitot good:
 Orsat good:
Temp Check
 Meter Box Temp:
 Reference Temp:
 Pass/Fail (+/- 2°):
 Temp Change Response:

K Factor 8.05		
Initial	Mid-Point	Final
1.007	1.005	1.005
151	81	101
(yes) / no	(yes) / no	(yes) / no
(yes) / no	(yes) / no	(yes) / no
Pre-Test Set		Post-Test Set
57		57
50.6		50.6
(Pass) / Fail		(Pass) / Fail
(yes) / no		(yes) / no

TRAVERSE POINT NO.	SAMPLE TIME (min)	CLOCK TIME (plant time)	VELOCITY PRESSURE Delta P (in H2O)	ORIFICE PRESSURE Delta H (in H2O)	DRY GAS METER READING (ft³)	STACK TEMP (°F)	DGM INLET TEMP (°F)	DGM OUTLET TEMP (°F)	PROBE TEMP (°F)	FILTER BOX TEMP (F)	IMPINGER EXIT TEMP (°F)	SAMPLE TRAIN VAC (in Hg)	XAD TEMP	COMMENTS
	0	14:08			373.010									
A1	4		.19	1.53	375.9	76	NA	57	101	100	56	8	52	
2	8		.20	1.61	378.7	79		57	100	102	54	8	54	
3	12		.20	1.61	381.5	80		57	100	101	46	8	53	
4	16		.20	1.61	384.4	80		57	100	104	43	8	53	
5	20		.20	1.61	387.1	80		57	100	104	43	8	51	
6	24		.20	1.61	390.0	80		57	100	104	43	8	51	
7	28		.19	1.53	392.7	80		57	100	104	43	8	51	
8	32		.16	1.29	394.9	80		54	100	104	43	8	52	
9	36		.15	1.21	397.7	80		57	100	104	43	6	51	
10	40		.13	1.05	400.0	80		57	100	104	44	6	52	
11	44		.13	1.05	402.2	79		57	100	102	44	6	53	
12	48	14:56	.11	.89	404.308	77		57	100	104	44	6	53	
					404.449									- .141
B1	52	15:10	.19	1.53	407.2	76		56	100	105	51	8	52	
2	56		.20	1.61	410.2	80		56	100	100	53	8	51	
3	60		.20	1.61	412.9	80		57	100	105	52	8	51	
4	64		.20	1.61	415.8	81		57	100	108	52	8	50	
5	68		.20	1.61	418.6	80		57	100	102	53	8	52	
6	72		.20	1.61	421.5	80		57	100	104	53	8	51	
7	76		.20	1.61	424.3	80		57	100	107	54	8	53	
8	80		.18	1.45	426.9	80		58	100	105	58	8	56	
9	84		.16	1.29	429.5	80		58	100	104	55	6	56	
10	88		.15	1.21	432.1	80		58	100	104	55	6	56	
11	92		.13	1.05	434.3	80		58	100	107	58	6	54	
12	96	15:58	.13	1.05	436.543	77		58	100	104	54	6	53	

Avg Sqrt Delta P: .417
 Avg Delta H: 1.410
 Total Volume: 63.392
 Avg Ts: 79.375
 Avg Tm: 57
 Min/Max: 100/101
 Min/Max: 100/101
 Max Temp: 58
 Max Vac: 8
 Max Temp: 56

0.41666
 .17500

Avg Sqrt Del H: 1.182

Comments:



SAMPLE RECOVERY FIELD DATA

Method 0010 HFPO Dimer Acid

Client Chemours W.O. # 15418.002.009.0001
 Location/Plant Fayetteville, NC Source & Location VE South Stack

Run No. 1 Sample Date 1/9/19 Recovery Date 1/9/19
 Sample I.D. Chemours - VE South - STK - 1 - M 0010 HFPO Dimer A Analyst VMM Filter Number NA

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents									50	
Final	2	28	208	2					318.2	
Initial	0	100	100	0					300	
Gain	2	28	8	2				10	18.2	18.2

Impinger Color clear Labeled?
 Silica Gel Condition good Sealed? 28.2

Run No. 2 Sample Date 1/9/19 Recovery Date 1/9/19
 Sample I.D. Chemours - VE South - STK - 2 - M 0010 HFPO Dimer A Analyst VMM Filter Number NA

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents									50	
Final	2	95	105	2					326.2	
Initial	0	100	100	0					300	
Gain	2	95	5	2				6	26.2	28.2

Impinger Color clear Labeled?
 Silica Gel Condition Good Sealed? 20.2

Run No. 3 Sample Date 1/9/19 Recovery Date 1/9/19
 Sample I.D. Chemours - VE South - STK - 3 - M 0010 HFPO Dimer A Analyst VMM Filter Number NA

	Impinger							Imp.Total	8	Total
	1	2	3	4	5	6	7			
Contents									50	
Final	2	94	110	4					320.8	
Initial	0	100	100	0					300	
Gain	2	94	10	4				10	20.8	30.8

Impinger Color clear Labeled?
 Silica Gel Condition Good Sealed?

Check COC for Sample IDs of Media Blanks



SAMPLE RECOVERY FIELD DATA

Method 0010 HFPO Dimer Acid

Client Chemours W.O. # 15418.002.009.0001
 Location/Plant Fayetteville, NC Source & Location VE South Stack

Run No. BT Sample Date 1/9/18 Recovery Date 1/9/18
 Sample I.D. Chemours - VE South - STK - BT - M 0010 HFPO Dime Analyst [Signature] Filter Number NA

	Impinger								Imp.Total	8	Total
	1	2	3	4	5	6	7				
Contents											
Final	0	100	100	0						300	
Initial	0	100	100	0						300	
Gain	0	0	0	0					0	0	0

Impinger Color clear Labeled? ✓
 Silica Gel Condition good Sealed? _____

Run No. _____ Sample Date _____ Recovery Date _____
 Sample I.D. _____ Analyst _____ Filter Number _____

	Impinger								Imp.Total	8	Total
	1	2	3	4	5	6	7				
Contents											
Final											
Initial											
Gain											

Impinger Color _____ Labeled? _____
 Silica Gel Condition _____ Sealed? _____

Run No. _____ Sample Date _____ Recovery Date _____
 Sample I.D. _____ Analyst _____ Filter Number _____

	Impinger								Imp.Total	8	Total
	1	2	3	4	5	6	7				
Contents											
Final											
Initial											
Gain											

Impinger Color _____ Labeled? _____
 Silica Gel Condition _____ Sealed? _____

Check COC for Sample IDs of Media Blanks



METHODS AND ANALYZERS

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

File: C:\DATA\Chemours\010919 VE South.cem
Program Version: 2.1, built 19 May 2017 **File Version:** 2.02
Computer: WSWCAIRSERVICES **Trailer:** 27
Analog Input Device: Keithley KUSB-3108

Channel 1

Analyte	O₂
Method	EPA 3A, Using Bias
Analyzer Make, Model & Serial No.	Servomex 4900
Full-Scale Output, mv	10000
Analyzer Range, %	25.0
Span Concentration, %	21.0

Channel 2

Analyte	CO₂
Method	EPA 3A, Using Bias
Analyzer Make, Model & Serial No.	Servomex 4900
Full-Scale Output, mv	10000
Analyzer Range, %	20.0
Span Concentration, %	16.6

CALIBRATION DATA

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Start Time: 07:23

O₂

Method: EPA 3A

Calibration Type: Linear Zero and High Span

Calibration Standards

%	Cylinder ID
12.0	CC18055
21.0	SG9169108

Calibration Results

Zero	10 mv
Span, 21.0 %	7989 mv

Curve Coefficients

Slope	Intercept
380.0	10

CO₂

Method: EPA 3A

Calibration Type: Linear Zero and High Span

Calibration Standards

%	Cylinder ID
8.9	CC18055
16.6	SG9169108

Calibration Results

Zero	-1 mv
Span, 16.6 %	5519 mv

Curve Coefficients

Slope	Intercept
332.9	-1

CALIBRATION ERROR DATA

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Start Time: 07:23

O₂

Method: EPA 3A

Span Conc. 21.0 %

Slope 380.0

Intercept 10.0

Standard %	Result %	Difference %	Error %	Status
Zero	0.0	0.0	0.0	Pass
12.0	12.1	0.1	0.5	Pass
21.0	21.0	0.0	0.0	Pass

CO₂

Method: EPA 3A

Span Conc. 16.6 %

Slope 332.9

Intercept -1.0

Standard %	Result %	Difference %	Error %	Status
Zero	0.0	0.0	0.0	Pass
8.9	8.6	-0.3	-1.8	Pass
16.6	16.6	0.0	0.0	Pass

BIAS

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Start Time: 07:37

O₂

Method: EPA 3A
Span Conc. 21.0 %

Bias Results						
Standard	Cal.	Bias	Difference	Error	Status	
Gas	%	%	%	%		
Zero	0.0	0.0	0.0	0.0	Pass	
Span	12.1	11.9	-0.2	-1.0	Pass	

CO₂

Method: EPA 3A
Span Conc. 16.6 %

Bias Results						
Standard	Cal.	Bias	Difference	Error	Status	
Gas	%	%	%	%		
Zero	0.0	0.0	0.0	0.0	Pass	
Span	8.6	8.4	-0.2	-1.2	Pass	

RUN DATA

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
Start R1		
08:40	20.9	0.0
08:41	20.9	0.0
08:42	20.9	0.1
08:43	20.8	0.1
08:44	20.8	0.2
08:45	20.8	0.2
08:46	20.8	0.2
08:47	20.8	0.2
08:48	20.8	0.2
08:49	20.9	0.2
08:50	20.9	0.2
08:51	20.9	0.2
08:52	20.9	0.2
08:53	20.9	0.2
08:54	20.9	0.2
08:55	20.9	0.2
08:56	20.9	0.2
08:57	20.9	0.2
08:58	20.9	0.2
08:59	20.9	0.2
09:00	20.9	0.2
09:01	20.9	0.2
09:02	20.9	0.2
09:03	20.9	0.2
09:04	20.9	0.1
09:05	20.9	0.1
09:06	20.9	0.1
09:07	21.0	0.1
09:08	21.0	0.1
09:09	20.9	0.1
09:10	20.9	0.1
09:11	20.9	0.1
09:12	20.9	0.1
09:13	20.9	0.1
09:14	20.9	0.1
09:15	21.0	0.1
09:16	21.0	0.1
09:17	21.0	0.1
09:18	21.0	0.1
09:19	21.0	0.1

RUN DATA

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
09:20	21.0	0.1
09:21	21.0	0.1
09:22	21.0	0.1
09:23	21.0	0.1
09:24	21.0	0.1
09:25	21.0	0.1
09:26	21.0	0.1
09:27	21.0	0.1
09:28	21.0	0.1
End Port 1		
Start Port 2		
09:44	20.9	0.0
09:45	20.9	0.0
09:46	20.9	0.1
09:47	20.9	0.1
09:48	20.9	0.1
09:49	20.9	0.1
09:50	20.9	0.2
09:51	20.9	0.2
09:52	20.9	0.2
09:53	20.9	0.2
09:54	20.9	0.2
09:55	20.9	0.2
09:56	20.9	0.2
09:57	20.9	0.2
09:58	20.9	0.2
09:59	20.9	0.2
10:00	20.9	0.2
10:01	20.9	0.2
10:02	20.9	0.2
10:03	20.9	0.2
10:04	20.9	0.2
10:05	20.9	0.2
10:06	20.9	0.2
10:07	20.9	0.2
10:08	20.9	0.2
10:09	20.9	0.2
10:10	20.9	0.2
10:11	20.9	0.2
10:12	20.9	0.2
10:13	20.9	0.2

RUN DATA

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
10:14	20.9	0.2
10:15	20.9	0.2
10:16	20.9	0.2
10:17	20.9	0.2
10:18	20.9	0.2
10:19	20.9	0.2
10:20	20.9	0.2
10:21	20.9	0.2
10:22	20.9	0.2
10:23	20.9	0.2
10:24	20.9	0.2
10:25	20.9	0.2
10:26	20.9	0.2
10:27	20.9	0.2
10:28	20.9	0.2
10:29	20.9	0.2
10:30	20.9	0.2
10:31	20.9	0.2
10:32	20.9	0.2
	End Run 1	
Avg	20.9	0.2

RUN SUMMARY

Number 1

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Method	O ₂	CO ₂
Conc. Units	EPA 3A	EPA 3A
	%	%

Time: 08:39 to 10:32

Run Averages

20.9	0.2
------	-----

Pre-run Bias at 07:37

Zero Bias	0.0	0.0
Span Bias	11.9	8.4
Span Gas	12.0	8.9

Post-run Bias at 10:42

Zero Bias	0.0	0.0
Span Bias	12.0	8.4
Span Gas	12.0	8.9

Run averages corrected for the average of the pre-run and post-run bias

21.0	0.2
------	-----

BIAS AND CALIBRATION DRIFT

Number 2

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Start Time: 10:42

O₂

Method: EPA 3A
Span Conc. 21.0 %

Bias Results					
Standard	Cal.	Bias	Difference	Error	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	12.1	12.0	-0.1	-0.5	Pass

Calibration Drift					
Standard	Initial*	Final	Difference	Drift	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	11.9	12.0	0.1	0.5	Pass

*Bias No. 1

CO₂

Method: EPA 3A
Span Conc. 16.6 %

Bias Results					
Standard	Cal.	Bias	Difference	Error	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	8.6	8.4	-0.2	-1.2	Pass

Calibration Drift					
Standard	Initial*	Final	Difference	Drift	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	8.4	8.4	0.0	0.0	Pass

*Bias No. 1

RUN DATA

Number 2

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
Start R2		
11:40	20.9	0.0
11:41	20.9	0.0
11:42	20.9	0.1
11:43	20.9	0.1
11:44	20.9	0.1
11:45	20.9	0.1
11:46	20.9	0.1
11:47	20.9	0.1
11:48	20.9	0.1
11:49	20.9	0.1
11:50	20.9	0.1
11:51	20.9	0.1
11:52	20.9	0.1
11:53	20.9	0.1
11:54	20.9	0.1
11:55	20.9	0.1
11:56	20.9	0.1
11:57	20.9	0.1
11:58	20.9	0.1
11:59	20.9	0.1
12:00	20.9	0.1
12:01	20.9	0.1
12:02	20.9	0.1
12:03	20.9	0.1
12:04	20.9	0.1
12:05	20.9	0.1
12:06	20.9	0.1
12:07	20.9	0.1
12:08	20.9	0.1
12:09	20.9	0.1
12:10	20.9	0.1
12:11	20.9	0.1
12:12	20.9	0.1
12:13	20.9	0.1
12:14	20.9	0.1
12:15	20.9	0.1
12:16	20.9	0.1
12:17	20.9	0.1
12:18	20.9	0.1
12:19	20.9	0.1

RUN DATA

Number 2

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
12:20	20.9	0.1
12:21	20.9	0.1
12:22	20.8	0.1
12:23	20.8	0.1
12:24	20.9	0.1
12:25	20.8	0.1
12:26	20.8	0.1
12:27	20.8	0.1
12:28	20.8	0.1
End Port 1		
Start Port 2		
12:40	20.9	0.1
12:41	20.8	0.1
12:42	20.8	0.1
12:43	20.8	0.1
12:44	20.8	0.1
12:45	20.8	0.1
12:46	20.8	0.1
12:47	20.8	0.1
12:48	20.8	0.1
12:49	20.9	0.1
12:50	20.9	0.1
12:51	20.9	0.1
12:52	20.9	0.1
12:53	20.9	0.1
12:54	20.9	0.1
12:55	20.9	0.1
12:56	20.9	0.1
12:57	20.9	0.1
12:58	20.9	0.1
12:59	20.9	0.1
13:00	20.9	0.1
13:01	20.9	0.1
13:02	20.9	0.1
13:03	20.9	0.1
13:04	20.9	0.1
13:05	20.9	0.1
13:06	20.9	0.1
13:07	20.9	0.0
13:08	20.9	0.1
13:09	20.9	0.1

RUN DATA

Number 2

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
13:10	20.9	0.1
13:11	20.9	0.1
13:12	20.9	0.1
13:13	20.9	0.1
13:14	20.9	0.1
13:15	20.9	0.1
13:16	20.9	0.1
13:17	20.9	0.0
13:18	20.9	0.1
13:19	20.9	0.0
13:20	20.9	0.1
13:21	20.9	0.1
13:22	20.9	0.1
13:23	20.9	0.1
13:24	20.9	0.0
13:25	20.9	0.1
13:26	20.9	0.0
13:27	20.9	0.1
13:28	20.9	0.1
	End Run 2	
Avg	20.9	0.1

RUN SUMMARY

Number 2

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Method	O₂	CO₂
Conc. Units	EPA 3A	EPA 3A
	%	%

Time: 11:39 to 13:28

Run Averages

20.9 0.1

Pre-run Bias at 10:42

Zero Bias	0.0	0.0
Span Bias	12.0	8.4
Span Gas	12.0	8.9

Post-run Bias at 13:35

Zero Bias	0.1	0.0
Span Bias	12.0	8.4
Span Gas	12.0	8.9

Run averages corrected for the average of the pre-run and post-run bias

20.9 0.1

BIAS AND CALIBRATION DRIFT

Number 3

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Start Time: 13:35

O₂

Method: EPA 3A
Span Conc. 21.0 %

Bias Results					
Standard	Cal.	Bias	Difference	Error	Status
Gas	%	%	%	%	
Zero	0.0	0.1	0.1	0.5	Pass
Span	12.1	12.0	-0.1	-0.5	Pass

Calibration Drift					
Standard	Initial*	Final	Difference	Drift	Status
Gas	%	%	%	%	
Zero	0.0	0.1	0.1	0.5	Pass
Span	12.0	12.0	0.0	0.0	Pass

*Bias No. 2

CO₂

Method: EPA 3A
Span Conc. 16.6 %

Bias Results					
Standard	Cal.	Bias	Difference	Error	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	8.6	8.4	-0.2	-1.2	Pass

Calibration Drift					
Standard	Initial*	Final	Difference	Drift	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	8.4	8.4	0.0	0.0	Pass

*Bias No. 2

RUN DATA

Number 3

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
Start R3		
14:08	20.8	0.0
14:09	20.8	0.1
14:10	20.8	0.1
14:11	20.8	0.1
14:12	20.8	0.2
14:13	20.8	0.2
14:14	20.8	0.2
14:15	20.8	0.2
14:16	20.8	0.2
14:17	20.8	0.2
14:18	20.8	0.2
14:19	20.8	0.2
14:20	20.8	0.2
14:21	20.8	0.2
14:22	20.8	0.2
14:23	20.8	0.2
14:24	20.8	0.2
14:25	20.8	0.2
14:26	20.8	0.2
14:27	20.8	0.2
14:28	20.8	0.2
14:29	20.9	0.2
14:30	20.8	0.2
14:31	20.9	0.2
14:32	20.8	0.1
14:33	20.8	0.1
14:34	20.9	0.1
14:35	20.9	0.1
14:36	20.9	0.1
14:37	20.9	0.1
14:38	20.9	0.1
14:39	20.9	0.1
14:40	20.9	0.1
14:41	20.9	0.1
14:42	20.9	0.1
14:43	20.9	0.1
14:44	20.9	0.1
14:45	20.9	0.1
14:46	20.9	0.1
14:47	20.9	0.1

RUN DATA

Number 3

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
14:48	20.9	0.1
14:49	20.9	0.1
14:50	20.9	0.1
14:51	20.9	0.1
14:52	20.9	0.1
14:53	20.9	0.1
14:54	20.9	0.1
14:55	20.9	0.1
14:56	20.9	0.1
End Port 1		
Start Port 2		
15:10	20.8	0.1
15:11	20.8	0.1
15:12	20.8	0.1
15:13	20.8	0.1
15:14	20.8	0.1
15:15	20.8	0.1
15:16	20.8	0.1
15:17	20.8	0.1
15:18	20.8	0.1
15:19	20.9	0.2
15:20	20.8	0.2
15:21	20.8	0.2
15:22	20.8	0.2
15:23	20.8	0.2
15:24	20.9	0.2
15:25	20.9	0.2
15:26	20.9	0.2
15:27	20.9	0.2
15:28	20.9	0.2
15:29	20.8	0.2
15:30	20.9	0.2
15:31	20.9	0.2
15:32	20.9	0.2
15:33	20.9	0.2
15:34	20.9	0.2
15:35	20.9	0.2
15:36	20.9	0.2
15:37	20.9	0.2
15:38	20.9	0.2
15:39	20.8	0.2

RUN DATA

Number 3

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Time	O ₂ %	CO ₂ %
15:40	20.8	0.2
15:41	20.8	0.2
15:42	20.8	0.2
15:43	20.8	0.2
15:44	20.8	0.2
15:45	20.8	0.2
15:46	20.8	0.2
15:47	20.8	0.2
15:48	20.8	0.2
15:49	20.8	0.2
15:50	20.8	0.2
15:51	20.8	0.2
15:52	20.8	0.2
15:53	20.8	0.2
15:54	20.8	0.2
15:55	20.8	0.2
15:56	20.8	0.2
15:57	20.8	0.2
15:58	20.8	0.2
	End Run 3	
Avg	20.8	0.2

RUN SUMMARY

Number 3

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Calibration 1

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Method	O₂	CO₂
Conc. Units	EPA 3A	EPA 3A
	%	%

Time: 14:07 to 15:58

Run Averages

20.8 0.2

Pre-run Bias at 13:35

Zero Bias	0.1	0.0
Span Bias	12.0	8.4
Span Gas	12.0	8.9

Post-run Bias at 16:11

Zero Bias	0.1	0.0
Span Bias	12.0	8.4
Span Gas	12.0	8.9

Run averages corrected for the average of the pre-run and post-run bias

20.9 0.2

BIAS AND CALIBRATION DRIFT

Number 4

Client: **Chemours**
Location: **CHEMOURS**
Source: **VE South**

Project Number: **15418.002.009**
Operator: **CMH**
Date: **9 Jan 2019**

Calibration 1

Start Time: 16:11

O₂

Method: EPA 3A
Span Conc. 21.0 %

Bias Results					
Standard	Cal.	Bias	Difference	Error	Status
Gas	%	%	%	%	
Zero	0.0	0.1	0.1	0.5	Pass
Span	12.1	12.0	-0.1	-0.5	Pass

Calibration Drift					
Standard	Initial*	Final	Difference	Drift	Status
Gas	%	%	%	%	
Zero	0.1	0.1	0.0	0.0	Pass
Span	12.0	12.0	0.0	0.0	Pass

*Bias No. 3

CO₂

Method: EPA 3A
Span Conc. 16.6 %

Bias Results					
Standard	Cal.	Bias	Difference	Error	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	8.6	8.4	-0.2	-1.2	Pass

Calibration Drift					
Standard	Initial*	Final	Difference	Drift	Status
Gas	%	%	%	%	
Zero	0.0	0.0	0.0	0.0	Pass
Span	8.4	8.4	0.0	0.0	Pass

*Bias No. 3

APPENDIX C
LABORATORY ANALYTICAL REPORT

Note: The complete analytical report is included on the attached CD.

Client Sample Results

Client: Chemours Company FC, LLC The
Project/Site: VE South Stack - M0010

TestAmerica Job ID: 140-13930-1

Client Sample ID: R-1747,1748 VE SOUTH R1 M0010 FH

Lab Sample ID: 140-13930-1

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	196		2.51	0.271	ug/Sample		01/16/19 06:43	01/23/19 13:07	20
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	103	D	50 - 200				01/16/19 06:43	01/23/19 13:07	20

Client Sample ID: R-1749,1750,1752 VE SOUTH R1 M0010 BH

Lab Sample ID: 140-13930-2

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	14.8		0.200	0.0400	ug/Sample		01/16/19 06:45	01/23/19 13:36	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	74		50 - 200				01/16/19 06:45	01/23/19 13:36	1

**Client Sample ID: R-1751 VE SOUTH R1 M0010 IMP 1,2&3
CONDENSATE**

Lab Sample ID: 140-13930-3

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - HFPO-DA

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.200	0.0102	ug/Sample		01/21/19 04:09	01/23/19 14:12	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	90		50 - 200				01/21/19 04:09	01/23/19 14:12	1

**Client Sample ID: R-1753 VE SOUTH R1 M0010
BREAKTHROUGH XAD-2 RESIN TUBE**

Lab Sample ID: 140-13930-4

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	0.0818	J	0.200	0.0400	ug/Sample		01/16/19 06:45	01/23/19 13:40	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	82		50 - 200				01/16/19 06:45	01/23/19 13:40	1

TestAmerica Knoxville

Client Sample Results

Client: Chemours Company FC, LLC The
Project/Site: VE South Stack - M0010

TestAmerica Job ID: 140-13930-1

Client Sample ID: R-1754,1755 VE SOUTH R2 M0010 FH

Lab Sample ID: 140-13930-5

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	155		2.51	0.271	ug/Sample		01/16/19 06:43	01/23/19 13:10	20
Surrogate	%Recovery	Qualifier	Limits						
13C3 HFPO-DA	109	D	50 - 200						
				Prepared	Analyzed	Dil Fac			
				01/16/19 06:43	01/23/19 13:10	20			

Client Sample ID: R-1756,1757,1759 VE SOUTH R2 M0010 BH

Lab Sample ID: 140-13930-6

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	99.3		0.800	0.160	ug/Sample		01/16/19 06:45	01/23/19 13:43	4
Surrogate	%Recovery	Qualifier	Limits						
13C3 HFPO-DA	78	D	50 - 200						
				Prepared	Analyzed	Dil Fac			
				01/16/19 06:45	01/23/19 13:43	4			

Client Sample ID: R-1758 VE SOUTH R2 M0010 IMP 1,2&3

Lab Sample ID: 140-13930-7

CONDENSATE

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - HFPO-DA

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	0.173	J	0.184	0.00938	ug/Sample		01/21/19 04:09	01/23/19 14:16	1
Surrogate	%Recovery	Qualifier	Limits						
13C3 HFPO-DA	96		50 - 200						
				Prepared	Analyzed	Dil Fac			
				01/21/19 04:09	01/23/19 14:16	1			

Client Sample ID: R-1760 VE SOUTH R2 M0010

Lab Sample ID: 140-13930-8

BREAKTHROUGH XAD-2 RESIN TUBE

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.200	0.0400	ug/Sample		01/16/19 06:45	01/23/19 13:46	1
Surrogate	%Recovery	Qualifier	Limits						
13C3 HFPO-DA	88		50 - 200						
				Prepared	Analyzed	Dil Fac			
				01/16/19 06:45	01/23/19 13:46	1			

TestAmerica Knoxville

Client Sample Results

Client: Chemours Company FC, LLC The
Project/Site: VE South Stack - M0010

TestAmerica Job ID: 140-13930-1

Client Sample ID: R-1761,1762 VE SOUTH R3 M0010 FH

Lab Sample ID: 140-13930-9

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	163		1.52	0.164	ug/Sample		01/16/19 06:43	01/23/19 13:13	20
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	103	D	50 - 200				01/16/19 06:43	01/23/19 13:13	20

Client Sample ID: R-1763,1764,1766 VE SOUTH R3 M0010 BH

Lab Sample ID: 140-13930-10

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	26.6		0.225	0.0450	ug/Sample		01/16/19 06:45	01/23/19 13:49	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	75		50 - 200				01/16/19 06:45	01/23/19 13:49	1

Client Sample ID: R-1765 VE SOUTH R3 M0010 IMP 1,2&3

Lab Sample ID: 140-13930-11

CONDENSATE

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - HFPO-DA

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.194	0.00989	ug/Sample		01/21/19 04:09	01/23/19 14:19	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	91		50 - 200				01/21/19 04:09	01/23/19 14:19	1

Client Sample ID: R-1767 VE SOUTH R3 M0010

Lab Sample ID: 140-13930-12

BREAKTHROUGH XAD-2 RESIN TUBE

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.200	0.0400	ug/Sample		01/16/19 06:45	01/23/19 13:53	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	82		50 - 200				01/16/19 06:45	01/23/19 13:53	1

TestAmerica Knoxville

Client Sample Results

Client: Chemours Company FC, LLC The
Project/Site: VE South QC Samples - M0010

TestAmerica Job ID: 140-13931-1

Client Sample ID: A-5596,5597 VE SOUTH QC M0010 FH BT

Lab Sample ID: 140-13931-1

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	0.321		0.0260	0.00281	ug/Sample		01/16/19 06:43	01/23/19 13:17	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	99		50 - 200	01/16/19 06:43	01/23/19 13:17	1

Client Sample ID: A-5598,5599,5601 VE SOUTH QC M0010 BH

Lab Sample ID: 140-13931-2

BT

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	0.415		0.200	0.0400	ug/Sample		01/15/19 04:25	01/23/19 11:46	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	80		50 - 200	01/15/19 04:25	01/23/19 11:46	1

Client Sample ID: A-5600 VE SOUTH QC M0010 IMP 1,2&3

Lab Sample ID: 140-13931-3

CONDENSATE BT

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - HFPO-DA

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	0.000574	J	0.00250	0.000128	ug/Sample		01/21/19 04:09	01/23/19 14:25	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	117		50 - 200	01/21/19 04:09	01/23/19 14:25	1

Client Sample ID: A-5602 VE SOUTH QC M0010

Lab Sample ID: 140-13931-4

BREAKTHROUGH XAD-2 RESIN TUBE BT

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.200	0.0400	ug/Sample		01/15/19 04:25	01/23/19 11:49	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	87		50 - 200	01/15/19 04:25	01/23/19 11:49	1

TestAmerica Knoxville

Client Sample Results

Client: Chemours Company FC, LLC The
Project/Site: VE South QC Samples - M0010

TestAmerica Job ID: 140-13931-1

Client Sample ID: A-5603 VE SOUTH QC M0010 DI WATER RB

Lab Sample ID: 140-13931-5

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - HFPO-DA

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.00250	0.000128	ug/Sample		01/21/19 04:09	01/23/19 14:29	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	130		50 - 200				01/21/19 04:09	01/23/19 14:29	1

Client Sample ID: A-5604 VE SOUTH QC M0010 MEOH WITH 5% NH4OH RB

Lab Sample ID: 140-13931-6

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.0250	0.00500	ug/Sample		01/15/19 04:25	01/23/19 11:52	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	108		50 - 200				01/15/19 04:25	01/23/19 11:52	1

Client Sample ID: A-5605 VE SOUTH QC M0010 XAD-2 RESIN TUBE RB

Lab Sample ID: 140-13931-7

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.200	0.0400	ug/Sample		01/15/19 04:25	01/23/19 11:55	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	92		50 - 200				01/15/19 04:25	01/23/19 11:55	1

Client Sample ID: A-5606 VE SOUTH QC M0010 MEOH WITH 5% NH4OH TB

Lab Sample ID: 140-13931-8

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.0250	0.00500	ug/Sample		01/15/19 04:25	01/23/19 11:59	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	111		50 - 200				01/15/19 04:25	01/23/19 11:59	1

TestAmerica Knoxville

Client Sample Results

Client: Chemours Company FC, LLC The
 Project/Site: VE South QC Samples - M0010

TestAmerica Job ID: 140-13931-1

Client Sample ID: A-5607 VE SOUTH QC M0010 XAD-2 RESIN

Lab Sample ID: 140-13931-9

TUBE TB

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	ND		0.200	0.0400	ug/Sample		01/15/19 04:25	01/23/19 12:02	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	88		50 - 200	01/15/19 04:25	01/23/19 12:02	1

Client Sample ID: A-5608 VE SOUTH QC M0010 COMBINED

Lab Sample ID: 140-13931-10

GLASSWARE RINSES (MEOH/5% NH4OH) PB

Date Collected: 01/09/19 00:00

Matrix: Air

Date Received: 01/13/19 07:30

Sample Container: Air Train

Method: 8321A - PFOA and PFOS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
HFPO-DA	0.00599	J	0.0250	0.00500	ug/Sample		01/15/19 04:25	01/23/19 12:05	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
13C3 HFPO-DA	103		50 - 200	01/15/19 04:25	01/23/19 12:05	1

APPENDIX D
SAMPLE CALCULATIONS

**SAMPLE CALCULATIONS FOR
HFPO DIMER ACID (METHOD 0010)**

Client: Chemours
Test Number: Run 3
Test Location: VE South Stack

Plant: Fayetteville, NC
Test Date: 01/09/19
Test Period: 1408-1558

1. HFPO Dimer Acid concentration, lbs/dscf.

$$\text{Conc1} = \frac{W \times 2.2046 \times 10^{-9}}{V_m(\text{std})}$$

$$\text{Conc1} = \frac{189.6 \times 2.2046 \times 10^{-9}}{64.430}$$

$$\text{Conc1} = 6.49\text{E-}09$$

Where:

W = Weight of HFPO Dimer Acid collected in sample in ug.

Conc1 = Division Stack HFPO Dimer Acid concentration, lbs/dscf.

2.2046×10^{-9} = Conversion factor from ug to lbs.

2. HFPO Dimer Acid concentration, ug/dscm.

$$\text{Conc2} = W / (V_m(\text{std}) \times 0.02832)$$

$$\text{Conc2} = 189.6 / (64.430 \times 0.02832)$$

$$\text{Conc2} = 103.90$$

Where:

Conc2 = Division Stack HFPO Dimer Acid concentration, ug/dscm.

0.02832 = Conversion factor from cubic feet to cubic meters.

3. HFPO Dimer Acid mass emission rate, lbs/hr.

$$\text{MR1}_{(\text{Outlet})} = \text{Conc1} \times Q_s(\text{std}) \times 60 \text{ min/hr}$$

$$\text{MR1}_{(\text{Outlet})} = 6.49\text{E-}09 \times 13134 \times 60$$

$$\text{MR1}_{(\text{Outlet})} = 5.11\text{E-}03$$

Where:

$\text{MR1}_{(\text{Outlet})}$ = Division Stack HFPO Dimer Acid mass emission rate, lbs/hr.

4. HFPO Dimer Acid mass emission rate, g/sec.

$$\text{MR2}_{(\text{Outlet})} = \text{PMR1} \times 453.59 / 3600$$

$$\text{MR2}_{(\text{Outlet})} = 5.11\text{E-}03 \times 453.59 / 3600$$

$$\text{MR2}_{(\text{Outlet})} = 6.44\text{E-}04$$

Where:

$\text{MR2}_{(\text{Outlet})}$ = Division Stack HFPO Dimer Acid mass emission rate, g/sec.

453.6 = Conversion factor from pounds to grams.

3600 = Conversion factor from hours to seconds.

**EXAMPLE CALCULATIONS FOR
VOLUMETRIC FLOW AND MOISTURE AND ISOKINETICS**

Client: Chemours
Test Number: Run 3
Test Location: VE South Stack

Facility: Fayetteville, NC
Test Date: 1/09/19
Test Period: 1408-1558

1. Volume of dry gas sampled at standard conditions (68 deg F, 29.92 in. Hg), dscf.

$$Vm(std) = \frac{17.64 \times Y \times Vm \times \left(Pb + \frac{\Delta H}{13.6} \right)}{(Tm + 460)}$$

$$Vm(std) = \frac{17.64 \times 0.9915 \times 63.392 \times \left(29.94 + \frac{1.410}{13.6} \right)}{57.00 + 460} = 64.430$$

Where:

$Vm(std)$ = Volume of gas sample measured by the dry gas meter, corrected to standard conditions, dscf.
 Vm = Volume of gas sample measured by the dry gas meter at meter conditions, dcf.
 Pb = Barometric Pressure, in Hg.
 ΔH = Average pressure drop across the orifice meter, in H₂O
 Tm = Average dry gas meter temperature, deg F.
 Y = Dry gas meter calibration factor.
 17.64 = Factor that includes ratio of standard temperature (528 deg R) to standard pressure (29.92 in. Hg), deg R/in. Hg.
 13.6 = Specific gravity of mercury.

2. Volume of water vapor in the gas sample corrected to standard conditions, scf.

$$Vw(std) = (0.04707 \times Vwc) + (0.04715 \times Wwsg)$$

$$Vw(std) = (0.04707 \times 10.0) + (0.04715 \times 20.8) = 1.45$$

Where:

$Vw(std)$ = Volume of water vapor in the gas sample corrected to standard conditions, scf.
 Vwc = Volume of liquid condensed in impingers, ml.
 $Wwsg$ = Weight of water vapor collected in silica gel, g.
 0.04707 = Factor which includes the density of water (0.002201 lb/ml), the molecular weight of water (18.0 lb/lb-mole), the ideal gas constant 21.85 (in. Hg) (ft³/lb-mole)(deg R); absolute temperature at standard conditions (528 deg R), absolute pressure at standard conditions (29.92 in. Hg), ft³/ml.
 0.04715 = Factor which includes the molecular weight of water (18.0 lb/lb-mole), the ideal gas constant 21.85 (in. Hg) (ft³/lb-mole)(deg R); absolute temperature at standard conditions (528 deg R), absolute pressure at standard conditions (29.92 in. Hg), and 453.6 g/lb, ft³/g.

3. Moisture content

$$\text{bws} = \frac{V_w(\text{std})}{V_w(\text{std}) + V_m(\text{std})}$$
$$\text{bws} = \frac{1.45}{1.45 + 64.430} = 0.022$$

Where:

bws = Proportion of water vapor, by volume, in the gas stream, dimensionless.

4. Mole fraction of dry gas.

$$\text{Md} = 1 - \text{bws}$$
$$\text{Md} = 1 - 0.022 = 0.978$$

Where:

Md = Mole fraction of dry gas, dimensionless.

5. Dry molecular weight of gas stream, lb/lb-mole.

$$\text{MWd} = (0.440 \times \% \text{CO}_2) + (0.320 \times \% \text{O}_2) + (0.280 \times (\% \text{N}_2 + \% \text{CO}))$$
$$\text{MWd} = (0.440 \times 0.0) + (0.320 \times 20.9) + (0.280 \times (79.1 + 0.0))$$
$$\text{MWd} = 28.84$$

Where:

MWd = Dry molecular weight, lb/lb-mole.
% CO₂ = Percent carbon dioxide by volume, dry basis.
% O₂ = Percent oxygen by volume, dry basis.
% N₂ = Percent nitrogen by volume, dry basis.
% CO = Percent carbon monoxide by volume, dry basis.
0.440 = Molecular weight of carbon dioxide, divided by 100.
0.320 = Molecular weight of oxygen, divided by 100.
0.280 = Molecular weight of nitrogen or carbon monoxide, divided by 100.

6. Actual molecular weight of gas stream (wet basis), lb/lb-mole.

$$\text{MWs} = (\text{MWd} \times \text{Md}) + (18 \times (1 - \text{Md}))$$
$$\text{MWs} = (28.84 \times 0.978) + (18 \times (1 - 0.978)) = 28.60$$

Where:

MWs = Molecular weight of wet gas, lb/lb-mole.
18 = Molecular weight of water, lb/lb-mole.

7. Average velocity of gas stream at actual conditions, ft/sec.

$$V_s = 85.49 \times C_p \times ((\Delta p)^{1/2})_{avg} \times \left(\frac{T_s (avg)}{P_s \times MW_s} \right)^{1/2}$$

$$V_s = 85.49 \times 0.84 \times 0.41666 \times \left(\frac{539}{29.98 \times 28.60} \right)^{1/2} = 23.7$$

Where:

- V_s = Average gas stream velocity, ft/sec.
- 85.49 = Pitot tube constant, ft/sec $\times \frac{(\text{lb/lb-mole})(\text{in. Hg})^{1/2}}{(\text{deg R})(\text{in H}_2\text{O})}$
- C_p = Pitot tube coefficient, dimensionless.
- T_s = Absolute gas stream temperature, deg R = $T_s, \text{ deg F} + 460$.
- P_s = Absolute gas stack pressure, in. Hg. = $P_b + \frac{P(\text{static})}{13.6}$
- Δp = Velocity head of stack, in. H₂O.

8. Average gas stream volumetric flow rate at actual conditions, wacf/min.

$$Q_s(\text{act}) = 60 \times V_s \times A_s$$

$$Q_s(\text{act}) = 60 \times 23.7 \times 9.62 = 13699$$

Where:

- $Q_s(\text{act})$ = Volumetric flow rate of wet stack gas at actual conditions, wacf/min.
- A_s = Cross-sectional area of stack, ft².
- 60 = Conversion factor from seconds to minutes.

9. Average gas stream dry volumetric flow rate at standard conditions, dscf/min.

$$Q_s(\text{std}) = 17.64 \times M_d \times \frac{P_s}{T_s} \times Q_s(\text{act})$$

$$Q_s(\text{std}) = 17.64 \times 0.978 \times \frac{29.98}{539.4} \times 13699$$

$$Q_s(\text{std}) = 13134$$

Where:

- $Q_s(\text{std})$ = Volumetric flow rate of dry stack gas at standard conditions, dscf/min.

10. Isokinetic variation calculated from intermediate values, percent.

$$I = \frac{17.327 \times Ts \times Vm(std)}{Vs \times O \times Ps \times Md \times (Dn)^2}$$

$$I = \frac{17.327 \times 539 \times 64.430}{23.7 \times 96 \times 29.98 \times 0.978 \times (0.300)^2} = 100.2$$

Where:

- I = Percent of isokinetic sampling.
- O = Total sampling time, minutes.
- Dn = Diameter of nozzle, inches.
- 17.327 = Factor which includes standard temperature (528 deg R), standard pressure (29.92 in. Hg), the formula for calculating area of circle $D^{2/4}$, conversion of square feet to square inches (144), conversion of seconds to minutes (60), and conversion to percent (100), $\frac{(in. Hg)(in^2)(min)}{(deg R)(ft^2)(sec)}$

APPENDIX E
EQUIPMENT CALIBRATION RECORDS

Balance ID:

Date	Initials	Calibration Weight	Measured Weight ⁽¹⁾	Maintenance and Adjustments
10/30/17	MPW	500.0	499.8	
10/31/17	MPW	500.0	499.9	
9/5/18	CH	500.0	500.1	
9/13/18	ZA	500.0	500.1	
10/8/18	JDO	500	499.6	NA - SOC
10/9/18	JDO	500	499.7	NA - SOC
10/10/18	MV	500	499.6	NA - SOC
10/11/18	JDO	500	499.7	NA - SOC
10/23/18	TB	500	499.8	NA - Chem CW
10/24/18	JDO	500	499.0	NA Chem CW
10/25/18	MV	500	499.8	NA Chem CW
01/07/19	CH	500	499.7	NA Chemours
01/08/19	CH	500	499.7	NA Chemours
01/08/19	CH	500	499.7	NA Chemours
1/10/19	JDO	500	499.6	NA Chem
1/11/19	CW	500.0	499.8	NA Chemours

(1) Measured weight within ± 0.5 grams of calibration weight

Long Cal and Temperature Cal Datasheet for Standard Dry Gas Meter Console

Calibrator PM

Meter Box Number 21

Ambient Temp 71

Date 12-Feb-18

Wet Test Meter Number P-2952

Temp Reference Source Thermocouple Simulator
(Accuracy +/- 1°F)

Dry Gas Meter Number 17485140

Setting	Gas Volume		Temperatures				Time, min (O)	Baro Press, in Hg (Pb)	
	Wet Test Meter	Dry gas Meter	Wet Test Meter	Dry Gas Meter				Y	ΔH
in H ₂ O (ΔH)	ft ³ (Vw)	ft ³ (Vd)	°F (Tw)	Outlet, °F (Tdo)	Inlet, °F (Tdi)	Average, °F (Td)			
0.5	5.0	570.015	70.0	69.00	69.00	70.0	13.00	0.9948	1.9159
		575.035		71.00	71.00				
		5.020		70.00	70.00				
1.0	5.0	575.035	70.0	71.00	71.00	71.5	9.3	0.9910	1.9555
		580.082		72.00	72.00				
		5.047		71.50	71.50				
1.5	10.0	580.082	70.0	72.00	72.00	73.0	15.6	0.9898	2.0575
		590.205		74.00	74.00				
		10.123		73.00	73.00				
2.0	10.0	590.205	70.0	74.00	74.00	74.5	13.6	0.9945	2.0792
		600.296		75.00	75.00				
		10.091		74.50	74.50				
3.0	10.0	600.296	70.0	75.00	75.00	75.5	11.0	0.9873	2.0365
		610.454		76.00	76.00				
		10.158		75.50	75.50				
Average								0.9915	2.0089

Vw - Gas Volume passing through the wet test meter
 Vd - Gas Volume passing through the dry gas meter
 Tw - Temp of gas in the wet test meter
 Tdi - Temp of the inlet gas of the dry gas meter
 Tdo - Temp of the outlet gas of the dry gas meter
 Td - Average temp of the gas in the dry gas meter

O - Time of calibration run
 Pb - Barometric Pressure
 ΔH - Pressure differential across orifice
 Y - Ratio of accuracy of wet test meter to dry gas meter

$$Y = \frac{Vw * Pb * (td + 460)}{Vd * \left[Pb + \frac{(\Delta H)}{13.6} \right] * (tw + 460)}$$

$$\Delta H = \left[\frac{0.0317 * \Delta H}{Pb * (td + 460)} \right] * \left[\frac{(tw + 460) * O}{Vw} \right]^2$$

Reference Temperature Select Temperature <input type="radio"/> °C <input checked="" type="radio"/> °F	Temperature Reading from Individual Thermocouple Input ¹						Average Temperature Reading	Temp Difference ² (%)
	Channel Number							
	1	2	3	4	5	6		
32	32	32	32	32	32		32.0	0.0%
212	212	212	212	212	212		212.0	0.0%
932	932	932	932	932	932		932.0	0.0%
1832	1830	1830	1830	1830	1830		1830.0	0.1%

¹ - Channel Temps must agree with +/- 5°F or 3°C

² - Acceptable Temperature Difference less than 1.5 %

$$\text{Temp Diff} = \left[\frac{(\text{Reference Temp}^{\circ\text{F}} + 460) - (\text{Test Temp}^{\circ\text{F}} + 460)}{\text{Reference Temp}^{\circ\text{F}} + 460} \right]$$

Post Test Calibration

Calibrator PM

Meter Box Number 21

Client Chemours

Date 1/28/19

Wet Test Meter Number P-2952

Location/Plant Fayetteville, NC

Dry Gas Meter Number 17485140

PreTest Y 0.9915

Baro Press, in Hg (Pb)	29.88
---------------------------------	-------

Setting	Gas Volume		Temperatures				Time, min (O)	Y
	Orifice Manometer	Wet Test Meter	Dry gas Meter	Wet Test Meter	Dry Gas Meter			
in H ₂ O (ΔH)	ft ³ (Vw)	ft ³ (Vd)	°F (Tw)	Outlet, °F (Tdo)	Inlet, °F (Tdi)	Average, °F (Td)		
1.40	10.0	559.252	71.5	72.00	73.00	72.5	16.1	1.0027
		569.210						
		9.958						
1.40	10.0	569.210	71.5	73.00	75.00	74.0	16.2	1.0002
		579.221						
		10.011						
1.40	10.0	579.221	71.5	75.00	76.00	75.5	16.0	1.0068
		589.194						
		9.973						
Average							1.0032	
Difference¹							0.0117	

1 - Tolerance for Y is less than 0.0500

Vw - Gas Volume passing through the wet test meter

Vd - Gas Volume passing through the dry gas meter

Tw - Temp of gas in the wet test meter

Tdi - Temp of the inlet gas of the dry gas meter

Tdo - Temp of the outlet gas of the dry gas meter

Td - Average temp of the gas in the dry gas meter

O - Time of calibration run

Pb - Barometric Pressure

ΔH - Pressure differential across orifice

Y - Ratio of accuracy of wet test meter to dry gas meter

$$Y = \frac{Vw * Pb * (td + 460)}{Vd * \left[Pb + \frac{(\Delta H)}{13.6} \right] * (tw + 460)}$$

No Long Calibration Required



Y Factor Calibration Check Calculation
MODIFIED METHOD 0010 TEST TRAIN
VE SOUTH STACK
METER BOX NO. 21
01/09/2019

	Run 1	Run 2	Run 3
MWd = Dry molecular weight source gas, lb/lb-mole.			
0.32 = Molecular weight of oxygen, divided by 100.			
0.44 = Molecular weight of carbon dioxide, divided by 100.			
0.28 = Molecular weight of nitrogen or carbon monoxide, divided by 100.			
% CO ₂ = Percent carbon dioxide by volume, dry basis.	0.0	0.0	0.0
% O ₂ = Percent oxygen by volume, dry basis.	20.9	20.9	20.9

$$MWd = (0.32 * O_2) + (0.44 * CO_2) + (0.28 * (100 - (CO_2 + O_2)))$$

$$MWd = (0.32 * 20.9) + (0.44 * 0) + (0.28 * (100 - (0 + 20.9)))$$

$$MWd = (6.69) + (0.00) + (22.15)$$

MWd =	28.84	28.84	28.84
--------------	-------	-------	-------

	Run 1	Run 2	Run 3
Tma = Source Temperature, absolute(°R)			
Tm = Average dry gas meter temperature, deg F.	50.3	55.9	57.0

$$Tma = T_s + 460$$

$$Tma = 50.29 + 460$$

Tma =	510.29	515.88	517.00
--------------	--------	--------	--------

	Run 1	Run 2	Run 3
Ps = Absolute meter pressure, inches Hg.			
13.60 = Specific gravity of mercury.			
delta H = Avg pressure drop across the orifice meter during sampling, in H ₂ O	1.31	1.51	1.41
Pb = Barometric Pressure, in Hg.	29.94	29.94	29.94

$$Pm = Pb + (\text{delta H} / 13.6)$$

$$Pm = 29.94 + (1.30508333333333 / 13.6)$$

Pm =	30.04	30.05	30.04
-------------	-------	-------	-------

	Run 1	Run 2	Run 3
Yqa = dry gas meter calibration check value, dimensionless.			
0.03 = (29.92/528)(0.75) ² (in. Hg/ ^o R) cfm ² .			
29.00 = dry molecular weight of air, lb/lb-mole.			
Vm = Volume of gas sample measured by the dry gas meter at meter conditions, dcf.	62.591	65.028	63.392
Y = Dry gas meter calibration factor (based on full calibration)	0.9915	0.9915	0.9915
Delta H@ = Dry Gas meter orifice calibration coefficient, in. H ₂ O.	2.0089	2.0089	2.0089
avg SQRT Delta H = Avg SQRT press. drop across the orifice meter during sampling, in. H ₂ O	1.1358	1.2228	1.1828
O = Total sampling time, minutes.	96	96	96

$$Yqa = (O / Vm) * \text{SQRT} (0.0319 * Tma * 29) / (\text{Delta H}@ * Pm * MWd) * \text{avg SQRT Delta H}$$

$$Yqa = (96.00 / 62.59) * \text{SQRT} (0.0319 * 510.29 * 29) / (2.01 * 30.04 * 28.84) * 1.14$$

$$Yqa = 1.534 * \text{SQRT} 472.071 / 1,740.176 * 1.14$$

Yqa =	0.9073	0.9452	0.9390
--------------	--------	--------	--------

Diff = Absolute difference between Yqa and Y	8.49	4.67	5.30
--	------	------	------

$$\text{Diff} = ((Y - Yqa) / Y) * 100$$

$$\text{Diff} = ((0.9915 - 0.907) / 0.9915) * 100$$

Average Diff = 6.15


Allowable = 5.0

Type S Pitot Tube Inspection Data Form

Pitot Tube Identification Number: P-694

If all Criteria PASS
Cp is equal to 0.84

Inspection Date 2/19/18 Individual Conducting Inspection KS




Distance to A Plane (PA) - inches 0.432
 Distance to B Plane (PB) - inches 0.432
 Pitot OD (Dt) - inches 0.375

PASS/FAIL
 PASS
 PASS

$1.05 D_t < P < 1.5 D_t$


PA must Equal PB



Are Open Faces Aligned
Perpendicular to the Tube Axis

YES NO

PASS



Angle of Q1 from vertical A Tube-
degrees (absolute) 4
 Angle of Q2 from vertical B Tube-
degrees (absolute) 3

PASS

PASS

Q1 and Q2 must be $\leq 10^\circ$



Angle of B1 from
vertical A Tube-
degrees (absolute) 4


PASS



Angle of B1 from
vertical B Tube-
degrees (absolute) 2

PASS

B1 or B2 must be $\leq 5^\circ$




Horizontal offset between A and
B Tubes (Z) - inches 0.024

PASS

Vertical offset between A and B
Tubes (W) - inches 0.028


PASS



Distance between Sample
Nozzle and Pitot (X) - inches 0.962


PASS

X must be ≥ 0.75 inches



Impact Pressure
Opening Plane is
above the Nozzle
Entry Plane

YES NO
 NA



Thermocouple meets
the Distance Criteria
in the adjacent figure

YES NO
 NA

Thermocouple meets
the Distance Criteria
in the adjacent figure

YES NO
 NA

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI79E15A00E4	Reference Number: 82-401288926-1
Cylinder Number: CC18055	Cylinder Volume: 150.5 CF
Laboratory: 124 - Riverton (SAP) - NJ	Cylinder Pressure: 2015 PSIG
PGVP Number: B52018	Valve Outlet: 590
Gas Code: CO2,O2,BALN	Certification Date: Sep 04, 2018

Expiration Date: Sep 04, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	9.000 %	8.864 %	G1	+/- 0.7% NIST Traceable	09/04/2018
OXYGEN	12.00 %	12.00 %	G1	+/- 0.4% NIST Traceable	09/04/2018
NITROGEN	Balance			-	

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13060629	CC413730	13.359 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	May 09, 2019

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA 510-CO2-19GYCXEG	NDIR	Aug 09, 2018
Horiba MPA 510-O2-7TWMJ041	Paramagnetic	Aug 09, 2018

Triad Data Available Upon Request



Signature on file
Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E03NI62E15A0224	Reference Number: 82-401044874-1
Cylinder Number: SG9169108	Cylinder Volume: 157.2 CF
Laboratory: 124 - Riverton (SAP) - NJ	Cylinder Pressure: 2015 PSIG
PGVP Number: B52017	Valve Outlet: 590
Gas Code: CO2,O2,BALN	Certification Date: Nov 18, 2017

Expiration Date: Nov 18, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	17.00 %	16.58 %	G1	+/- 0.7% NIST Traceable	11/18/2017
OXYGEN	21.00 %	21.00 %	G1	+/- 0.5% NIST Traceable	11/18/2017
NITROGEN	Balance			-	

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12061336	CC360792	11.002 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2018
NTRM	09061415	CC273526	22.53 % OXYGEN/NITROGEN	+/- 0.4%	Mar 08, 2019

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba VIA 510-CO2-19GYCXEG	NDIR	Oct 30, 2017
Horiba MPA 510-O2-7TWMJ041	Paramagnetic	Oct 27, 2017

Triad Data Available Upon Request



Signature on file
Approved for Release

INTERFERENCE CHECK

Date: 12/4/14-12/5/14
Analyzer Type: Servomex - O₂
Model No: 4900
Serial No: 49000-652921
Calibration Span: 21.09 %
Pollutant: 21.09% O₂ - CC418692

INTERFERENT GAS	ANALYZER RESPONSE		% OF CALIBRATION SPAN ^(a)
	INTERFERENT GAS RESPONSE (%)	INTERFERENT GAS RESPONSE, WITH BACKGROUND POLLUTANT (%)	
CO ₂ (30.17% CC199689)	0.00	-0.01	0.00
NO (445 ppm CC346681)	0.00	0.02	0.11
NO ₂ (23.78 ppm CC500749)	NA	NA	NA
N ₂ O (90.4 ppm CC352661)	0.00	0.05	0.24
CO (461.5 ppm XC006064B)	0.00	0.02	0.00
SO ₂ (451.2 ppm CC409079)	0.00	0.05	0.23
CH ₄ (453.1 ppm SG901795)	NA	NA	NA
H ₂ (552 ppm ALM048043)	0.00	0.09	0.44
HCl (45.1 ppm CC17830)	0.00	0.03	0.14
NH ₃ (9.69 ppm CC58181)	0.00	0.01	0.03
TOTAL INTERFERENCE RESPONSE			1.20
METHOD SPECIFICATION			< 2.5%

^(a) The larger of the absolute values obtained for the interferent tested with and without the pollutant present was used in summing the interferences.


 Chad Walker

INTERFERENCE CHECK

Date: 12/4/14-12/5/14
Analyzer Type: Servomex - CO₂
Model No: 4900
Serial No: 49000-652921
Calibration Span: 16.65%
Pollutant: 16.65% CO₂ - CC418692

INTERFERENT GAS	ANALYZER RESPONSE		% OF CALIBRATION SPAN ^(a)
	INTERFERENT GAS RESPONSE (%)	INTERFERENT GAS RESPONSE, WITH BACKGROUND POLLUTANT (%)	
CO ₂ (30.17% CC199689)	NA	NA	NA
NO (445 ppm CC346681)	0.00	0.02	0.10
NO ₂ (23.78 ppm CC500749)	0.00	0.00	0.02
N ₂ O (90.4 ppm CC352661)	0.00	0.01	0.04
CO (461.5 ppm XC006064B)	0.00	0.01	0.00
SO ₂ (451.2 ppm CC409079)	0.00	0.11	0.64
CH ₄ (453.1 ppm SG901795)	0.00	0.07	0.44
H ₂ (552 ppm ALM048043)	0.00	0.04	0.22
HCl (45.1 ppm CC17830)	0.10	0.06	0.60
NH ₃ (9.69 ppm CC58181)	0.00	0.02	0.14
TOTAL INTERFERENCE RESPONSE			2.19
METHOD SPECIFICATION			< 2.5%

^(a) The larger of the absolute values obtained for the interferent tested with and without the pollutant present was used in summing the interferences.


 Chad Walker

APPENDIX F
LIST OF PROJECT PARTICIPANTS

The following Weston employees participated in this project.

Paul Meeter	Senior Project Manager
Steve Rathfon	Team Member
Kyle Schweitzer	Team Member
Chris Hartsky	Team Member
John Mills	Team Member