



City of High Point Sedimentation Inspection Report

Inspector Jon R. Shepherd ASV Date of Inspection 3/29/22

Permit Number EIV-21-0226 Project Name Triangle Lake Rd Commercial Site

Address 3124 Triangle Lake Rd, High Point NC 27260

Individual responsible for Erosion Control PTI of USA, LLC

Mailing address for individual 7 westmark Court, Greensboro NC 27410

Contact made with Nobody on site Soil/Weather Conditions Dry/Cloudy 40°

Site in COMPLIANCE  with approved plan or in NON-COMPLIANCE  Under NOV?

The following Violations that were discovered on your site are: Failure to protect, Failure to Follow plan, Failure to Install devices

The necessary actions to correct the above violations are: Install rain gauge on site per plans. Place letter of Approval in Jobbox on site and keep it there at all times. Supply NPDES Self Inspection reports on site and filled out correctly. Begin Installing Erosion Control devices at once!, Begin Construction of Skimmer basin before grubbing the Jobsite.

Additional remarks by Inspector: Financial responsible Party has been non responsive via email, phone. Begin Installing erosion Control devices on site. Jobsite has not had any activity on site in several weeks. Contact Erosion Control Inspector and provide a time line as to when work will begin.

Has off-site sedimentation occurred since last inspection? YES  NO

Photographs YES  NO

Describe and estimate amount of off-site sedimentation damage and area that it covers:  
None

























































TOD



