

# Underground Storage Tanks (USTs) Public Record - Summary Information

## General Information

Public Record Posted Date: 12/9/2021

Total Number Of Active UST Facilities: 7,377  
 Total Number Of USTs: 23,853

## Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 3,412  
 Inspection Period Dates: 10/1/2020 To: 10/1/2021  
 Percent Compliance (Combined Measure): 57%

Note: \*Number of whole tanks = 21,618; \*\*Compliance rate reflects implementation of new federal regulations on 10/13/2018;

## Summary Information For Releases

Number Of Confirmed UST Releases: 317  
 Release Reporting Period Dates 10/1/2020 To: 10/1/2021

## Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Corrosion		Phys/Mech Damage		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	151	48%	2	0%	1	0%	26	8%	42	13%	0	0%	16	5%	64	20%
Piping	39	12%	0	0%	0	0%	1	0%	31	10%	0	0%	1	0%	6	2%
Dispenser	42	13%	6	2%	0	0%	1	0%	18	6%	0	0%	2	0%	15	5%
STP**	1	1%	0	0%	0	0%	0	0%	1	0%	0	0%	0	0%	0	0%
Delivery Problem	3	1%	2	0%	0	0%	0	0%	1	0%	0	0%	0	0%	0	0%
Other	53	16%	2	0%	1	0%	0	0%	22	7%	0	0%	19	6%	9	3%
Unknown	28	9%	0	0%	0	0%	0	0%	2	0%	0	0%	2	0%	24	7%
<b>Totals</b>	<b>317</b>	<b>100%</b>	<b>12</b>	<b>4%</b>	<b>2</b>	<b>0%</b>	<b>28</b>	<b>9%</b>	<b>117</b>	<b>37%</b>	<b>0</b>	<b>0%</b>	<b>40</b>	<b>13%</b>	<b>118</b>	<b>37%</b>

Note: Release, source and cause information is based on data from regulated tanks. Source and cause data were collected primarily using forms and reports submitted by Responsible Parties or their agents.

\*Additionally, there were 284 confirmed releases from non-regulated USTs, primarily heating oil tanks. There are also 351 confirmed releases from non-usts during the reporting period.

\*\*STP - Submersible Turbine Pump

To obtain site-specific information on UST releases contact the Regional DENR Office for the county in which the release occurred. To obtain UST compliance information contact the UST Section Central Office.