



NORTH CAROLINA  
Environmental Quality

ROY COOPER  
Governor

MICHAEL S. REGAN  
Secretary

MICHAEL SCOTT  
Director

May 22, 2020

To: Mr. Alex Conklin  
Fairfield Industries, Inc.  
4483 Choppee Road  
Georgetown, SC 29440

Subject: Fairfield Industries, Inc. Double-Walled Spill Bucket  
Model: SCM-5D-NCGG

Mr. Conklin,

The North Carolina Department of Environmental Quality (NCDEQ) – Underground Storage Tank (UST) Section has reviewed your request to evaluate the Fairfield Industries SCM-5D-NCGG double-walled spill bucket as to whether it meets the performance standards set out in Title 15A North Carolina Administrative Code, Subchapter 02N “Criteria and Standards Applicable to Underground Storage Tanks”, Section .0900 (15A NCAC 02N .0900). Based on the information you have provided, the Fairfield Industries SCM-5D-NCGG is a five-gallon double-walled spill bucket constructed of stainless steel and installed within a HDPE gravel guard/pan. The design also includes a pre-installed third-party certified liquid-detecting sensor (i.e., Gems Sensor LS-3) to monitor the interstice of the double-walled spill bucket. Based on the information you have provided, NCDEQ – UST Section has concluded that the Fairfield Industries SCM-5D-NCGG would meet the requirements of 15A NCAC 2N .0900, provided it is always installed within the non-metallic gravel guard / pan, so as to isolate the stainless steel bucket from the backfill, uses a third-party certified method of continuous interstitial monitoring, such as the listed liquid-detecting Gems Sensor LS-3, and is installed in accordance with the manufacturer’s written guidelines. Please note, that using an electronic liquid-detecting sensor, as opposed to a continuous interstitial monitoring method that uses vacuum, pressure or hydrostatic method will require integrity testing of the interstice at installation and every three years thereafter (e.g., a vacuum test, hydrostatic test, etc. as defined by the manufacturer) and should be designed with that in mind. Furthermore, please note that electronic sensors used for leak detection are also required to be tested for operability on an annual basis and should also be considered in the design.

Should you have any questions, please do not hesitate to contact me at [matt.wegner@ncdenr.gov](mailto:matt.wegner@ncdenr.gov).

Sincerely,

A handwritten signature in blue ink that reads "Matt A. Wegner".

Matt A. Wegner  
Engineering Associate  
North Carolina Department of Environmental Quality  
Division of Waste Management  
Underground Storage Tank Section  
(919) 707-8163  
Email: [Matt.Wegner@ncdenr.gov](mailto:Matt.Wegner@ncdenr.gov)

