



NORTH CAROLINA
Environmental Quality

ROY COOPER

Governor

MICHAEL S. REGAN

Secretary

MICHAEL SCOTT

Director

June 15, 2020

Melissa Terry
ESCO Manufacturing Inc.
13901 Lynmar Blvd
Tampa, FL 33626-3124

Re: Remanufactured Automatic Tank Gauge probes
Veeder-Root probe models: 846390-XXX and 847390-XXX

Dear Ms. Terry:

The Underground Storage Tank (UST) Section has reviewed your request for approval of the remanufactured ATG probe models listed above. In your request you state that all components used in the remanufacturing process are either OEM or meet the original specifications of the OEM components. As long as the components used in the remanufacturing process are either OEM or meet the original specifications of the OEM components; the probes are not altered from their original design that would cause them to no longer meet the original third party certification; and they are tested to function as originally designed, then the remanufactured Veeder-Root probe models listed above are approved for use in North Carolina and can be used to meet the leak detection requirements listed in federal regulation 40 CFR 280.45(a) (as incorporated by 15A NCAC 2N .0506) and as described in 40 CFR 280.40(a)(3) (as incorporated by 15A NCAC 2N .0501).

If you have any questions, please contact me at the letterhead address, (336) 776-9684 or michael.phelps@ncdenr.gov.

Sincerely,

A handwritten signature in black ink that reads "Michael Phelps".

Michael Phelps, Environmental Supervisor
Division of Waste Management, NC DEQ

cc: Files



North Carolina Department of Environmental Quality | Division of Waste Management
450 W Hanes Mill Rd, Suite 300 | Winston Salem, North Carolina 27105
336.776.9800