

Categorical Exclusion

North Carolina Division of Water Infrastructure

Project Applicant: *The Honorable Esterine Gary Pitt*
Date: *May 2, 2023*
Project Name: *Sewer Collection System Rehabilitation*
Project Number: *CS370579-02 & SRP-W-ARP-0020*
Estimated Project Cost: *\$1,760,000*
Estimated Funding Amount: *\$500,000*

Eligible

Collection System

Replacement of approximately 12,430 LF of 8-inch diameter pipe, 49 manholes, and 192 services; rehabilitation of nine (9) manholes; and removal and replacement of pavement, roadways, driveways and curbs, and sedimentation and erosion control devices.

Walnut Cove Pump Station

Rehabilitation to include rehabilitation of wet well; replacement of two (2) 100 GPM submersible pumps with two (2) 100 GPM submersible pumps, and generator; installation of ATS; and electrical, valves, vaults, and associated appurtenances.

Main Street Pump Station

Rehabilitation to include rehabilitation of wet well; replacement of two (2) 100 GPM submersible pumps with two (2) 100 GPM submersible pumps, and generator; installation of ATS; and electrical, valves, vaults, and associated appurtenances.

Taylor Estate Pump Station

Rehabilitation to include rehabilitation of wet well; replacement of two (2) 80 GPM submersible pumps with two (2) 80 GPM submersible pumps, and generator; installation of ATS; and electrical, valves, vaults, and associated appurtenances.

Non-Eligible Paving of roadways in excess of the excavated area. Spare parts, service contracts, maintenance contracts, and extended warranties.

A map of the project is attached.

The above-named applicant will receive funding assistance from the State Revolving Fund. The North Carolina Division of Water Infrastructure (Division) has conducted a review of the project in accordance with the NCGS §159G-38. The Division has determined that this project is below the minor construction activities threshold outlined in the 15A NCAC 01C .0408; therefore, the project is exempt from inter-agency review, and the preparation of additional environmental documents is not required.

This determination shall become effective upon its distribution by the Division and will be available on the Division's website (<https://deq.nc.gov/about/divisions/water-infrastructure/division-water-infrastructure/environmental-documents>). This determination can be revoked at any time adverse information is made available. The documentation to support this decision will be on file with the North Carolina Department of Environmental Quality, Division of Water Infrastructure, and is available for public scrutiny upon request.

Comments concerning this decision may be addressed to Mr. Jon Risgaard, Section Chief, State Revolving Fund Section, Division of Water Infrastructure, 1633 Mail Service Center, Raleigh, North Carolina 27699, or he can be reached by phone at (919) 707-9175.

Sincerely,

Antonio V. Evans, PE, Supervisor
Wastewater & Stormwater Projects Unit
Division of Water Infrastructure




Figure 3 – Whitakers Sanitary Sewer Collection System Sizes and Location