

Categorical Exclusion (Revised)

North Carolina Division of Water Infrastructure

Project Applicant: *City of Thomasville*
Date: *November 13, 2020*
Project Number: *WIF1961 (Previously WIFs 1961, 1970, 1971 and 1972)*
Estimated Project Cost: *\$2,832,434*
Estimated Funding Amount: *\$2,832,434*

Section A: (Previously approved as WIF1961- Lambeth Knolls Waterline Replacement)

Replacement of $\pm 3,789$ LF of 2-inch diameter galvanized waterlines by new 6-inch diameter ductile iron pipe along Dogwood Road, English Street, Knollwood Drive, Oaklawn Drive, Rapp Street and Runneymeade Street on the south side of the City

Section B: (Previously approved as WIF1970 – Litwin & Fleet Darr Roads Waterline Replacement)

Replacement of $\pm 1,811$ LF of 2-inch diameter galvanized waterlines by new 6-inch diameter ductile iron pipe along Litwin Drive, and replacement of approximately 890 LF of 2-inch diameter galvanized waterlines by new 2-inch diameter ductile iron pipe along Fleet Darr Road within the northwest area of the City.

Section C: (Previously approved as WIF1971 – Liberty and Virginia Waterline Replacement)

Replacement of $\pm 1,286$ LF of 2-inch diameter galvanized waterlines along Liberty Drive, and ± 986 LF of 2-inch diameter galvanized waterlines along Virginia Drive by new 6-inch diameter ductile iron pipe on the south side of the City.

Section D: (Previously approved as WIF1972- Urgent Need Waterline Replacement)

Replacement of $\pm 11,130$ LF of 2-inch galvanized waterlines by new 6-inch diameter ductile iron pipe along Circle Place, Griffith Street, Middle Avenue, Nance Drive, Shuler Road, White Street and Wilson Street; and transferring of ± 10 services to existing 6-inch diameter galvanized waterline along Rockspring Drive.

The above named applicant will receive funding assistance from the State Revolving Fund. The North Carolina Division of Water Infrastructure (Division) has conducted a review of the project in accordance with the NCGS §159G-38. The Division has determined that this project is below the minor construction activities threshold outlined in 15A NCAC 01C .0408; therefore, the project is exempt from inter-agency review, and the preparation of additional environmental documents is not required.

This determination shall become effective upon its distribution by the Division and will be available on the Division's website (<https://deq.nc.gov/about/divisions/water-infrastructure/division-water-infrastructure/environmental-documents>). This determination can be revoked at any time adverse information is made available. The documentation to support this decision will be on file with the

North Carolina Department of Environmental Quality, Division of Water Infrastructure, and is available for public scrutiny upon request.

Comments concerning this decision may be addressed to Ms. Jennifer Haynie, Environment and Special Projects Unit, Division of Water Infrastructure, 1633 Mail Service Center, Raleigh, North Carolina 27699, or she can be reached by phone at (919) 707-9173.

Sincerely,

Vincent Jude Tomaino

Vincent Jude Tomaino, PE, Supervisor
Drinking Water Projects Unit
Division of Water Infrastructure