



PAT MCCRORY
Governor

DONALD R. VAN DER VAART
Secretary

S. JAY ZIMMERMAN
Director

Requirements for Reporting of Bacteriological Compliance Sample Results to the Public Water Supply Section

1. “Present” *E. coli* Results:

Submit electronically as soon as possible but no later than by the end of the day the analysis is completed

2. “Present” Total Coliform Results for routine distribution system and/or ground water source water compliance samples:

Submit electronically as soon as possible but no later than 48 hours after completion of the analysis

3. “Absent” REPEAT and TRIGGERED Compliance Sample Results:

Submit electronically as soon as possible but no later than 48 hours after completion of the analysis

4. “Absent” Total Coliform ROUTINE and HPC Results:

Submit electronically as soon as possible but no later than by the 10th day of the following month in which the sample was collected