

Civil Penalties Assessed During the Month of January 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Alan Borders 217 Highway 70 SW Hickory, NC Catawba Co.	Holiday Full Service & Towing 217 Highway 70 SW Hickory, NC Catawba Co.	Violation of 15A NCAC 2N .0302 by failing to provide corrosion protection for one UST system, violation of 15A NCAC 2N .0502 by failing to provide leak detection for one UST system, violation of 15A NCAC 2N .0801 by failing to permanently close three substandard UST systems, and violation of NCGS 143-215.94U by failing to hold a currently valid operating permit.	\$10,283.17	1/16/04
Saleh A. Odeh 1521 Raleigh St. Rocky Mount, NC Edgecombe Co.	Friendly Way 1616 Raleigh St. Rocky Mount, NC Edgecombe Co.	Violation of 15A NCAC 2N .0402 by failing to operate and maintain corrosion protection for three UST systems, violation of 15A NCAC 2N .0502 by failing to meet the requirements for leak detection for two USTs and two suction piping systems, violation of 15A NCAC 2N .0601 by failing to report suspected releases, and violation of 15A NCAC 2N .0603 by failing to investigate suspected releases.	\$17,445.26	1/20/04
Pacemaker Leasing Co. 543 Cox Rd. Gastonia, NC Gaston Co.	Handy Pantry #10 3601 Chapel Grove School Rd. Gastonia, NC Gaston Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a comprehensive site assessment report.	\$18,193.46	1/14/04
Rex Chapman 4395 Bill Dale Rd. Morganton, NC Burke Co.	Fisher's Market 4570 Dentons Chapel Church Rd. Morganton, NC Burke Co.	Violation of 15A NCAC 2N .0801 by failing to permanently close two substandard UST systems and violation of 15A NCAC 2N .0803 by failing to assess the site a the permanent closure of one UST system and to submit a closure report.	\$4,882.02	1/16/04
Max Palmer 234 Blazing Tr. Waynesville, NC Haywood Co.	Dallas Food Mart (former) 3499 Smoky Park Highway Candler, NC Buncombe Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a comprehensive site assessment report.	\$11,041.96	1/12/04
Furnitureland South, Inc. P.O. Box 1550 Jamestown, NC Guilford Co.	Furnitureland South 5635 Riverdale Rd. Jamestown, NC Guilford Co.	Violation of 15A NCAC 2N .0303 by failing to register one UST system.	\$4,652.12	1/16/04
Arnold Jones Oil & Heating Co., Inc. 3516 E. Kivett Dr. High Point, NC Guilford Co.	Furnitureland South 5635 Riverdale Rd. Jamestown, NC Guilford Co.	Violation of NCGS 143-215.94U by placing petroleum product into an unpermitted UST.	\$1,452.12	1/22/04
Clay Oliver 3842 Old US Highway 421 Hamptonville, NC Yadkin Co.	Arlington Branco Oil Co. 270 N. Main St. Jonesville, NC Yadkin Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a limited site assessment report.	\$5,901.01	1/20/04
Farrell Teague 4406 US Hwy 220 Bus S Asheboro, NC Randolph Co.	Teague's Exxon 4106 US Hwy 220 Bus. S Asheboro, NC Randolph Co.	Violation of 15A NCAC 2N .0302 by failing to provide verification of overfill protection for one UST and failing to inspect the internal lining of two USTs within 10 years of initial lining, violation of 15A NCAC 2N .0502 by failing to meet the requirements for leak detection for three USTs and three suction piping systems, violation of 15A NCAC 2N .0601 by failing to report a suspected release, violation of 15A NCAC 2N .0603 by failing to investigate a suspected release, and violation of NCGS 143-215.94U by failing to hold a currently valid operating permit.	\$17,997.29	1/20/04
Snak Mart, Inc. 7820 Sanderling Dr. Wilmington, NC New Hanover Co.	Snak Mart 6865 Market St. Wilmington, NC New Hanover Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a comprehensive site assessment report.	\$8,043.96	1/14/04

Civil Penalties Assessed During the Month of February 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Ralph & Katherine Kitrell, Sr. 2313 Crab Point Loop Rd. Morehead City, NC Carteret Co.	Kitrell Property 2102 Country Club Rd. Morehead City, NC Carteret Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report.	\$5,779.56	2/12/04
Pernjit Sahdra 2100 Lawndale Dr. Greensboro, NC Guilford Co.	G&S Food Mart 2100 Lawndale Dr. Greensboro, NC Guilford Co.	Violation of 15A NCAC 2N .0402 by failing to inspect an impressed current cathodic protection system every sixty days and violation of 15A NCAC 2N .0502 by failing to meet the requirements for leak detection for three USTs.	\$4,755.78	2/2/04
Kenneth & Judy Barlow 870 Barlow Hill Rd. N. Wilkesboro, NC Wilkes Co.	Market Basket #13 6370 W. NC Highway 268 Wilkesboro, NC Wilkes Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report.	\$9,409.18	2/10/04
Spur Service Center, Inc. 712 N. George St. Goldsboro, NC Wayne Co.	Spur Service Center #5 2202 Wayne Memorial Dr. Goldsboro, NC Wayne Co.	Violation of 15A NCAC 2N .0601 by failing to report a suspected release within twenty-four hours, violation of 15A NCAC 2N .0603 by failing to investigate a suspected release and failure to investigate a suspected release based on environmental contamination.	\$6,898.23	2/16/04
Fletcher Oil Company, Inc. 508 Crow St. Monroe, NC Union Co.	Deese Corner Store 4702 Concord Highway Monroe, NC Union Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report and violation of 15A NCAC 2H .0217 by failing to properly dispose of contaminated soil stored on-site for greater than forty-five days.	\$18,022.15	2/10/04
Brenda Severt & David & Nancie Wilson 8904 Brief Rd. Charlotte, NC Mecklenburg Co.	Wilson/Severt Property 9000 Brief Rd. Charlotte, NC Mecklenburg Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report.	\$5,745.92	2/10/04
Bumgarner Oil Company, Inc. 2004 Highland Ave. NE Hickory, NC Catawba Co.	Cubbard Express #4 1969 West Side Blvd. Newton, NC Catawba Co.	Violation of NCGS 143-215.94U at least forty-four times by placing product into USTs at a facility for which it did not hold a currently valid operating permit.	\$6,677.83	2/24/04
Sharpe Oil Company P.O. Box 219 Elm City, NC Wilson Co.	John's Convenience Mart Highway 264A Greenville, NC Pitt Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a limited site assessment report.	\$7,789.54	2/27/04

Civil Penalties Assessed During the Month of March 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Spur Service Center, Inc. 712 N. George St. Goldsboro, NC Wayne Co.	Spur Service Center #1 301 W. Grantham St. Goldsboro, NC Wayne Co.	Violation of 15A NCAC 2N .0504 by failing to conduct one valid 0.2 gallon per hour leak rate test at least every 30 days for 4 automatic tank gauges, violation of 15A NCAC 2N .0601 by failing to report a suspected release within 24 hours, violation of 15A NCAC 2N .0603 by failing to investigate a suspected release.	\$5,078.62	3/22/04
LEECO Oil Co., Inc. 2625 Statesville Blvd. Salisbury, NC Rowan Co.	Quality Food Mart 2625 Statesville Blvd. Salisbury, NC Rowan Co.	Violation of 15A NCAC 2N .0802 by failing to notify DWM prior to permanently closing UST systems, and violation of 15A NCAC 2N .0803 by failing to assess a site at the permanent closure of UST systems and submit a closure report.	\$7,530.31	3/9/04
Brownstone Properties VIII, LLC 442 1/2 E. Main St. Clayton, NC Johnston Co.	Benton Nance Grocery 2601 Marshville-Olive Branch Rd. Marshville, NC Union Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit groundwater monitoring reports and failure to submit a Corrective Action Plan, and violation of 15A NCAC 2L .0115(c)(1) by failing to submit free product recovery reports.	\$12,817.73	3/23/04
Margie Crawford 11185 NC Highway 42 E. Middlesex, NC Johnston Co.	Peggy's Quick Mart 5403 Flower Hill Rd. Kenly, NC Johnston Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a Comprehensive Site Assessment report.	\$8,145.88	3/22/04
Clyde McGrady 11834 Long Bottom Rd. Traphill, NC Wilkes Co.	McGrady's Grocery 11834 Long Bottom Rd. Traphill, NC Wilkes Co.	Violation of 15A NCAC 2N .0803 by failing to assess a site at the permanent closure of UST systems and submit a closure report.	\$5,282.54	3/29/04

Civil Penalties Assessed During the Month of April 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Bipin B. Patel 2525 W. Lawyers Rd. Indian Trail, NC Union Co.	Fast Food Mart 2525 Lawyers Rd. Indian Trail, NC Union Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a Comprehensive Site Assessment report.	\$8,013.31	4/13/04
Times Oil Corporation P.O. Box 795 Lincolnton, NC Lincoln Co.	Alexis Grocery 4231 Charles Raper Jonas Hwy Alexis, NC Gaston Co.	Violation of 15A NCAC 2L.0115(f) by failing to submit a Corrective Action Plan.	\$11,447.88	4/6/04

Civil Penalties Assessed During the Month of May 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Petroleum Transport Company, Inc. P.O. Box 1283 Mt. Airy, NC Surry Co.	One Stop #5 Highway 64 & Ecusta Rd. Brevard, NC Transylvania Co.	Violation of NCGS 143-215.94U at least six times by placing petroleum product into USTs at a facility for which the owner or operator did not hold a currently valid operating permit.	\$1,813.76	5/3/04
Robert Ray Mathis 4535 S. Main St. Winston Salem, NC Forsyth Co.	Ray's Motor & Body Shop 4345 S. Main St. Winston Salem, NC Forsyth Co.	Violation of 15A NCAC 2N .0801 by failing to permanently close three substandard UST systems.	\$4,683.74	5/7/04
Quik Chek, Inc. 220 W. Spring St. Troy, NC Montgomery Co.	Quik Chek #26 204 Broad St. Seagrove, NC Randolph Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a Corrective Action Plan.	\$20,089.22	5/27/04
Quik Chek, Inc. 220 W. Spring St. Troy, NC Montgomery Co.	Quik Chek #8 1123 Albemarle Rd. Asheboro, NC Randolph Co.	Violation of 15A NCAC 2L .0115(f) by failing to implement a Corrective Action Plan as approved and modified by DWM.	\$16,475.92	5/27/04

Civil Penalties Assessed During the Month of June 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Gaston Merchants Oil Company 1513 N. Chester St. Gastonia, NC Gaston Co.	Omni-Mart #30 245 Market St. Cramerton, NC Gaston Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a complete Corrective Action Plan.	\$16,462.20	6/14/04
Sam Gallani P.O. Box 69 Pisgah Forest, NC Transylvania Co.	One Stop #5 Highway 64 & Ecusta Rd. Brevard, NC Transylvania Co.	Violation of NCGS 143-215.94U by failing to hold a currently valid operating permit at a facility where petroleum products were caused to be placed.	\$1,853.76	6/8/04
Gouge Transportation & Equipment P.O. Box 405 Spruce Pine, NC Mitchell Co.	Appalachian Exxon 400 Blowing Rock Rd. Boone, NC Watauga Co.	Violation of 15A NCAC 2N .0302 by failing to provide verification of overfill control for three USTs, violation of 15A NCAC 2N .0502 by failing to conduct manual tank gauging correctly for one UST system, violation of 15A NCAC 2N .0601 by failing to report suspected releases, and violation of 15A NCAC 2N .0603 by failing to investigate suspected releases.	\$9,582.02	6/1/04
Ray Thomas Petroleum Co., Inc. 1629 S. Lafayette St. Shelby, NC Cleveland Co.	Toney's Grocery 5041 Bostic-Sunshine Highway Bostic, NC Rutherford Co.	Violation of 15A NCAC 2N .0302 by failing to assess the integrity of three USTs prior to the addition of a field-installed corrosion protection system, violation of 15A NCAC 2N .0304 by failing to provide enhanced leak detection or secondary containment for three UST systems located between 100 and 500 feet of a public water supply well, violation of 15A NCAC 2N .0402 by failing to inspect an impressed current cathodic protection system every 60 days, violation of 15A NCAC 2N .0601 by failing to report a suspected release, and violation of 15A NCAC 2N .0603 by failing to investigate a suspected release.	\$16,232.02	6/15/04
A.J. Lancaster, Jr. 9453 Lancaster Store Rd. Castalia, NC Nash Co.	A.J. Lancaster Store SR 1321 & SR 1324 Castalia, NC Nash Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a Comprehensive Site Assessment report.	\$15,562.38	6/17/04
P. Dean Jacobs 5427 US Highway 158 Advance, NC Davie Co.	Dean's Mini Mart #2 5427 US Highway 158 Advance, NC Davie Co.	Violation of 15A NCAC 2N .0301 by failing to maintain spill prevention for three UST systems and by failing to provide verification of overfill control for three UST systems, violation of 15A NCAC 2N .0502 by failing to meet the requirements of leak detection for three USTs and three pressurized piping systems, violation of 15A NCAC 2N .0505 by failing to conduct an annual test of the operation of automatic line leak detectors associated with three pressurized piping systems, and violation of 15A NCAC 2N .0506 by failing to provide third party performance claims for leak detection methods.	\$11,680.00	6/1/04
Maple Leaf Sports, Inc. 36 N. Main St. Marion, NC McDowell Co.	Kehler's #6 221 Bypass & Highway 70 Marion, NC McDowell Co.	Violation of 15A NCAC 2N .0502 by failing to comply with leak detection requirements for five UST systems, violation of 15A NCAC 2N .0601 by failing to report a suspected release, and violation of 15A NCAC 2N .0603 by failing to investigate a suspected release.	\$5,386.44	6/16/04

Civil Penalties Assessed During the Month of August 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Stallings Brothers, Inc. P.O. Box 40 Middlesex, NC Nash Co.	Kountry Kwik Pik 10762 Liles Rd. Bailey, NC Nash Co.	Violation of 15A NCAC 2N .0301 by failing to demonstrate compliance with corrosion protection requirements for 6 UST systems and by failing to demonstrate compliance with overfill control requirements for 3 USTs, violation of 15A NCAC 2N .0304 by failing to provide secondary containment or enhanced leak detection for 6 UST systems located between 100 and 500 feet of a well serving a public water system, violation of 15A NCAC 2N .0502 by failing to meet leak detection requirements for 2 suction piping systems, and violation of 15A NCAC 2N .0506 by failing to maintain records demonstrating compliance with leak detection requirements for 4 pressurized piping systems.	\$11,845.16	8/30/04
Stallings Brothers, Inc. P.O. Box 40 Middlesex, NC Nash Co.	Stallings Bros Coastal 11471 W. Finch Ave. Middlesex, NC Nash Co.	Violation of 15A NCAC 2N .0301 and .0302 by failing to demonstrate compliance with corrosion protection requirements for 7 UST systems, violation of 15A NCAC 2N .0502 by failing to meet leak detection requirements for 2 suction piping systems, violation of 15A NCAC 2N .0504 by failing to provide one valid 0.2 gallon per hour leak rate test using an automatic tank gauge at least every 30 days for one UST, and violation of 15A NCAC 2N .0506 by failing to maintain records demonstrating compliance with leak detection requirements for 5 pressurized piping systems.	\$8,045.16	8/30/04
Quality Oil Company, LLC 1540 Silas Creek Pkwy. Winston Salem, NC Forsyth Co.	Bixby Convenience Store 2216 Comatzer Rd. Advance, NC Davie Co.	Violation of 15A NCAC 2N .0301 by failing to provide a method of overfill control for 2 USTs.	\$2,952.70	8/12/04

Civil Penalties Assessed During the Month of September 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Stallings Brothers, Inc. P.O. Box 40 Middlesex, NC Nash Co.	Skips Groc Mart 106 E. Nash St. Spring Hope, NC Nash Co.	Violation of 15A NCAC 2N .0302 by failing to have a corrosion expert design a field-installed corrosion protection system and by failing to ensure the integrity of five UST systems prior to installing corrosion protection, violation of 15A NCAC 2N .0402 by failing to operate and maintain a corrosion protection system to continuously provide corrosion protection and by failing to have a qualified cathodic protection tester evaluate a cathodic protection system at least every three years, and violation of 15A NCAC 2N .0502 by failing to conduct a valid method of leak detection for two USTs and by failing to meet the leak detection requirements for five suction piping systems.	\$20,645.16	9/7/04
Neal Woody 3183 New Leicester Hwy. Leicester, NC Buncombe Co.	Leicester BP 3187 New Leicester Hwy. Leicester, NC Buncombe Co.	Violation of 15A NCAC 2N .0502 by failing to provide leak detection for five USTs.	\$3,033.76	9/7/04

Civil Penalties Assessed During the Month of October 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Sutton's Service Center, Inc. 1205 Dickinson Ave. Greenville, NC Pitt Co.	Gulf Station (former) 203 Lee St. Ayden, NC Pitt Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report.	\$10,764.06	10/4/04
Samuel A. Wilson 2175-A Turner Rd. Mebane, NC Alamance Co.	Samuel Wilson Property 4224 Old Hillsborough Rd. Mebane, NC Alamance Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report.	\$9,955.30	10/4/04
Robin R. Moore 6623 River Rd. Washington, NC Beaufort Co.	Pit N Pump 844 W. 15th St. Washington, NC Beaufort Co.	Violation of 15A NCAC 2N .0502 by failing to meet leak detection requirements for seven USTs.	\$7,017.63	10/11/04
Wayne Langston 415 Alseron Rd. Washington, NC Beaufort Co.	Pit N Pump 844 W. 15th St. Washington, NC Beaufort Co.	Violation of 15A NCAC 2N .0502 by failing to meet leak detection requirements for seven USTs.	\$4,522.05	10/11/04
Ronald Sadler P.O. Box 489 Alexis, NC Gaston Co.	Country Corner 4262 Charles Raper Jonas Hwy. Alexis, NC Gaston Co.	Violation of 15A NCAC 2L .0115(f) by failing to submit a complete Comprehensive Site Assessment report.	\$10,800.66	10/8/04

Civil Penalties Assessed During the Month of November 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Kash & Karry, Inc. 5430 Front Ln. Ayden, NC Pitt Co.	Jolly Rogers 405 E. 15th St. Greenville, NC Pitt Co.	Violation of 15A NCAC 2N .0402 by failing to inspect an impressed current cathodic protection system every sixty days, violation of 15A NCAC 2N .0502 by failing to conduct a valid method of leak detection for five USTs, and violation of 15A NCAC 2N .0801 by failing to secure and maintain two UST systems in temporary closure.	\$8,678.08	11/19/04
Page Distributing Company, Inc. P.O. Box 15047 Winston Salem, NC Forsyth Co.	Wades Pace Station 1220 N. Horner Blvd. Sanford, NC Lee Co.	Violation of 15A NCAC 2N .0603 by failing to investigate a suspected release.	\$1,512.64	11/8/04
Eanes Oil Company 435 Old Durham Rd. Roxboro, NC Person Co.	The Country Store 4807 Highway 57 N. Semora, NC Caswell Co.	Violation of 15A NCAC 2N .0603 by failing to investigate a suspected release.	\$6,918.66	11/23/04
Roger W. Bone 210 N. Person St. Raleigh, NC Wake Co.	La Pasada 5862 Highway 58 S. Nashville, NC Nash Co.	Violation of 15A NCAC 2N .0301 by failing to meet corrosion protection requirements for metal flexible connectors associated with a UST piping system, violation of 15A NCAC 2N .0304 by failing to provide secondary containment for a UST system located between 100 and 500 feet of three wells serving a public water system, violation of 15A NCAC 2N .0603 by failing to investigate a suspected release, and violation of 15A NCAC 2N .0801 by failing to secure and maintain a UST system in temporary closure.	\$9,191.58	11/9/04
Janet Harvey 1204 S. Main St. Mt. Holly, NC Gaston Co.	Bubba's Convenience Store 1204 S. Main St. Mt. Holly, NC Gaston Co.	Violation of 15A NCAC 2L .0115(c)(4) by failing to submit a Limited Site Assessment report.	\$6,674.37	11/23/04

Civil Penalties Assessed During the Month of December 2004

Responsible Party	Facility Name	Violation(s)	Penalty Amount	Date Assessed
Ronald G. Overcash 1150 Shelton Rd. Concord, NC Cabarrus Co.	Overcash Gravel & Grading, Inc. 1150 Shelton Rd. Concord, NC Cabarrus Co.	Violation of 15A NCAC 2N .0301 by failing to demonstrate compliance with corrosion protection requirements for one UST system, by failing to maintain spill prevention equipment for two UST systems, and by failing to verify overfill control for one UST system, violation of 15A NCAC 2N .0502 and .0506 by failing to meet leak detection requirements, violation of 15A NCAC 2N .0506 by failing to provide performance claims for leak detection equipment, violation of 15A NCAC 2N .0603 by failing to investigate a suspected release from two UST systems, and violation of 15A NCAC 2N .0803 by failing to assess the site at the permanent closure of one UST system and submit a closure report.	\$26,552.88	12/6/04
George W. White 919 Will Jefferson Rd. Henderson, NC Vance Co.	Carolina Country Mart 10795 Highway 86 N. Providence, NC Caswell Co.	Violation of 15A NCAC 2N .0302 by failing to provide secondary containment for four single-walled UST systems located within 100 feet of a well serving a public water system, and violation of 15A NCAC 2N .0801 by failing to maintain and secure four UST systems in temporary closure.	\$9,232.75	12/27/04
Laney Oil Company, Inc. P.O. Box 68 Monroe, NC Union Co.	etail Outlet #4 202 E. Union St. Marshville, NC Union Co.	Violation of 15A NCAC 2N .0302 by failing to conduct an internal inspection of the lining of three USTs within ten years of liner installation.	\$5,319.00	12/7/04
Laney Oil Company, Inc. P.O. Box 68 Monroe, NC Union Co.	Retail Outlet #11 NC 27 & Potters Rd. Mineral Springs, NC Union Co.	Violation of 15A NCAC 2N .0801 by failing to maintain and secure six UST systems in temporary closure.	\$5,319.46	12/23/04
Debbie Gail Grant 187 Maola Ln. Rockingham, NC Richmond Co.	D&D Convenience 432 US 1 S. Rockingham, NC Richmond Co.	Violation of 15A NCAC 2N .0301 by failing to meet corrosion protection and overfill control requirements for two UST systems, violation of 15A NCAC 2N .0303 by failing to register two UST systems, and violation of 15A NCAC 2N .0502 by failing to conduct a valid method of leak detection for two USTs.	\$6,819.22	12/29/04
Ben Mynatt Chevrolet, Inc. P.O. Box 1110 Concord, NC Cabarrus Co.	Ben Mynatt Chevrolet, Inc. 281 Concord Parkway S. Concord, NC Cabarrus Co.	Violation of 15A NCAC 2N .0502 by failing to have a cathodic protection system evaluated by a qualified corrosion tester within six months of installation and every three years thereafter and violation of 15A NCAC 2N .0502 and .0506 by failing to meet leak detection requirements for three USTs.	\$8,418.78	12/27/04