

From: Michael Phelps [mailto:michael.phelps@ncmail.net]
Sent: Thursday, January 15, 2009 8:06 PM
To: lcutugno@optonline.net
Cc: Ruth Strauss
Subject: [Re: Liner for Spill containers]

Len,

We discussed your companies product for repairing broken spill buckets and have determined that it is acceptable for use in NC to repair a spill bucket. As part of the repair we would require an integrity test (e.g. hydrostatic or vacuum) of the spill bucket to show that it has been repaired and has integrity. I would be interested in witnessing a repair and/or training session for your spill bucket repair kits. Could you let me know when you might have a contractor who is installing the kit or getting trained on the procedures.

Thanks

Michael Phelps
NC DENR Winston-Salem Regional Office
Division of Waste Management, UST Section
585 Waughtown Street
Winston-Salem, NC 27107
Voice: (336) 771-5344
FAX: (336) 771-4632
<http://www.wastenotnc.org>