

Minimum Test Times for Additional Modern Welding Tanks

Glasteel II Model GS-13, GS-16 & Glasteel Model GS-19

(Not specifically listed in Table 3, but calculated in accordance with the 01/2012 Modern Welding third-party certified tank testing protocol)

Tank Capacity (gal.)	Tank Diameter (in.)	Modern Test Time (hrs.)
7,500 (Calculation Sheet)	72	13.2
4,000 (Calculation Sheet)	96	11
18,000 (Calculation Sheet)	120	17.75
22,000 (Calculation Sheet)	120	18.5
24,000 (Calculation Sheet)	120	19.5
25,000 (Calculation Sheet)	120	20
30,000 (Calculation Sheet)	120	26
19,400 (Calculation Sheet)	126	19
26,000 (Calculation Sheet)	126	21.5

Revised 10/30/2024