



North Carolina Department of Environment and Natural Resources

Pat McCrory  
Governor

Donald R. van der Vaart  
Secretary

August 11, 2015

Peter Kellogg  
PMP Corporation  
PO Box 422  
25 Security Drive  
Avon, CT 06001

Re: Remanufactured Tank and Sump Sensor third party certifications

Dear Mr Kellogg:

The Underground Storage Tank (UST) Section is in receipt of the leak detection evaluations conducted by Ken Wilcox Associates, Inc. on March 13, 2015 for the leak detection sensors your company remanufacturers with the following model numbers:

PMP Corp P/N	OEM P/N
62208	794380-208
62209	794380-209
62401	794390-401
62404	794390-404

PMP Corp P/N	OEM P/N
62407	794390-407
62409	794390-409
62420	794390-420
62460	794390-460

After review of the leak detection evaluations, the UST Section has determined that the above equipment meets the leak detection requirements listed in federal regulation 40 CFR 280.45(a) (as incorporated by 15A NCAC 2N .0506) and as described in 40 CFR 280.40(a)(3) (as incorporated by 15A NCAC 2N .0501) as long as the components used in the remanufacturing process have not changed from the components used in the original leak detection evaluations your company had completed on March 13, 2015 and the sensors are used with non-remanufactured Automatic Tank Gauge consoles listed in the original March 13, 2015 evaluation.

If you have any questions regarding this, please contact me at the address below, (336) 776-9684 or michael.phelps@ncdenr.gov.

Sincerely,

Michael Phelps, Environmental Supervisor  
Division of Waste Management, NC DENR