

Agenda Item I-5. Drinking Water Applications: Project Descriptions

Blue rows = proposed full or partial funding in the scenario [preliminary]

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
1	No	No	194060	Neuse Regional Water and Sewer Authority	Lenoir	Not Distressed	41,087	NC6054001			PFAS Treatment	PFAS treatment to address current levels of PFOS and PFOA above the proposed limits	No		NRWASA	\$32,160,000	\$32,160,000	83	63	2.B.1. (-20 points) Project earned 1.J.1 points (20 points) 2.D. (-10 points) Project earned 1.J.1 points 4.B. (2 pts) Rate sheet for Water and Sewer rates increase combined rate to 10 points
2	Yes	No	194251	Beech Mountain, Town of	Avery,Watauga	Not Distressed	2,114	NC0195104			2023 Water System Rehabilitation Project	Replace 38,050 LF water lines, and extend 2,450 LF to close loops.	No		west Consultants, PLLC	\$10,000,000	\$10,000,000	62	62	
3	Yes	Yes	162645	Weldon, Town of	Halifax	Not Distressed	524	NC0442020			WaterPlant Replace,Emerg. Contam. Remove	Move WTP above 500-year floodplain and Replace facility at the current 2.0 MGD capacity. Add RO treatment and pre-treatment to remove PFOS.	Yes		Green Engineering, PLLC	\$48,036,000	\$48,036,000	69	61	2.N.7 (-3 points). Gave 2.N.3 (3 points) instead
4	No	Yes	162615	Fairmont, Town of	Robeson	Distressed	990	NC0378025			Water Supply & Dist. Improvements	Replace ~14,800 lf water mains. Rehab 3 water wells, 3 ground storage tanks, and replace of all manual meters with automatic read water meters.	Yes		LKC Engineering, PLLC	\$13,480,000	\$13,480,000	72	59	2.J. (-3 points) Insufficient water loss documentaiton 3.A.1. (10 points) CIP part of AMP insufficient
5	Yes	No	195242	Junaluska Sanitary District	Haywood	Not Distressed	1,820	NC0144035			HCC/Oak Park Low Pressure Water Line Reh	Replace 26,500 LF of undersized WL with 6-inch WL, a gravity pressure tank, 23 hydrants, and 268 reconections.	No		Brown Consultants, PA	\$9,495,104	\$9,495,104	58	58	
6	Yes	Yes	161890	Fayetteville Public Works Commission	Cumberland	Not Distressed	85,421	NC0326010			PO Hoffer Glenville Lake GAC Construction	Construct new GAC Facilities at both the PO Hoffer and Glenville Lake WTPs	No		Fayetteville PWC	\$75,858,446	\$74,307,300	63	58	
7	Yes	Yes	162484	Fuquay-Varina, Town of	Wake	Not Distressed	15,909	NC0392055			Sanford WFF - GAC Facility	GAC installation to remove PFAS.	No		Hazen and Sawyer	\$52,686,390	\$10,532,889	69	56	2.K.1. (-10 points) No interconnection in this project 2.N.7. (-3 points) Redundancy not part of project
8	No	Yes	161431	Bailey, Town of	Nash	Distressed	265	NC0464035			2023 Water System Improvements	Replace 1,400 ft waterline. Install a backup generator (Well No. 2)	Yes		Upper Coastal Plain Council of Governments	\$500,000	\$500,000	63	56	3.A.1. (-10 points) Insufficient AMP documentation 3.D. (- 5 points) Insufficient leak detection documentation 4.C.4 (-5 points) not given. 4.C.3 (7 points) given instead
9	Yes	No	195498	Aqua North Carolina	Cumberland	Not Distressed	12,437	NC0326127; NC0326124; NC0326332			Brookwood Community Ion Exchange Filters	Construct ion exchange filters on 8 contaminated wells	Yes		Black & Veatch	\$5,795,400	\$5,795,400	60	55	3.E (-3 points) Water rate structure information not sufficient 4.A (-2 points) Residential connections too high
10	Yes	Yes	161609	Holly Springs, Town of	Wake	Not Distressed	15,682	NC0392050			Sanford WFF Expansion – GAC Facility	Install GAC to remove PFAS.	No		Hazen and Sawyer	\$52,686,390	\$7,021,926	67	54	2.K.1. (-10 points) Interconnection not part of project 2.N.7. (-3 points) Redundeancy/resiliency not part of project
11	No	Yes	162716	Cape Fear Public Utility Authority	New Hanover	Not Distressed	67,124	NC0465010	34	\$74,943	Alandale Area Water Extension - PFAS	Connect ~34 private wells with PFAS contamination	No		Cape Fear Public Utility Authority	\$2,548,075	\$2,548,075	57	54	
12	Yes	Yes	162642	Columbus County Water District IV	Columbus	Not Distressed	1,072	NC7024013			Water System Improvements	Replace waterline and other aging waterlines and appurtenances	Yes		Green Engineering P.LLC	\$2,574,639	\$2,574,639	54	54	
13	No	Yes	162488	South Granville Water and Sewer Authority	Granville	Not Distressed	5,223	NC0239107			Post-Filter PFAS Treatment Improvements	Post filter improvements to remove PFAS to include GAC/IX, pump station to send filtered water to pressure contactors, flow meter and electrical & instrumentation.	No		CDM Smith	\$22,210,000	\$22,210,000	75	53	1.J.1. (20 points) points received, so not eligible for 2.B.1 (-20 points) 3.A.2. (-2 points) Insufficient CIP adoption documentation
14	No	Yes	162718	Greensboro, City of	Guilford	Not Distressed	99,283	NC0241010			Greensboro Mitchell ATEC	5 GAC feed pumps (booster pump station), 8 GAC contactor basins, 2 backwash pumps	No		HDR	\$55,674,000	\$55,674,000	53	53	
15	No	Yes	162626	Whiteville, City of	Columbus	Not Distressed	1,637	NC0424010			Phase 1 Water Improvements	Replace Approx 13,600 lf of 6" and 8" AC water mains and associated hydrants, valves, and 155 service connections, add permanent generators to 2 wells.	No		Engineering Services, PA	\$4,735,350	\$4,735,350	58	53	
16	No	No	194185	Ayden, Town of	Pitt	Distressed	2,227	NC0474025	253	\$1,976	Galvanized/Cast Iron Waterline Replace	Replace approx. 3,075 LF water lines	Yes		McDavid Associates, Inc.	\$500,000	\$500,000	80	53	2.B.1 (-20 points) Does not address water source contamination 3.E (-3 points) Water rate structure not sufficient
17	No	Yes	162544	Bald Head Island, Town of	Brunswick	Not Distressed	1,248	NC0410130			BHI DW Construction-Emerging Contaminant	Add an activated carbon system to treat all streams of the RO drinking water system.	No		WithersRave nel	\$5,000,000	\$5,000,000	52	52	
18	No	Yes	162614	Wadesboro, Town of	Anson	Not Distressed	2,170	NC0304020			Uptown Water Replacements Phase 2	Replace approx 13,000 LF watermain in downtown area. Replace ~135 lead service connections in the project area	No		LKC Engineering.c om	\$8,575,000	\$8,575,000	52	52	
19	No	Yes	162526	Sanford, City of	Lee	Not Distressed	19,192	NC0353010			Sanford WFF Expansion	Expand WFF from 12 mgd to 30 mgd and adding a GAC system.	Yes		Hazen and Sawyer	\$315,144,770	\$151,785,268	65	52	2.K.1. (-10 points) Project contains no interconnection 2.N.7. (-3 points) Project does not add resilience/redundancy

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
20	No	No	195365	Wilkesboro, Town of	Wilkes	Distressed	1,299	NC0197025			Yadkin River Raw Water Intake	New raw water intake facility	Yes	Yes	McGill Associates PA	\$18,354,250	\$9,805,243	56	51	2.K.1. (-10 points) Project does not create an interconnection 2.K.2. (-10 points) Two systems are not already interconnected 2.N.4. (-4 points) Existing equipment vulnerable to flood submersion 2.N.7. (-3 points) Received Line Item 2.N.5 points (4 points)
21	No	Yes	160857	Robersonville, Town of	Martin	Distressed	749	NC0459015			Unified SCADA and Meter Replacement Proj	Replace 998 water meters. Replace 44 lead service line with lead goosenecks		Yes	Municipal Engineering, Inc.	\$2,161,996	\$2,161,996	63	51	2.B.2. (-10 points) No LSL documentation 4.C.4. (-5 points) Line Item 4.C.3 (7 points) awarded instead
22	No	No	195665	Magnolia, Town of	Duplin	Distressed	493	NC0431035			Water Supply Well Replacement Project	Replace existing Well No. 1		Yes	McDavid Associates, Inc.	\$2,381,775	\$2,381,775	82	51	1.B. (-22 points) Insufficient failing infrastructure documentation. Received Line Items 1.C (12 points) and 1.C.1 (8 points) instead 2.B.1. (-20 points) Insufficient dry well documentation 3.D. (-5 points) Insufficient water loss documentation 4.C.4 (-5 points) Only one line item in Line Item 4.C.4 can be claimed
23	No	Yes	161544	Gates County	Gates	Distressed	4,631	NC0437020	39	\$73,760	WaterSys.Improve.DisadvantagedCommunity	Add 24,375 ft water line to disadvantaged community to serve 39 homes. Add backup well. Add standby power at 4 sites and SCADA.		No	Green Engineering, PLLC	\$2,876,634	\$2,876,634	58	51	1.D. (-2 points) Not awarded because received 1.E. (20 points) 4.C.4. (-5 points) Gave 4.C.2 (5 points) instead
24	No	No	194157	Parmele, Town of	Martin	Distressed	146	NC0459113			Fire Hydrant Replacement	Replacing Approx 20 existing fire hydrants and 50 services.		Yes	McDavid Associates, Inc.	\$500,000	\$500,000	75	51	2.B.1. (-20 points) Contamination documentation not provided
25	No	Yes	162635	North Lenoir Water Corporation	Lenoir	Not Distressed	6,061	NC0454025			2023 Water System Improvements	Replace ~3, 550 ft water lines in disadventaed area		Yes	McDavid Associates, Inc.	\$1,815,445	\$1,815,445	56	51	4.C.4 (-5 points) Project receives 4.C.3 (7 points) instead
26	No	No	195658	Aqua North Carolina, Inc	Catawba	Not Distressed	26	NC0118130			Idlewood Acres Water Line Replacement	Replace approx. 2,100 LF water line		No	WK Dickson & Co., Inc.	\$800,000	\$800,000	60	50	3.A.2 (-2 points) CIP insufficient. 4.A (-2 points) No owner connections provided
27	No	No	195406	Edgecombe County	Edgecombe	Distressed	5,178	NC0433050			2024 General Water System Improvements	Rehab and replacement of Tank mixers, Booseter Pump, chem feeder, Meter read system, & SCADA		Yes	The Wooten Company	\$6,739,000	\$6,739,000	55	50	
28	No	Yes	161415	Whitakers, Town of	Nash,Edgecombe	Distressed	319	NC0433040			Advanced Metering Infrastructure System	Replace existing water meters		Yes	Upper Coastal Plain Council of Governments	\$677,876	\$677,886	68	50	2.B.2. (-10 points) Insufficient mapping documentation 3.D. (-5) Insufficient leak detection documentation 3.E. (-3 points) Rates not conservation rates 4.C.4. (-5 points) Insufficient DA documentation. Gave 4.C.3 points instead
29	No	No	195587	Goldsboro, City of	Wayne	Distressed	12,276	NC0496010			PFAS Treatment Improvement Project	New post-filter treatment to WTP to address the PFAS levels in the drinking water. The improvements are sitework and install of GAC, pressure contact vessels & piping		No	CDM Smith	\$35,584,800	\$35,584,800	59	49	2.D. (-10 points) Missing regulatory citation 2.H.4 Information provided in the application project description, not the narrative. Copy of most recent lab reports provided. No maps provided.
30	No	Yes	162420	Maysville, Town of	Jones	Distressed	510	NC0452010			Waterline Repairs	Install automated controls and SCADA at WTP to enhance PFOS and PFOA removal. Replace ~7,800 ft of water mains.		No	TRC Engineers, Inc.	\$3,161,730	\$3,161,730	53	49	4.C.4. (-5 points) Insufficient documentation provided
31	No	No	195570	Seaboard, Town of	Northampton	Distressed	276	NC0466035			2024 Water System Improvements	Replace water storage tank		Yes	Upper Coastal Plain Council of Governments	\$2,500,000	\$2,500,000	56	49	3.A.1. (-10 points) Insufficient AMP documentation related to CIP 3.C. (-5 points) WPP > 5 years old 3.D. (-5 points) Insufficient leak detection documentation
32	No	Yes	161725	Murfreesboro, Town of	Hertford	Not Distressed	1,125	NC0446015			Main St. & Third St. Water Line Replacem	Replace of ~6,000 ft water line and any lead goose necks encountered		No	Municipal Engineering, Inc.	\$1,237,500	\$1,237,500	59	49	2.B.2. (-10 points) Insufficient LSL removal documentation
33	No	Yes	162441	Murfreesboro, Town of	Hertford	Not Distressed	1,125	NC0446015			System Water Valve Replacement	Replace of ~240 System Valves, like for like.		No	Municipal Engineering, Inc.	\$761,000	\$761,000	49	49	
34	No	Yes	161425	Wilkesboro, Town of	Wilkes	Distressed	1,503	NC0197025			Water Treatment Plant Upgrades	Replace raw water intake, construct storage and pretreatment tank, and Rehab filter and backwash system.		Yes	McGill Associates	\$25,472,700	\$25,472,700	47	48	2.N.4. (-4 points) Insufficient resiliency documentation 3.B. (5 points) OR documentation >= 1.00
35	No	No	195500	Magnolia, Town of	Duplin	Distressed	493	NC0431035			Automatic Meter Infrastructure Project	AMI system for the entire water system		Yes	McDavid Associates, Inc.	\$634,855	\$634,855	67	48	2.B.2. (-10 points) Insufficient LSL documentation 3.A.2 (-2 points) Insufficient CIP documentation 3.D (-5 points) Insufficient leak detection documentation

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
36	No	No	195652	River Bend, Town of	Craven	Not Distressed	1,483	NC0425113			Water Supply Wells	Intallation of two new wells to replace two older wells and a interconnection with the City of Newbern.	No		Rivers & Associates, Inc.	\$2,211,000	\$2,211,000	74	47	1.C.1. (-8 points) Insufficient old infrastructure supporting documentation provided 2.I. (-3 points) No additional treatment is being added or upgraded 2.N.7. (-3 points) Only 1 line item allowed under 2.N 3.A.1. (-10 points) Insufficient AMP documentation provided. Gave 3.A.2. for CIP instead (2 points) 3.C. (-5 points) Insufficient SWP documentation provided
37	No	No	195645	Roper, Town of	Washington	Not Distressed	207	NC0494015			Phase 3 Waterline Replacement	Replace 4,050 LF water mains with new 6-inch PVC.	No		The Wooten Company	\$1,083,140	\$1,083,140	60	46	2.G. (-10 points) Insufficient low pressure documentation 4.C.4. (-5 points) Can only claim one line item under Line Item 4.C
38	No	No	195595	North Lenoir Water Corporation	Lenoir	Not Distressed	6,131	NC0454025			2024 Water System Improvements	replace approx 8,000 LF water lines	Yes		McDavid Associates, inc.	\$1,414,900	\$1,414,900	51	46	3.D. (-5 points) Water loss documention not provided
39	No	Yes	162209	Ansonville, Town of	Anson	Not Distressed	451	NC0304012			Water Distribution System Improvements	Replace aging water lines with like size to reduce expenses related to water loss.	No		TRC Engineers, Inc.	\$995,000	\$955,000	40	44	3.B. (5 points) OR >= 1.00 as calculated by data 4.B. (4 pts) Based on provided data 4.C.4 (-5 points) Gave 4.C.3 (7 points) instead
40	No	Yes	162671	Newland, Town of	Avery	Not Distressed	348	NC0106020			Avery Square WM Improvements	Replace cast iron lines in the central part of the town	No		Mack Gay Associates, PA	\$407,683	\$407,683	43	43	
41	No	Yes	162677	Henderson, City of	Vance	Not Distressed	8,221	NC0291010			Kerr Lake WTP Expansion Project	Increase plant capacity of already undergoing project from 15MGD to 20MGD.	No		CDM Smith	\$104,995,172	\$45,000,000	58	43	
42	No	Yes	162674	Greenville Utilities Commission	Pitt	Not Distressed	34,432	NC0474010			GAC Filter Media Replacement	GAC media installation.	No		Greenville Utilities Commission	\$1,815,000	\$1,815,000	47	42	3.A.1. (-10 points) Insufficient CIP documentation 3.B. (5 points) added OR points though not requested
43	No	Yes	162659	Hookerton, Town of	Greene	Distressed	215	NC0440020			Drinking Water Improvements	Replace ~2,500 lf water main, ~100 services, and install ~15 hydrants	Yes		Mack Gay Associates, PA	\$972,515	\$972,515	57	42	
44	No	No	194252	Beech Mountain, Town of	Avery, Watauga	Not Distressed	2,114	NC0195104			2023 Water System Rehab (Expansion)	replace 2 booster pump stations & addition of a generator.	No		West Consultants, PLLC	\$1,469,900	\$1,469,900	42	42	
45	No	No	195693	Perquimans County	Perquimans	Distressed	5,300	NC0472025			Water Treatment Plant Discharge	Bethel WTP approx. 8,000 LF of discharge piping, 780 LF of horizontal drilling, a new 250 GPM pump station and a flow diffusing structure. Winfall WTP clean and convert an existing raw water main to use as backwash piping, 500 LF discharge piping, 200 LF horizontal drilling and a diffuser discharge structure. Construct approx. 21,100 LF of 12-inch water main.	No		The East Group	\$6,142,000	\$6,142,000	55	42	1.C. (-12 points) Rehabilitation/replacement documentation not provided. Gave 1.D points for expansion (2 points). 2.N.7. (-3 points) insufficient resiliency/redundancy documentation provided.
46	No	No	195506	Burlington, City of	Alamance	Not Distressed	24,112	NC0201010			GAC Construction Project	Installation of a GAC system to treat for PFAS.	No		Hazen and Sawyer	\$28,160,000	\$28,160,000	40	40	
47	No	No	194190	Chowan County	Chowan	Not Distressed	4,340	NC0421015			Cape Colony Wtr Syst Imp & Fire Hyd Repl	Phase I: Replace Approx 23,850 LF water line; add 25 hydrants, and 213 new services. Phase II: Replace 11,330 LF water line, add 16 hydrants, and 211 services.	Yes	Yes	Rivers & Associates, Inc.	\$15,290,696	\$15,290,696	50	40	3.A.1. (-10 points) Insufficient AMP documentation. 3.A.2. (-2 points) CIP not adopted within last 2 yrs
48	No	Yes	161493	Jonesville, Town of	Yadkin	Distressed	1,193	NC0299010			Elevated Water Tank	Replace tanks with new 1,000,000 gallon elevated storage tank.	Yes		The Wooten Company	\$9,379,600	\$9,379,600	95	40	1.B. (-22 points) Failing infrastructure purpose not met. Gave 1.C (12 points) and 1.C.1 (8 points) instead 2.B.1. (-20 points) Insufficient dry well/well contamination documentation 2.G. (-10 points) Insufficient low pressure documentation 2.H.3. (-5 points) Project does not address PFAS 2.J. (-3 points) Insufficient water loss documentation 2.N.7. (-3 points) Insufficient resiliency/redundancy documentation 3.A.1. (-10 points) Insufficient AMP documentation 3.A.2. (-2 points) Insufficient CIP documentation 3.C. Insufficient documentation. 4.C.4. Insufficient narrative.

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
49	No	Yes	162612	Carolina Water Service, Inc	Mecklenburg	Not Distressed	31,422	NC0157125			Watauga Vista - Water Main Replacement	Replace 2,300 ft waterline to increase volume and pressure.	No	No	Carolina Water Service, Inc. of North Carolina	\$151,083	\$151,083	46	40	2.N.7. (-3 points) Project does not add redundancy/resiliency
50	No	No	195499	Fayetteville Public Works Commission	Cumberland	Not Distressed	85,421	NC0326010			PO Hoffer WTF Phase 3 Residuals	New dewatering facility and add a third gravity thickener.	No	No	Hazen and Sawyer	\$34,923,298	\$34,184,606	50	40	
51	No	Yes	162501	Carolina Water Service, Inc	Mecklenburg	Not Distressed	31,422	NC0103102			High Meadows -Mains & Valves Replacement	Replace 1,850 LF waterline and add a pressure relief valve.	No	No	Carolina Water Service, Inc. of North Carolina	\$410,000	\$410,000	56	40	2.G. (-10 points) Insufficient low pressure 2.J. (-3 points) Insufficient water loss 2.N.7 (-3 points) Does not meet resiliency/redundancy requirements
52	No	No	195601	Rocky Point Topsail Water and Sewer District	Pender	Not Distressed	11,944	NC7071011			RO WTP and Assoc Improvements	New Groundwater wellfield with conveyance to the WTP, Pretreatment, Membrane system and controls, Permeate collection piping and storage tank, Chemical dosing systems, Ground storage tank, High service pumping, Concentrate discharge pump and piping	No	No	CDM Smith	\$110,950,000	\$37,200,000	59	40	2.B.1. (-20 points) Line item not for PFAS 2.H.2. (-10 points) Line item not for PFAS
53	No	Yes	162720	Cape Fear Public Utility Authority	New Hanover	Not Distressed	67,124	NC0465010	10	\$67,170	Rockhill Area Water Extension - PFAS	Connect approx. 10 private wells with PFAS contamination	No	No	Cape Fear Public Utility Authority	\$671,700	\$671,700	52	39	3.A.1. (-10 points) AMP points removed because project not on CIP
54	No	Yes	162828	Edenton, Town of	Chowan	Distressed	1,729	NC0421010			Replacement of Virginia Road Well	Construct new well and interconnect with WTP. Add generator for backup power and SCADA.	0	No	Stroud Engineering, PA	\$1,449,300	\$1,449,300	70	39	2.B.1 (-20 points) Project does not meet dry well criteria. 3.B (-5 points) Rate sheet not provided. 3.C (-5 points) Outdated wellhead protection plan. 4.B (-6 points) Rate sheet not provided.
55	No	Yes	161312	Cerro Gordo, Town of	Columbus	Distressed	72	NC0424055			Water St. Well Rehab & Emergency Interco	Rehab of well and Install an interconnection meter.	Yes	Yes	LKC Engineering, PLLC.	\$1,375,000	\$1,375,000	57	39	1.C.1. (-8 points) Insufficient age documentation 2.K.1. (-10 points) Insufficient interconnection documentation
56	No	Yes	161879	Stoneville, Town of	Rockingham	Distressed	558	NC0279035			Water System Improvements	Replace 18,500 lf water main. Upgrade Booser Pump, rehab 75,000 gal. elevated storage tank, construct Booster Pump Station.	Yes	Yes	LKC Engineering, PLLC	\$8,825,000	\$8,825,000	59	39	1.C. (-12 points) Project is expansion. Received 1.D (2 points instead) 1.C.1 (-8 points) Points rolled down to 1.D.1 (8 points) 3.A.1. (-10 points) insufficient AMP narrative 3.A.2. (-2 points) Insufficient CIP matrix
57	No	No	195435	Roanoke Rapids Sanitary District	Halifax	Not Distressed	8,204	NC0442010			Drinking Water Emerging Contaminant Study	Conduct PFAS Treatment Alternatives Evaluation including: 1. Review PFAS trends 2. PFAS Treatment Technology Assessment - Bench-Scale Testing 3. PFAS Treatment Technology Assessment - Pilot Testing 4. Treatment Technology Selection	No	No	Hazen and Sawyer	\$500,000	\$500,000	39	39	
58	No	Yes	162427	Pine Level, Town of	Johnston	Not Distressed	1,303	NC0351040			Water Treatment Plant Renovation	Rehab Aeration tower. SCADA upgrades and miscellaneous WTP site improvements.	No	No	TRC Engineers, Inc.	\$1,118,000	\$1,118,000	38	38	
59	No	Yes	162435	Haw River, Town of	Alamance	Not Distressed	896	NC0202020			Spray Street Watermain Replacement	Increase size of an existing 2" waterline to 12" to increase fire protection.	Yes	Yes	Alley, Williams, Carmen, & King, Inc Carolina Water Service, Inc. of North Carolina	\$1,000,000	\$1,000,000	44	38	2.K.2 (-10 points) Insufficient narrative
60	No	Yes	162464	Carolina Water Service, Inc	Mecklenburg	Not Distressed	31,422	NC4092085			Rutledge Landing - Well#3 Rehabilitation	Replace Well #3 system with a new system, and remote monitoring.	No	No	Carolina Water Service, Inc. of North Carolina	\$495,980	\$495,980	43	38	1.D. (-2 points) Expansion purpose not met 2.N.7 (-3 points) Insufficient resiliency/redundancy narrative
61	No	Yes	162827	Piedmont Triad Regional Water Authority	Randolph	Not Distressed	0	NC3076010			PFAS Construction RO Treatment System	construct post filtration reverse osmosis treatment facility for the removal of PFAS, 1,4 Dioxane and other potential emerging compounds at the JFK WTP.	No	No	Piedmont Triad Regional Water Authority	\$74,646,250	\$74,646,250	37	37	
62	No	Yes	161554	Fuquay-Varina, Town of	Wake	Not Distressed	15,909	NC0392055			Sanford WFF Expansion - Conventional	Expand the Sanford Water Filtration Facility from 12 to 30 MGD. With Fuquay-Varina , Holly Springs and Sandford	No	No	Hazen and Sawyer	\$262,458,380	\$87,424,925	49	36	2.K.1. (-10 points) No interconnection as part of project 2.N.7. (-3 points) Insufficient resiliency/redundancy documentaiton

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
63	No	Yes	162503	Albemarle, City of	Stanly	Distressed	6,788	NC0184010			Albemarle – Old Whitney Raw Water Main	Replace 28,000 feet, 24" raw water main with 30". Install new permanent backup generator	Yes		LKC Engineering, PLLC	\$32,083,000	\$32,083,000	45	35	2.K.2. (-10 points) Project does not meet interconnection guidance requirements
64	No	Yes	162631	Cove City, Town of	Craven	Not Distressed	225	NC0425045			Automatic Meter Reading System Project	Replace all meters in town with an AMR slow "drive-by" meter reading system.	Yes		McDavid Associates, Inc.	\$394,627	\$394,627	54	35	2.B.2. (-10 points) Project does not replace LSLs 3.A.2. (-2 points) AMP CIP narrative and documentaiton insufficient 3.D. (-5 points) Insufficient water loss documentation
65	No	Yes	161599	Holly Springs, Town of	Wake	Not Distressed	15,682	NC0392050			Sanford WFF Expansion	Funding for 4 mgd capacity as part of Sanford expansion from 12 mgd to 30 mgd.	No		Hazen and Sawyer	\$262,458,380	\$58,349,762	47	34	2.K.1. (-10 points) Project contains no interconnection 2.N.7. (-3 points) Project replaces and does not add generators for redundancy.
66	No	Yes	162506	Albemarle, City of	Stanly	Distressed	6,788	NC0184010			US52 WTP 20-inch Water Transmission	Replace 12,000 ft of 24" and 20"lines	Yes		LKC Engineering, PLLC	\$6,276,000	\$6,276,000	32	32	
67	No	No	195575	Goldsboro, City of	Wayne	Distressed	12,276	NC0496010			PFAS Treatment Evaluation and Pilot	Study treatment alternatives to remove PFAS compounds.	No		CDM Smith	\$500,000	\$500,000	44	31	2.D. (-10 points) EC projects not eligible for 2.D points. 2.I. (-3 points) EC study projects not eligible for 2.I points. 4.C.4. (-5 points) Insufficient narrative for DA. Awarded 4.C.3. (7 points) instead.
68	No	Yes	161880	Holly Springs, Town of	Wake	Not Distressed	15,682	NC0392050			HS and F-V Waterline Transmission Main	36" transmission main from Sanford WFF to proposed BPS, two (2) 1.5 million gallon ground storage tanks, 30 and 24" transmission mains to Fuquay Varina and 24" transmission main to Holly Springs.	No		Hazen and Sawyer	\$139,722,151	\$51,011,755	31	31	
69	No	Yes	161539	Gates County	Gates	Distressed	4,631	NC0437020			Water Tank Replacement and Resiliency	Replace the 150,000 gallon Elevated Storage Tank and add standby power.	No		Green Engineering, PLLC	\$1,453,600	\$1,453,600	51	31	1.C. (-12 points) Insufficient rehab/replace documantation
70	No	Yes	162498	Hertford County Northern Rural Water District	Hertford	Not Distressed	936	NC0446045	15	\$32,450	Eleytown Road Waterline Extension	Water line extension to add 15 residential properties. 3,500 ft- 6" PVC water line & 4 hydrants. County to pay cost of connection due to residents location in Disadvantaged Area.	No		Municipal Engineering, Inc.	\$486,750	\$486,750	57	31	1.D. (-8 points) Insufficient expansion narrative 1.E. (-20 points) Insufficient DA service documentation 4.C.4 (-5 points) Insufficient DA narrative
71	No	Yes	162201	Carolina Water Service, Inc	Mecklenburg	Not Distressed	31,422	NC0120103			Bear Paw - Drill New Well	New well to address capacity and create redundancy	No		Carolina Water Service, Inc. of North Carolina	\$447,329	\$447,329	34	30	2.N.5. (-4 points) Insufficient fortification/elevation resilience narrative and documentation
72	No	No	195456	Orange Water and Sewer Authority	Orange	Not Distressed	19,765	NC0368010			PFAS Treatment at Jones Ferry WTP	Conduct PFAS study and pilot testing. Funds used to determine best option for treatment.	No		Black & Veatch	\$694,000	\$500,000	28	28	
73	No	No	195685	Harkers Island Sanitary District	Carteret	Not Distressed	982	NC0416025	50	\$32,695	HISD Water System Improvements	Installation of a 350 gpm well, treatment building, telemetry, approx 7,000 LF water line extension, and 50 new services.	Yes		Michael E. Weatherly, P.E. - Consulting Environmental & Civil Engineer	\$1,634,750	\$1,634,750	35	27	1.C.1. (-8 points) No infrastructure being taken out of service 1.D. New lines where none were. 2.N.7. Only one line item may be chosen under 2.N. 3.C. Letter provided is dated 5/13/2010 (older than 5 years).
74	No	Yes	162514	Hertford County Southern Rural Water District	Hertford	Not Distressed	2,237	NC0446045	8	\$115,725	Blowe Rd. Waterline Extension	Construct 7,100 LF waterline, 7 hydrants to add 8 residential customers. Residents requested County water service due to poor well quality and quantity.	No		Municipal Engineering, Inc.	\$925,800	\$925,800	54	27	1.D. (-2 points) Insufficient expansion documentation 1.E. (-20 points) Insufficient documentation of DA service area 4.C.4. (-5 points) Insufficient narrative for DA benefit
75	No	Yes	162508	Bladen County Water District	Bladen	Not Distressed	4,936	NC0309055			Bladen Co. West - Water System Improvs.	Construct new booster pump and iron filtration system to replace well with high influent PFAS levels.	Yes		LKC Engineering, PLLC	\$3,410,000	\$3,410,000	75	26	1.J.1. (-20 points) PFAS treatment construction purpose not met 2.B. (-20 points) Insufficient contamination narrative and documentation provided 2.H.4. (-10 points) Insufficient documentation for PFAS HI or proposed MCL

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
76	No	No	195644	Surry County	Surry	Distressed			22	\$59,255	Hiatt Road Water Extensions	Install ±8,200 LF of waterlines to serve 22 new residential and commercial customers.	Yes		The Lane Group, Inc.	\$1,303,600	\$1,303,600	73	25	1.D. (-2 points) - Purpose points earned for 1.E (20 points) 2.B.1. (-20 points) Project does not benefit areas served by public wells 2.F.2. (-5 points) Surry County is not a PWS 2.H.2. (-10 points) Insufficient documentation of contaminated wells 3.E. (-3 points) Applicant does not have conservation incentive rate structure 4.A (-2 points) Applicant does not have residential connections 4.B (-8 points) Applicant does not have water and sewer rates
77	No	Yes	161620	Carolina Water Service, Inc. of North Carolina	Mecklenburg	Not Distressed	31,422	Multiple			Phase 2 - AMI Meter Exchange	Replace 4,222 water meters in 16 communities in 9 Counties.	No		Carolina Water Service, Inc. of North Carolina	\$2,745,537	\$2,745,537	40	25	1.C. (-12 points) Applicant is not distressed 2.N.7. (-3 points) Insufficient narrative and documentation 4.C. (0 points) Applicant has no LGU indicators.
78	No	No	195584	Asheboro, City of	Randolph	Not Distressed	11,860	NC0276010			W L Brown WTP Emerg Cont Planning Study	Planning project to determine best practice for PFAS removal at current WTP.	No		City of Asheboro	\$500,000	\$500,000	28	23	2.H.3. (-5 points) Not awarded because 2.H.4 (10 points) awarded instead.
79	No	Yes	162611	Johnston County	Johnston	Not Distressed	66,595	NC0351070			Water TransSCADA & Security Improvements	Update SCADA hardware, add SCADA equipment to 10 new locations, pressure monitoring to 30 locations, and enhance cyber security measures and access control.	No		Johnston County Public Utilities	\$1,571,000	\$1,540,000	23	23	
80	No	No	195477	Rocky Mount, City of	Nash	Not Distressed	21,851	NC0464010			PFAS Treatment at Rocky Mount WTPs	Conduct a pilot study to: Compare alternative media configurations, refine operational parameters, validate design criteria, estimate life cycle costs based on media replace frequency.	No		Black & Veatch	\$500,000	\$500,000	27	22	3.B (-5 points) Not awarded. Does not meet OR/MHI criteria.
81	No	No	195608	Pender County	Pender	Not Distressed	11,944	NC7071011			Penderlea-Hwy421 Waterline Improvements	Installation of 17.5 miles WL to create loops and provide and emergency interconnection with the Town of Harrells water system.	No		CDM Smith	\$35,590,000	\$35,590,000	24	22	1.D. (-2 points) Expansion documentation not provided
82	No	Yes	161569	High Point, City of	Randolph	Not Distressed	40,001	NC3076010			PTRWA Emerging Compound Treatment	WTF expansion and RO treatments	0		City of High Point	\$120,185,000	\$16,150,000	75	16	1.C. (-12 points) Insufficient rehab/replace documentation 1.D. (-2 points) Insufficient expansion narrative 1.E. (-20 points) Insufficient service to DA narrative 1.J.1. (-20 points) Insufficient PFAS construction entire budget narrative 1.J.2. (-15 points) Insufficient PFAS construction partial budget narrative 2.D. (-10 points) Insufficient promulgated but not effective regulation narrative 2.H.1. (-15 points) Insufficient acute contamination narrative 2.H.3 (-5 points) Insufficient PFAS health impacts narrative 2.H.4. (-10 points) Insufficient HI or proposed MCL exceedance narrative 2.I. (-3 points) Insufficient treatment upgrade narrative 3.A.2. (-2 points) Insufficient CIP narrative 3.C. (-5 points) Insufficient SWP narrative 3.D. (-5 points) Insufficient water loss reduction narrative 4.C.4. (-5 points) Insufficient DA narrative
83	No	Yes	161589	Blue Ridge Water Association, Inc.	Wilkes	Not Distressed	3,226	NC0197030			Water System Improvements 2023	New 150,000 gallon storage tank	No		Municipal Engineering, Inc.	\$2,245,000	\$2,245,000	30	15	2.G. (-10 points) Insufficient low pressure documentation 3.B. (-5 points) Calculated OR < 1.00 4.C.4. (-5 points) Insufficient DA documentation
84	No	Yes	161604	Carolina Water Service, Inc. of North Carolina	Mecklenburg	Not Distressed	31,422	Multiple			Phase 1 - AMI Meter Exchange	Replace 8,640 water meters in 18 communities in 14 counties	No		Carolina Water Service, Inc. of North Carolina	\$5,628,879	\$5,628,879	40	15	1.C. (-12 points) Applicant is not distressed 2.N.7. (-3 points) Insufficient narrative and documentation 3.D. (-5) Insufficient water loss reduction documentation 4.C. (0 points) Applicant has no LGU indicators.

Application Number	Proposed Funding with DWSRF (non-EC)?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
--------------------	---------------------------------------	---	-------------	----------------	--------	------------------------	-------------------------	-------	----------------------------	------------------------------------	--------------	---------------------	-----------------------	-------------------------	----------------------	--------------------	-------------------	--	-----------------	---

Incomplete and Ineligible Applications

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	PWSID	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Result of AIA or MRF?	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Reason for Incompleteness/Ineligibility
INEL_1	No	Yes	162040	Fayetteville Public Works Commission	Cumberland	Not Distressed	85,421	NC0326010			PO Hoffer Glenville GAC Design	Design 14 GAC contactors at the PO Hoffer WTP, and 5 at the Glenville Lake WTP.	No	No	Fayetteville PWC	\$4,918,568	\$4,758,400	48	N/A	Ineligible - Construction project SRF-D-EC-0003 & SRF-D-2052 is currently funded and can cover planning costs