



Garry A. Whisnant  
Plant General Manager  
Asheville Steam Electric Plant

Duke Energy Progress  
ASVL PLT | 200 CP&L Dr  
Arden, NC 28704

June 13, 2019

o: 828-687-5211  
f: 828-687-5204

[garry.whisnant@duke-energy.com](mailto:garry.whisnant@duke-energy.com)

**ELECTRONIC SUBMITTAL**

Ms. Linda Culpepper, Interim Director  
North Carolina Division of Water Resources  
E-mail Address: [desocdata@ncdenr.gov](mailto:desocdata@ncdenr.gov)

**Subject: Duke Energy Progress, LLC  
Asheville Plant  
EMC SOC WQ S17-010  
NPDES Permit NC0000396  
2nd Quarter 2019 - Monitoring Data Results**

Dear Ms. Culpepper:

In accordance with paragraph 2. d. 3) of the NC Environmental Management Commission Special Order by Consent, EMC SOC WQ S17-010, Duke Energy Progress, LLC is hereby submitting the monitoring results for the 2nd quarter of 2019.

If you have any questions, please contact Mr. Robert Wylie (704) 382-4669 or Ms. Teresa Williams (828) 687-5240.

*I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.*

Sincerely,

A handwritten signature in black ink, appearing to read "Garry A. Whisnant".

Mr. Garry Whisnant  
Plant Manager - Asheville station

Enclosures

Duke Energy Carolinas, LLC - Asheville Steam Station  
Special Order by Consent - SOC No. S17-010  
Monitoring Report for 2nd Quarter of 2019

SAMPLING LOCATION	Date Sampled	TSS*	Oil and Grease*	pH	Fluoride	Mercury	Barium	Zinc	Arsenic	Boron	Cadmium	Chromium	Copper	Thallium	Lead	Nickel	Selenium	Nitrate/Nitrite as N	Bromides	Sulfates	Chlorides	TDS	Total Hardness	Temperature	Conductivity
		-	-	-	-	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	-	-	-	-	-	Total	-	-
		mg/L	mg/L	SU	ug/L	ng/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	°C
A-01	5/23/2019			6.6	< 100	8.22	86	< 5	< 1	555	< 0.1	< 1	< 1	< 0.2	0.380	< 1	2.44	1.0	0.14	54	33	140	84.7	23	279
B-01	5/23/2019			6.8	< 500	9.81	58	< 5	< 1	3670	< 0.1	< 1	< 1	< 0.2	< 0.2	1.70	< 1	0.27	1.4	150	180	580	371	24	889
C-01	5/23/2019			6.8	< 500	0.906	63	32.0	8.67	2840	0.545	< 1	< 1	0.312	0.694	23.0	1.53	0.52	1.2	450	110	870	591	19	1190
E-01	5/23/2019			6.6	< 500	1.35	80	7.42	< 1	512	< 0.1	< 1	< 1	< 0.2	< 0.2	1.87	< 1	0.01	< 0.5	58	35	230	123	21	387
F-01	5/23/2019			6.5	< 500	1.12	58	87.0	1.38	283	0.141	< 1	< 1	< 0.2	< 0.2	42.4	< 1	0.58	< 0.5	160	9.1	270	137	22	356
F-02	5/23/2019	no flow																							

\*Annual Monitoring Only

\*\*Duplicate was gathered at this location and the respective values averaged

Duke Energy Carolinas, LLC - Asheville Steam Station  
Special Order by Consent - SOC No. S17-010  
Monitoring Report for 2nd Quarter of 2019

SAMPLING LOCATION	Date Sampled	TSS*	Oil and Grease*	pH	Fluoride	Mercury	Barium	Zinc	Arsenic	Boron	Cadmium	Chromium	Copper	Thallium	Lead	Nickel	Selenium	Nitrate/Nitrite as N	Bromides	Sulfates	Chlorides	TDS	Total Hardness	Temperature	Conductivity
		-	-	-	-	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	-	-	-	-	-	Total	-	-
		mg/L	mg/L	SU	ug/L	ng/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	°C
N-01 Downstream	5/23/2019			7.5	< 100	3.98	29	9.54	< 1	< 50	1.63	2.42	< 1	< 0.2	0.267	1	< 1	0.44	< 0.1	31	6.3	81	49.1	16	132
French Broad Upstream	5/23/2019			7.2	< 100	1.51	12	< 5	< 1	< 50	< 0.1	< 1	< 1	< 0.2	0.268	< 1	< 1	0.28	< 0.1	1.5	2.3	< 25	8.78	19	35
French Broad Downstream	5/23/2019			7.3	< 100	1.24**	12	< 5	< 1	< 50	< 0.1	< 1	< 1	< 0.2	0.223	< 1	< 1	0.27	< 0.1	1.8	2.3	37	9.15	23	47

\*Annual Monitoring Only  
\*\*Duplicate was gathered at this location and the respective values averaged