



W. H. Weatherspoon Plant
491 Power Plant Rd
Lumberton, NC 28358

Mailing Address:
Kent Tyndall
L. V. Sutton Energy Complex
801 Sutton Steam Plant Rd
Wilmington, NC 28401
o 910.341-4775

April 22, 2020

Via email desocdata@ncdenr.gov
ELECTRONIC SUBMITTAL

Mr. Danny Smith, Director
North Carolina Division of Water Resources

Address: desocdata@ncdenr.gov

Subject: Duke Energy Progress, LLC
W.H. Weatherspoon Facility
EMC SOC WQ S19-006
1st Quarter 2020 – Monitoring Data Results

Dear Mr. Smith:

In accordance with paragraph 2.c.4 of the NC Environmental Management Commission Special Order By Consent, EMC SOC WQ S19-006, Duke Energy Progress, LLC is hereby submitting the monitoring results for the 1st quarter 2020.

If there are any questions, please contact either:

- Mr. Kent Tyndall, EHS Professional for the W. H. Weatherspoon Plant; phone (910) 341-4775 or e-mail Kent.Tyndall@duke-energy.com; or
- Ms. Joyce Dishmon, Environmental Specialist with our Environmental Permitting and Compliance Group, phone (336) 623-0238 or email Joyce.Dishmon@duke-energy.com.

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations

Sincerely,

Jeffrey Flanagan
Station Manager

Duke Energy Carolinas, LLC - Weatherspoon Steam Station
 Special Order by Consent - SOC No. S19-006
 Monitoring Report for 1st Quarter of 2020

SAMPLING LOCATION	Date Sampled	TSS*	Oil and Grease*	pH	Fluoride	Mercury	Barium	Zinc	Arsenic	Boron	Cadmium	Chromium	Copper	Thallium	Lead	Nickel	Selenium	Nitrate/Nitrite as N	Bromides	Sulfates	Chlorides	TDS	Total Hardness	Temperature	Conductivity	
		-	-	-	-	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	Total	-	-	-	-	-	Total	-	-
		mg/L	mg/L	SU	ug/L	ng/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	°C	umho/cm
S-05	3/11/2020	< 2.5	< 5	6.8	< 100	**0.810	86	< 5	2.73	1290	< 0.1	< 1	1.18	< 0.2	< 0.2	6.66	< 1	0.08	0.48	140	15	386	232	17	582	
S-16	3/11/2020	< 2.5	< 5	7	< 100	1.96	44	7.56	1.86	196	< 0.1	< 1	< 1	< 0.2	0.393	1.96	< 1	0.11	< 0.1	28	8.4	117	55	17	168	

*Annual Monitoring Only
 **Duplicate was gathered at this location and the respective values averaged