

**DEPARTMENT OF ENVIRONMENTAL QUALITY
DIVISION OF WATER RESOURCES
FACT SHEET FOR NPDES PERMIT DEVELOPMENT
NPDES No. NC0005088**

Facility Information			
Applicant/Facility	Duke Energy Carolinas, LLC / Rogers Energy Complex		
Applicant Address:	526 Church St., Charlotte, NC 28202		
Facility Address:	573 Duke Power Road, Mooresboro, NC 28024		
Permitted Flow (MGD):	Not limited		
Type of Waste:	Industrial & domestic		
Facility Classification:	II		
Permit Status:	Renewal		
County:	Rutherford & Cleveland		
Miscellaneous			
Receiving Stream:	Broad River/UT to Broad River (Outfall 106)	State Grid:	G11NE
Stream Classification:	WS-IV	USGS Quad:	Chesnee
Drainage Area (mi ²):	849 - Broad River	Basin/Subbasin:	Broad/03-08-02
Summer 7Q10 (cfs)	287 Broad River	303(d) Listed?	No
Winter 7Q10 (cfs):	440 Broad River	HUC:	03050105
30Q2 (cfs)	635 Broad River	Regional Office:	Asheville
Average Flow (cfs):	1460 Broad River	Permit Writer:	Teresa Rodriguez
IWC (%):	7.7 (002) 3.1 (005)	Date:	4/3/2018

SUMMARY

Duke Energy Carolinas operates the Rogers Energy Complex (REC); formerly known as Cliffside Steam Station; a two-unit coal fired steam electric generating facility. Units 1-4 have been removed from service. The station now operates only two units; Units 5 and 6. The total combined output is 1500 megawatts. Each unit has a Flue Gas Desulfurization (FGD) system. The site has an industrial landfill for combustion byproducts where fly ash, bottom ash, gypsum and WWTP sludge is deposited.

Water for cooling is withdrawn from the Broad River. Both units use cooling towers for heat dissipation. Blowdown from Unit 5 is discharged to the ash basin. Blowdown from Unit 6 can be used in the unit's make up water or discharged to the ash basin.

The receiving water is the Broad River, class WS-IV waters in the Broad River Basin. Previous permits had this section classified as C. The correct classification is WS-IV and it will be modified in the permit.

REC is subject to EPA effluent guideline limits per 40 CFR 423 - Steam Electric Power Generating Point Source Category. The facility is also subject to the Cooling Water Intake Structures Rules (40

CFR 125) effective October 14, 2014 and to the North Carolina Senate Bill 729 - Coal Ash Management Act.

Outfall Descriptions:

Outfall 002 - Ash basin

The ash basin receives wastewaters collected in the Yard Drainage Basin (effluent from the domestic WWTP, cooling tower blowdown from Unit 5, landfill leachate, floor drains, treated FGD wet scrubber water, limestone unloading and storage area, and stormwater), sluiced ash, cooling tower blowdown from Unit 6, equipment backwashes, boiler blowdown, drainage from recirculating cooling systems, demineralizing resin, cooling water from heat exchangers, rinse water from limestone unloading and storage area, stormwater, low volume waste including flight conveyor quench water overflow), and miscellaneous waste streams. This outfall discharges to the Broad River.

Outfall 002A - Emergency Yard Drainage Overflow

This outfall was closed in 2016. This was an emergency outfall from the yard drainage basin.

Internal Outfall 004 - FGD

If the wastewater from the FGD system is not used in Unit 6 it is treated in the FGD WWTS which consists of equalization tank, reaction tank, flocculating clarifier, and gravity filters. The effluent is discharged to the Yard Drainage Basin. A new treatment system will be installed for the FGD wastewaters. The effluent of the treatment system will be combined with the effluent from proposed outfall 005 before discharging to the Broad River.

Proposed Outfalls:

Outfall 005 - New Wastewater Treatment System

A new treatment system will be installed to treat wastewaters from the holding basin effluent (Outfall 002C - fly ash silo sump, coal, gypsum and limestone piles runoff), Basement Basin effluent (RO reject, stormwater and Unit 6 sanitary system), Unit 6 cooling tower blowdown, landfill leachate, Unit 6 process sump (mechanical drag chain overflow, and low volume waste including flight conveyor quench water overflow) Unit 5 process sump (sanitary system, low volume wastes, mechanical drag chain overflow and cooling tower blowdown), and ash basin dewatering/decanting. The FGD WWTS discharge (Internal Outfall 004) and heat exchanger non-contact cooling water will be combined with the discharge from the WWTS before discharge to the Broad River. The treatment system will be a physical/chemical treatment system with flow equalization, pH neutralization, coagulation and flocculation, and filters. This outfall will discharge to the Broad River.

Outfall 002B - Basement Basin

This will be an emergency outfall from the Basement Basin if a significant rain event overflows the system. An existing structure will be used as a holding cell for process wastewater, treated sanitary wastewater and stormwater that currently go to the P-5 yard basin. The effluent from this holding cell will be pumped to the ash basin during normal operations. When the new WWTS starts operations the holding cell will receive stormwater runoff from Unit 6, RO reject wastewater, Unit 6 treated sanitary wastewater and process and stormwater from Unit 5. Effluent will be pumped to the new WWTS. An auxiliary basin will hold excess water during storm events. The emergency outfall will discharge to the Broad River.

Outfall 002C - Holding Basin

This will be an emergency outfall from a new holding basin if a significant rain event overflows the system. This holding basin will receive stormwater, coal pile runoff, gypsum pile runoff, limestone pile runoff and flows from the holding cell auxiliary basin (stormwater runoff from Unit 6, RO reject wastewater, treated sanitary wastewater and process and stormwater from Unit 5). The effluent from

this holding basin will be pumped to the new WWTS. The emergency overflow will discharge to the Broad River.

Outfalls 104 and 106 Constructed Seeps

Outfalls 104 discharge seepage from the ash basin into the Broad River and Outfall 106 discharges seepage to an UT to the Broad River. A Special Order by Consent ("Special Order"), EMC SOC 17-009, also addresses Outfalls 104 and 106. In this Special Order, these outfalls are called "engineered seeps." Duke Energy shall follow the requirements of the Special Order with regard to these engineered seeps, including but not limited to the requirement that if any of the engineered seeps are not dispositioned (as described in EMC SOC 17-009 § 2(c)(3)) following decanting of the ash basins (as described in EMC SOC 17-009 § 1(a)) at Rogers Energy Complex, Duke Energy shall submit an amendment to its groundwater Corrective Action Plan and/or Closure Plan for the Rogers Energy Complex describing how any of the non-dispositioned engineered seeps will be remediated in a manner sufficient to protect public health, safety, and welfare, the environment, and natural resources (as described in EMC SOC 17-009 § 2(d))

COMPLIANCE REVIEW/PROPOSED ACTIONS

Outfall 002 - Ash Basin - Decanting/Normal Operations

This outfall is subject to the Effluent Limitations Guidelines (ELG) in Table 1.

Table 1. ELG Outfall 002

Pollutant	Daily Maximum (DM)	Monthly Average (MA)	ELG
TSS	50 mg/l	30 mg/l	40 CFR 423(b)(4) (monthly average) 423(b) (9) (daily max)
Oil & Grease	20 mg/l	15 mg/l	40 CFR 423.12 (b) (4)
pH	6 to 9 SU		40 CFR 423.12 (b) (1)

As per 40 CFR 423.13 (h) (1) (i) and (k) (1) (i) bottom ash and fly ash transport water shall not be discharged, compliance with this section shall be as soon as possible beginning on November 1, 2018 for fly ash and November 1, 2020 for bottom ash, but no later than December 31, 2023. Duke has submitted the following proposed schedule for meeting the rule:

Bottom ash: An underneath the boiler mechanical drag system will be installed and will be operational by November 1, 2020. This technology will not generate bottom ash.

Fly ash: dry fly ash is handled dry at this facility.

DMR review:

DMR data were review for the period of January 2011 to April 2016. There were no violations of permit limits.

Table 2. DMR Summary Outfall 002

Parameter	Average	Maximum	Minimum
Flow (MGD)	6.753	29.8	0.40
TSS (mg/l)	6.8	18	< 5
Temperature °F	66.4	88.3	45.5
O & G (mg/l)	< 5	< 5	< 5
Total Nitrogen (mg/l)	0.93	1.5	0.54

Total Phosphorus (mg/l)	0.09	0.19	0.01
pH (S.U.)	7.4	8.6	6.1

RPA Outfall 002:

The need for toxicant limits is based upon a demonstration of reasonable potential to exceed water quality standards, a statistical evaluation that is conducted during every permit renewal utilizing the most recent effluent data for each outfall. The RPA is conducted in accordance with 40 CFR 122.44 (d) (i). The NC RPA procedure utilizes the following: 1) 95% Confidence Level/95% Probability; 2) assumption of zero background; 3) use of ½ detection limit for “less than” values; and 4) streamflows used for dilution consideration based on 15A NCAC 2B.0206. Effective April 6, 2016, NC began implementation of dissolved metals criteria in the RPA process in accordance with guidance titled *NPDES Implementation of Instream Dissolved Metals Standards*, dated June 10, 2016.

The current permit included monitoring for various metals to evaluate the impact from FGD wastewaters. A reasonable potential analysis was performed for arsenic, cadmium, chlorides, chromium, copper, fluoride, lead, molybdenum, nickel, selenium, silver, zinc, antimony, barium, sulfates and thallium. A reasonable potential analysis was conducted on effluent toxicant data collected between January 2011 and May 2016. Pollutants of concern for the decant wastewater included toxicants with positive detections and associated water quality standards/criteria. None of the parameters presented reasonable potential.

TOXICITY TESTING:

Current Requirement: Outfall 002 – Chronic P/F @ 7.14% using Ceriodaphnia

Recommended Requirement: Outfall 002 – Chronic P/F @ 7.7% using Ceriodaphnia

Instream waste concentration is based on the maximum monthly flow during the previous permit cycle.

This facility has passed 21 out of 21 toxicity tests during previous permit cycle.

Mercury Evaluation:

Table 3. Mercury Data Evaluation

	2011	2012	2013	2014	2015
# of Samples	18	12	12	13	12
Annual Average, ng/L	3.1	1.8	1.7	1.5	1.1
Maximum Value, ng/L	11.30	3.50	3.10	3.90	2.30
TBEL, ng/L	47				
WQBEL, ng/L	159.1				

Annual averages are below the TBEL and WQBEL, no limit is required for mercury.

Table 4. Monitoring Requirements/Proposed Changes Outfall 002

Parameter	Monitoring requirements	Changes	Basis
Flow	Monitor	No changes	15A NCAC 2B.0505
TSS	30 mg/l MA 100 mg/l DM	Daily maximum for TSS changed to 50 mg/L	MA - 40 CFR 423.12(b)(4) DM - 40 CFR 423 (b) (9) coal pile runoff is discharged through this outfall
Oil & Grease	15 mg/l MA 20 mg/l DM	No changes	40 CFR 423.12(b)(4)

Total iron	1 mg/l MA 1 mg/l DM	No changes	40 CFR 423.12(b)(5) Only monitored during discharge of metal cleaning wastes
Total cooper	1 mg/l MA 1 mg/l DM	101 µg/l MA 111 µg/l DM	State WQ standards, 15A NCAC 2B .0200. Only monitored during discharge of metal cleaning wastes. Water quality limits more stringent than ELG.
Total chromium	Monitoring	0.2 mg/L MA 0.2 mg/L DM	40 CFR 423.13 (d)(1)
Total zinc	Monitoring	1.0 mg/L MA 1.0 mg/L DM	40 CFR 423.13 (d)(1)
Total nickel, total silver	Monitor weekly	Eliminate monitoring	Previous permit had monitoring to evaluate impact from FGD. There is no ELG for these parameters and no reasonable potential to exceed wqs.
Total cadmium	Monitor weekly	Monitor Monthly	Maximum predicted concentration greater than 50% of the allowable
Total selenium,	Monthly monitoring	Monitor Monthly	Pollutant of concern for ash.
Total arsenic	Monthly monitoring	Monitor Monthly	Pollutant of concern for ash.
Total thallium, total lead	No requirement	Monitor Monthly	Reasonable potential to exceed EPA water quality criteria.
Total mercury	Monitor monthly	No changes	Pollutant of concern for ash.
Total Hardness	No requirement	Quarterly monitoring	Collect data for RPA
BOD5	No requirement	30 mg/L MA 45 mg/L DM	Outfall discharges treated domestic wastes
Fecal Coliform	No requirement	200/100 mL MA 400/100 mL DM	Outfall discharges treated domestic wastes
Total Nitrogen Total Phosphorus	Quarterly Monitoring	No changes	15A NCAC 2B .0500
pH	6 to 9 SU	No changes	State WQ standards, 15A NCAC 2B .0200

Outfall 002 – Ash Basin Dewatering

To meet the requirements of the Coal Ash Management Act of 2014, the facility needs to dewater the ash pond by removing the interstitial water and excavate the ash to deposit it in landfills. The facility's highest discharge rate from the dewatering process will be 1 MGD. The facility submitted data for the standing surface water in the ash pond, interstitial water in the ash, and interstitial ash water that was treated by filters of various sizes. To introduce a margin of safety the highest measured concentration of a parameter was used in the RPA. RPA analysis was done for arsenic, cadmium, chlorides, aluminum, TDS, copper, fluoride, lead, molybdenum, nickel, selenium, zinc, barium, sulfates and thallium. None of the parameters showed reasonable potential.

Internal Outfall 004 - FGD

This outfall is subject to the ELG in Table 5. These are new limitations promulgated November 3, 2015. The permittee has to meet the limitations as soon as possible beginning November 1, 2020 but no later than December 31, 2023.

Table 5. ELG Outfall 004

Pollutant	Daily Maximum	Monthly Average	ELG
pH	6 to 9 SU		40 CFR 423.12 (b) (1)
TSS	100 mg/l	30 mg/l	40 CFR 423.12 (b) (11)
Oil and grease	20 mg/l	15 mg/l	40 CFR 423.12 (b) (11)
Total Arsenic	11 µg/l	8 µg/l	40 CFR 423.13 (g) (1) (i)
Total Mercury	788 ng/l	356 ng/l	40 CFR 423.13 (g) (1) (i)
Total Selenium	23 µg/l	12 µg/l	40 CFR 423.13 (g) (1) (i)
Nitrate/nitrite	17 mg/l	4.4 mg/l	40 CFR 423.13 (g) (1) (i)

Schedule of Compliance for ELG:

The new rule establishes compliance dates for the new limitations. Permittee must meet limits as soon as possible beginning on November 1, 2020 but no later than December 31, 2023. Duke requested a compliance schedule to evaluate, install and test a new treatment system with a proposed compliance date of December 31, 2023. Duke estimates 22 months for technology evaluation, engineering design, and siting. 27 months are estimated for procurement, 16 for construction and 15 for startup and optimization. The permit will require compliance by December 31, 2023.

Table 6. Monitoring Requirements/Proposed Changes Outfall 004

Parameter	Monitoring requirements	Changes	Basis
Flow	Monitor	No changes	15A NCAC 2B.0505
TSS	Monitor	Limits of 30 mg/l (MA) and 100 mg/l (DM)	40 CFR 423.13 (b) (11)
Oil and grease	No Monitor	Limits of 15 mg/l (MA) and 20 mg/l (DM)	40 CFR 423.13 (b) (11)
Total Arsenic	Monitor	Add limits of 11 µg/l daily max and 8 µg/l monthly average	40 CFR 423.13 (g) (1) (i)
Total Cadmium	Monitor	Remove monitoring	Internal outfall, not a parameter of concern.
Total Chromium	Monitor	Remove monitoring	Internal outfall, not a parameter of concern.
Chloride	Monitor	Remove monitoring	Internal outfall, not a parameter of concern.
Total Mercury	Monitor	Add limits of 788 ng/l daily max and 356 ng/l monthly average.	40 CFR 423.13 (g) (1) (i)
Total Nickel	Monitor	Remove monitoring	Internal outfall, not a parameter of concern.
Total Selenium	Monitor	Add limits of 23 µg/l daily max and 12 µg/l monthly average	40 CFR 423.13 (g) (1) (i)
Total Silver	Monitor	Remove monitoring	Internal outfall, not a parameter of concern.
Total Zinc	Monitor	Remove monitoring	Internal outfall, not a parameter of concern.

Nitrate/Nitrite	No monitoring	Add limits of 17 mg/l daily max and 4.4 mg/l monthly average	40 CFR 423.13 (g) (1) (i)
-----------------	---------------	--	---------------------------

Proposed Outfalls:

Outfall 005 - New Wastewater Treatment System (WWTS)

This new outfall will discharge treated process wastewaters from the plant including low volume wastes and cooling tower blowdown. This treatment system is expected to be in place by the end of 2018. Proposed limits and monitoring requirements are described in Table 7.

Table 7. Monitoring Requirements/Limits Proposed Outfall 005

Parameter	Limits/Monitoring requirements	Basis
Flow	Monitor	15A NCAC 2B.0505
TSS	30 mg/L MA 50 mg/L DM	MA - 40 CFR 423.12(b)(4) DM - 40 CFR 423 (b) (9) coal pile runoff is discharged through this outfall
Oil & Grease	15 mg/L MA 20 mg/L DM	40 CFR 423.12(b)(4)
Total Iron	1 mg/L MA 1 mg/L DM	40 CFR 423.13 (b) (5) Parameter only monitored during discharge of metal cleaning wastes
Total Cooper	251 µg/L MA 272 µg/L DM	State WQ standards, 15A NCAC 2B .0200. Parameters only monitored during discharge of metal cleaning wastes.
Total Chromium	0.2 mg/L MA 0.2 mg/L DM	40 CFR 423.13 (d)(1)
Total Zinc	1.0 mg/L MA 1.0 mg/L DM	40 CFR 423.13 (d)(1)
Total Hardness	Quarterly Monitoring	Collect data for RPA
Total Nitrogen Total Phosphorus	Quarterly Monitoring	15A NCAC 2B .0500
pH	6 to 9 SU	State WQ standards, 15A NCAC 2B .0200
BOD5	30 mg/L MA 45 mg/L DM	Outfall discharges treated domestic wastes
Fecal Coliform	200/100 mL MA 400/100 mL DM	Outfall discharges treated domestic wastes
TRC	28 µg/L DM	State WQ standards, 15A NCAC 2B .0200
Whole Effluent Toxicity	Chronic toxicity test at 3.14%	State WQ standards, 15A NCAC 2B .0200
Total Cadmium, Total Mercury, Total Selenium, Total Arsenic, Total Thallium	Monitor Monthly	Only applicable if the decanting and dewatering is discharged through the WWTS

Outfall 002B:

This outfall will discharge from the Basement Basin only during excessive rain events (100-yr 24 hr rain). The holding cell will collect stormwater runoff from Unit 6, RO reject wastewater, treated sanitary wastewater and process and stormwater from Unit 5.

Table 8. Monitoring Requirements/Limits Proposed Outfall 002B

Parameter	Limits/Monitoring requirements	Basis
Flow	Monitor	15A NCAC 2B.0505
TSS	30 mg/L MA 100 mg/L DM	40 CFR 423.12(b)(3)
Oil & Grease	15 mg/L MA 20 mg/L DM	40 CFR 423.12(b)(4)
Total iron	1 mg/L MA 1 mg/L DM	40 CFR 423.13 (b) (5) Parameter only monitored during discharge of metal cleaning wastes
Total cooper	251 µg/L MA 272 µg/L DM	State WQ standards, 15A NCAC 2B .0200. Parameters only monitored during discharge of metal cleaning wastes.
pH	6 to 9 SU	State WQ standards, 15A NCAC 2B .0200
BOD5	30 mg/L MA 45 mg/L DM	Outfall discharges treated domestic wastes
Fecal Coliform	200/100 mL MA 400/100 mL DM	Outfall discharges treated domestic wastes
Whole Effluent Toxicity	Acute episodic test	State WQ standards, 15A NCAC 2B .0200

Outfall 002C:

This outfall will discharge from the proposed Holding Basin only during excessive rain events (100-yr 24 hr rain). The holding cell will collect stormwater, coal pile runoff, gypsum pile runoff and limestone storage area runoff and flows from the Basement Basin auxiliary basin (stormwater runoff from Unit 6, RO reject wastewater, treated sanitary wastewater and process and stormwater from Unit 5).

Table 9. Monitoring Requirements/Limits Proposed Outfall 002C

Parameter	Limits/Monitoring requirements	Basis
Flow	Monitor	15A NCAC 2B.0505
TSS	30 mg/L MA 50 mg/L DM	MA - 40 CFR 423.12(b)(4) DM - 40 CFR 423 (b) (9) coal pile runoff is discharged through this outfall
Oil & Grease	15 mg/L MA 20 mg/L DM	40 CFR 423.12(b)(4)
Total Iron	1 mg/L MA 1 mg/L DM	40 CFR 423.13 (b) (5) Parameter only monitored during discharge of metal cleaning wastes
Total Cooper	102 µg/L MA 111 µg/L DM	State WQ standards, 15A NCAC 2B .0200. Parameters only monitored during discharge of metal cleaning wastes.
pH	6 to 9 SU	State WQ standards, 15A NCAC 2B .0200
BOD5	30 mg/L MA	Outfall discharges treated domestic wastes

	45 mg/L DM	
Fecal Coliform	200/100 mL MA 400/100 mL DM	Outfall discharges treated domestic wastes
Whole Effluent Toxicity	Acute episodic test	State WQ standards, 15A NCAC 2B .0200

Outfalls 104 and 106 – constructed seeps outfalls:

Two constructed seeps, Outfalls 104 and 106, discharge from the ash basin into the Broad River (104) and an UT to the Broad River (106). A Special Order by Consent (“Special Order”), EMC SOC 17-009, also addresses Outfalls 104 and 106. In this Special Order, these outfalls are called “engineered seeps.” Duke Energy shall follow the requirements of the Special Order with regard to these engineered seeps, including but not limited to the requirement that if any of the engineered seeps are not dispositioned (as described in EMC SOC 17-009 § 2(c)(3)) following decanting of the ash basins (as described in EMC SOC 17-009 § 1(a)) at Rogers Energy Complex, Duke Energy shall submit an amendment to its groundwater Corrective Action Plan and/or Closure Plan for the Rogers Energy Complex Station describing how any of the non-dispositioned engineered seeps will be remediated in a manner sufficient to protect public health, safety, and welfare, the environment, and natural resources (as described in EMC SOC 17-009 § 2(d))

Table 10. Toe drains Coordinates and Assigned Outfall Numbers

ID	Latitude	Longitude	Outfall number
S-4	35° 13' 3.5"	81° 45' 9.3"	104
S-6	35° 13' 6.3	81° 44' 53.7"	106

RPA Seeps

A RPA was conducted for the seeps. RPA was conducted for total arsenic, cadmium, chlorides, total chromium, total copper, total lead, total boron, total mercury, total molybdenum, total nickel, selenium, total zinc, antimony, sulfate and total thallium. Maximum flow recorded for toe drain 104 was 0.032 mgd. The maximum flow recorded for toe drain 106 was 0.164 mgd. The flows were multiplied by a factor of safety of 10 for the RPA. Based on the RPA Outfall 106 include limits for total aluminum and total dissolved solids.

These outfalls will have monitoring requirements for fluoride, total mercury, total barium, total iron, total manganese, total zinc, total arsenic, total cadmium, total chromium, total copper, total lead, total nickel, and total selenium, chlorides, nitrate/nitrite, total dissolved solids, hardness, turbidity, conductivity and limits as described in Table 11.

Table 11. Monitoring Requirements Proposed Toe Drain Outfalls Monitoring:

Parameter	Limits/Monitoring requirements	Basis
Flow	Monitor	15A NCAC 2B.0505
pH	6.0 to 9.0 S.U.	State WQ standards, 15A NCAC 2B .0200
TSS	30 mg/l MA 100 mg/l DM	40 CFR 423.12(b)(4)
Oil & Grease	15 mg/l MA 20 mg/l DM	40 CFR 423.12(b)(4)

316(b) REQUIREMENTS

The permittee shall comply with the Cooling Water Intake Structure Rule per 40 CFR 125.95. The Division approved the facility request for an alternative schedule in accordance with 40 CFR 125.95(a)(2). The permittee shall submit all the materials required by the Rule with the next renewal application.

The rule requires the Director to establish interim BTA requirements in the permit on a site-specific basis based on the Director's best professional judgment in accordance with §125.90(b) and 40 CFR 401.14. The existing closed-cycle system at REC is one of the pre-approved compliance alternatives for impingement in accordance with §125.94(c)(1). EPA also considered it as a pre-approved BTA for entrainment, but excluded it from the rule due to the cost concerns. Based on this information the DEQ has determined that the existing closed-cycle cooling system meets the requirements for an interim BTA.

316 (a) CWA

The thermal variance and temperature mixing zone once included in the permit for outfall 002 is no longer applicable. The special conditions referring to the variance and mixing zone were eliminated.

FISH TISSUE STUDIES

The facility performed fish tissue analysis for arsenic, selenium and mercury as required by the permit. The Division reviewed the information and concluded that all the fish tissue levels reported are below the Department of Health screening values.

INSTREAM MONITORING

The current permit did not require instream monitoring. The proposed permit will require monthly upstream and downstream monitoring for total arsenic, total selenium, total mercury, total chromium, dissolved lead, dissolved cadmium, dissolved copper, dissolved zinc, total bromide, total hardness (as CaCO₃), temperature, turbidity, and total dissolved solids (TDS).

SUMMARY OF CHANGES:

1. Eliminated outfall 002A since it has been shut down.
2. Added effluent pages for outfalls 002B, 002C and 005.
3. A separate effluent page for the dewatering of the ash ponds (Outfall 002) was added to the permit. Please see Special Condition A. (2)
4. Special Condition A. (24) Section 316(b) of CWA was updated to reflect the new regulations.
5. Special Condition A. (8) Section 316(a) Thermal Variance in the old permit was eliminated since the facility no longer requires a thermal variance.
6. Special Condition A. (26) Ash Pond Closure was added to the permit to facilitate the decommissioning of the ash ponds.
7. Special Condition A. (13) Instream Monitoring was added to the permit to monitor the impact of the discharges on the receiving stream.
8. Special Condition A. (25) Applicable State Law was added to the permit to meet the requirements of Senate Bill 729 (Coal Ash Management Act).
9. Special Condition A. (23) Domestic Wastewater Treatment Plant was added to the permit to assure compliance with the 40 CFR 133.102.
10. Special Condition A. (28) Electronic Reporting was added to the permit describing requirements for electronic reporting of DMRs. Starting December 21, 2016, federal regulations require electronic submittal of all discharge monitoring reports (DMRs) and specify that, if a state does not establish a

system to receive such submittals, then permittees must submit DMRs electronically to the Environmental Protection Agency (EPA).

11. Special Condition A. (29) Notification of Start-up – Outfall 005 was added to the permit.

Changes to the September 21, 2016 draft permit:

1. Steam Electric ELG - In September 2017, the EPA delayed the implementation date for effluent guidelines for the Steam Electric Power Generating Point Source Category to allow time to revise some of the BAT limitations for FGD wastewaters and bottom ash transport water. The earliest compliance date for the FGD wastewater in §123.13(g)(1)(i) and for the bottom ash transport water in §123.13(k)(1)(i) were delayed from November 1, 2018 to November 1, 2020. A reopener was added to outfall 004 specifying that the Division may reopen the permit to implement limits as revised in the ELGs.
2. Seeps Discharges - Effluent Limitations and Monitoring Requirements for Outfalls 102, 103, 110, 111, 113, 114, 115, 116, 117, 121, 127, 128, 129, 130, 131, and 132 were eliminated from the draft permit transmitted on September 21, 2016. The seeps will be covered under a Special Order by Consent. Constructed seeps 104 and 106 will remain in the permit.
3. Added monitoring for lead and TDS for dewatering and decanting in response to EPA comments.
4. The footnote under outfall 002 requiring physical/chemical treatment was modified to allow the installation of treatment if it is necessary.
5. A statement was added to condition A. (6) Effluent Limitations and Monitoring Requirements for outfall 005 to require submittal of Form 2C Parts V and VI within 180 days of commencement of operations.
6. Special conditions for instream sampling and fish tissue monitoring were modified to clarify requirements (See A. (13) and A. (14)).
7. The mixing zone for outfall 002 was removed from the permit. Recent data shows that the temperature standard is not exceeded at outfall 002. The Division does not consider that the mixing zone in the current permit is justified since the conditions are different from when the mixing zone was established.
8. Added limits for 126 pollutants for outfall 005 since this outfall will discharge the cooling tower blowdown.
9. The groundwater monitoring well construction and sampling condition was eliminated from the permit.
10. Special condition A. (30) Compliance Boundary was added to the permit.
11. The groundwater compliance boundary map was added to the permit.

Outfall 005 Temperature Mixing Zone:

Duke requested a mixing zone for temperature for Outfall 005. Outfall 005 is a proposed outfall that will discharge among other flows, the cooling tower blowdown. A Cormix analysis was developed to evaluate a mixing zone. Both summer and winter conditions were considered in the analysis. The model was run under conservative assumption such as the use of maximum design flow rate of 6 MGD for both summer and winter and a sensitivity analysis resulted in the use of the most conservative river depth.

Summer Analysis - The summer maximum effluent discharge temperature was estimated as 100°F. Maximum ambient temperature was recorded as 86.3°F.

Winter Analysis - The winter maximum effluent discharge temperature was estimated as 93.7°F. The minimum ambient temperature was 35.5°F.

The temperature water quality standard has two components: not to exceed 2.8 °C (5.04 °F) above natural background and not to exceed 32 °C (89.6 °F). The critical condition modeled for the summer was the maximum temperature. The critical condition modeled for the winter was the temperature exceedance over background conditions.

The model includes the following assumptions/inputs:

Outfall 005	
Flow	6 MGD
Max summer temperature	100 °F
Max winter temperature	93.7 °F
Outfall structure	36" pipe followed by 10 feet wide rip rap channel

Ambient Conditions - Broad River	
Summer 7Q10	287 cfs
Winter 7Q10	440 cfs
Summer max temperature	86.3 °F
Winter min temperature	35.5 °F
Summer ΔT	3.3 °F
Winter ΔT	58.2 °F
River width	200 ft (60.9 m)
River depth	2.5 ft

Model results:

	Mixing Zone		Dilution
	Distance downstream (x)	Plume width (y)	
Summer	130 m (426.8 ft)	37 m (121.4 ft)	4.1
Winter	145 m (476 ft)	24.5 m (80.4 ft)	10.8

A mixing zone will be implemented comprising a distance of 145 meters downstream of the outfall and 37 meters wide. The mixing zone length is maximized for the winter condition and the width is maximized for the summer condition. For both summer and winter conditions the effluent is buoyant providing for passage of fish through the mixing zone. The mixing zone shall not result in acute toxicity, prevent free passage of aquatic organisms, result in offensive conditions, produce undesirable aquatic life or result in a dominance of nuisance species outside of the assigned mixing zone; or endanger the public health or welfare.

Temperature monitoring will be implemented upstream and downstream at the edge of the mixing zone to evaluate compliance with the temperature criteria outside of the mixing zone and to verify the model predictions. If model predictions are not validated the permit will be reopened to implement more stringent requirements.

The permit includes requirements to submit a mixing zone verification study and an assessment to verify that the mixing zone does not prevent the passage of fish around the mixing zone. The assessment would include a biological component but is not intended to be a full BIP demonstration due to the greatly reduced area of the historic thermal mixing zone. The study is intended to confirm the projected impacts of the discharge that were presented in the CORMIX model.

PROPOSED SCHEDULE FOR PERMIT ISSUANCE

Draft Permit to Public Notice: May 2, 2018
Permit Scheduled to Issue: June 16, 2018

NPDES DIVISION CONTACT

If you have questions regarding any of the above information or on the attached permit, please contact Teresa Rodriguez at (919) 807-6387.

NAME: TERESA RODRIGUEZ DATE: 5/2/2018

Modifications included in the final permit:

1. The discharge from Outfall 106 was reclassified as discharging to a UT to the Broad River. The RPA was revised which resulted in the implementation of limits for TDS and aluminum.
2. Sampling frequency for metals during dewatering was modified to weekly. Total bromide monitoring was added to the monitoring requirements.
3. Sampling frequency for total arsenic, total mercury and total selenium during decanting was modified to weekly. Total bromide monitoring was added to the monitoring requirements.
4. A footnote was added for the decanting and dewatering effluent pages that requires the facility to discontinue the discharge if pollutant levels reach 85% of the allowable concentrations and to report the event to the Division.
5. Footnote 8 for outfall 005 was modified to clarify that monthly monitoring is required during normal operations and during decanting. In addition, the fecal coliform sample type was changed to grab.
6. The downstream sample location for the instream monitoring required by special condition A.(13) was modified to approximately 250 meters from the discharge.
7. Special condition A.(24) was modified to require the submittal of materials required by the 316(b) rule by 3.5 years from the issuance of the permit and to add language stating that the Division determined that operating and maintaining the existing Closed-cycle recirculating system meets the requirements for an interim BTA.
8. The Division evaluated the schedule of compliance for the FGD limits and determined that Duke did not provide sufficient justification to delay the completion of the project until December 31, 2023. The compliance date was modified to December 31, 2021.

Qw (MGD) = 1.00
 1Q10S (cfs) = 232.54
 7Q10S (cfs) = 287.00
 7Q10W (cfs) = 440.00
 30Q2 (cfs) = NO 30Q2 DATA
 Avg. Stream Flow, QA (cfs) = 1460.00
 Receiving Stream: NO HUC NUMBER

WWT/WWTP Class:
 IW% @ 1Q10S = 0.662138494
 IW% @ 7Q10S = 0.5371688602
 IW% @ 7Q10W = 0.351036123
 IW% @ 30Q2 = N/A
 IW% @ QA = 0.106051794
 Stream Class: WS-IV

COMBINED HARDNESS (mg/L)
 Acute = 25 mg/L
 Chronic = 25 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
 Effluent Hard: 0 value > 100 mg/L
 Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA		P	UNITS	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION	
		Chronic Applied Standard	Acute			n	# Det.	Max Pred Cw		Allowable Cw
Arsenic	C	150	FW(7Q10s) 340		ug/L	1	1	3,366.6 Default C.V.	Acute (FW): 51,348.8 Chronic (FW): 27,924.2 No value > Allowable Cw Chronic (HH): 9,429.4 No value > Allowable Cw	No RP
Arsenic	C	10	HH/WS(Qavg)		ug/L	Note: n ≤ 9 Limited data set				
Beryllium	NC	6.5	FW(7Q10s) 65		ug/L	0	0	N/A	Acute: 9,816.68 Chronic: 1,210.05	
Cadmium	NC	0.5899	FW(7Q10s) 3.2396		ug/L	1	0	NO DETECTS	Acute: 489.265 Chronic: 109.813 Max MDL = 1	No RP
Chlorides	NC	250	WS(7Q10s)		mg/L	29	28	109.4	Acute: NO WQS Chronic: 46,540.3 No value > Allowable Cw	No RP
Aluminum	NC	6.5	WS(7Q10s)		mg/L	1	1	403.0 Default C.V.	Acute: NO WQS Chronic: 1,210.0 No value > Allowable Cw	No RP
Total Dissolved Solids	NC	500	WS(7Q10s)		mg/L	1	1	2,728.0 Default C.V.	Acute: NO WQS Chronic: 93,080.6 No value > Allowable Cw	No RP
Chromium III	NC	117.7325	FW(7Q10s) 905.0818		µg/L	0	0	N/A	Acute: 136,690.7 Chronic: 21,917.2	
Chromium VI	NC	11	FW(7Q10s) 16		µg/L	0	0	N/A	Acute: 2,416.4 Chronic: 2,047.8	
Chromium, Total	NC				µg/L	1	1	FALSE 372.0 Default C.V.	Max reported value = 60	No RP
Copper	NC	7.8806	FW(7Q10s) 10.4720		ug/L	8	8	326.80 Default C.V.	Acute: 1,581.54 Chronic: 1,467.07	No RP

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	Rogers Energy Complex
WWTP/WTP Class	
NPDES Permit	NC0005088
Outfall	002 - Dewatering
Flow, Qw (MGD)	1.000
Receiving Stream	Broad River
HUC Number	
Stream Class	WS-IV
<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
<input type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	287.00
7Q10w (cfs)	440.00
30Q2 (cfs)	
QA (cfs)	1460.00
1Q10s (cfs)	232.54
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	Data collected: 6/17/15, 6/23/16, 9/9/15, 4/13/16, 6/20/16, 12/19/16, 2/13/17, 5/16/17
<input type="checkbox"/> CHECK TO APPLY MODEL	

REQUIRED DATA ENTRY

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Arsenic	Aquatic Life	C	150	FW	340		ug/L
Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Chlorides	Water Supply	NC	250	WS			mg/L
Aluminum	Water Supply	NC	6.5	WS			mg/L
Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Chromium VI	Aquatic Life	NC	11	FW	16		ug/L
Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Cyanide	Aquatic Life	NC	5	FW	22		ug/L
Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Molybdenum	Water Supply	NC	160	WS			ug/L
Nickel	Aquatic Life	NC	37.2313	FW	335.2087		ug/L
Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Selenium	Aquatic Life	NC	5	FW	56		ug/L
Boron	Aquatic Life	NC	7	FW			mg/L
Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Antimony	Water Supply	NC	5.6	WS			ug/L
Barium	Water Supply	NC	1	WS			mg/L
Sulfates	Water Supply	NC	250	WS			ug/L

REASONABLE POTENTIAL ANALYSIS

H1					H2				
Effluent Hardness					Upstream Hardness				
Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL Values" then "COPY" : Maximum data points = 58	Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL Values" then "COPY" : Maximum data points = 58
1		25	Std Dev.	0.0000	1		25	Std Dev.	0.0000
2			Mean	25.0000	2			Mean	25.0000
3			C.V. (default)	0.6000	3			C.V. (default)	0.6000
4			n	1	4			n	1
5			10th Per value	25.00 mg/L	5			10th Per value	25.00 mg/L
6			Average Value	25.00 mg/L	6			Average Value	25.00 mg/L
7			Max. Value	25.00 mg/L	7			Max. Value	25.00 mg/L
8					8				
9					9				
10					10				
11					11				
12					12				
13					13				
14					14				
15					15				
16					16				
17					17				
18					18				
19					19				
20					20				
21					21				
22					22				
23					23				
24					24				
25					25				
26					26				
27					27				
28					28				
29					29				
30					30				
31					31				
32					32				
33					33				
34					34				
35					35				
36					36				
37					37				
38					38				
39					39				
40					40				
41					41				
42					42				
43					43				
44					44				
45					45				
46					46				
47					47				
48					48				
49					49				
50					50				
51					51				
52					52				
53					53				
54					54				
55					55				
56					56				
57					57				
58					58				

REASONABLE POTENTIAL ANALYSIS

Par01 & Par02				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58	
Arsenic					
Date	Data	BDL=1/2DL	Results		
1		543	543	Std Dev.	0.0000
2				Mean	543.0000
3				C.V. (default)	0.8000
4				n	1
5					
6				Mult Factor =	6.20
7				Max. Value	543.0 ug/L
8				Max. Pred Cw	3366.6 ug/L
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					

REASONABLE POTENTIAL ANALYSIS

Par04				Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 58	Par05				Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 58
Cadmium					Chlorides				
Date	Data	BDL=1/2DL	Results		Date	Data	BDL=1/2DL	Results	
1	<	1	0.5	0.0000	1		56	56	18.7058
2				0.5000	2		28.6	28.6	45.7
3				0.6000	3	<	1	0.5	0.4098
4				1	4		27.6	27.6	29
5					5		40	40	
6				6.20	6		51.9	51.9	1.2
7				0.500 ug/L	7		57.5	57.5	95.1
8				0 DETECTS ug/L	8		55.8	55.8	109.4
9					9		47.6	47.6	
10					10		29.9	29.9	
11					11		33.8	33.8	
12					12		36.6	36.6	
13					13		33.9	33.9	
14					14		32.5	32.5	
15					15		30.8	30.8	
16					16		31.1	31.1	
17					17		52.7	52.7	
18					18		67.8	67.8	
19					19		47.1	47.1	
20					20		54.3	54.3	
21					21		58.3	58.3	
22					22		47.7	47.7	
23					23		52.7	52.7	
24					24				
25					25				
26					26		41.1	41.1	
27					27		70	70	
28					28		95.1	95.1	
29					29		80.2	80.2	
30					30		34	34	
31					31		28.8	28.8	
32					32				
33					33				
34					34				
35					35				
36					36				
37					37				
38					38				
39					39				
40					40				
41					41				
42					42				
43					43				
44					44				
45					45				
46					46				
47					47				
48					48				
49					49				
50					50				
51					51				
52					52				
53					53				
54					54				
55					55				
56					56				
57					57				
58					58				

REASONABLE POTENTIAL ANALYSIS

	Par06						Par07					
	Aluminum						Total Dissolved Solids					
CIAL- IPY" ints =	Date	Data	BDL=1/2DL	Results	Std Dev.	Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Date	Data	BDL=1/2DL	Results	Std Dev.	Use "PASTE SF Values" then "C Maximum data = 58
	1		65	65			1		440	440		
	2				0.0000		2				0.0000	
	3				65.0000		3				440.0000	
	4				0.6000		4				0.6000	
	5						5					
	6						6					
mg/L	7				6.20		7				6.20	
mg/L	8				65.0 mg/L		8				440.0	
	9				403.0 mg/L		9				2728.0	
	10						10					
	11						11					
	12						12					
	13						13					
	14						14					
	15						15					
	16						16					
	17						17					
	18						18					
	19						19					
	20						20					
	21						21					
	22						22					
	23						23					
	24						24					
	25						25					
	26						26					
	27						27					
	28						28					
	29						29					
	30						30					
	31						31					
	32						32					
	33						33					
	34						34					
	35						35					
	36						36					
	37						37					
	38						38					
	39						39					
	40						40					
	41						41					
	42						42					
	43						43					
	44						44					
	45						45					
	46						46					
	47						47					
	48						48					
	49						49					
	50						50					
	51						51					
	52						52					
	53						53					
	54						54					
	55						55					
	56						56					
	57						57					
	58						58					

REASONABLE POTENTIAL ANALYSIS

SPECIAL COPY points	Par10					Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58	Pa11					Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58
	Chromium, Total						Copper					
	Date	Data	BDL=1/2DL	Results			Date	Data	BDL=1/2DL	Results		
			60	60	Std Dev.	0.0000			172	172	Std Dev.	60.2889
mg/L					Mean	60.0000			1	1	Mean	22.6225
mg/L					C.V. (default)	0.6000					C.V. (default)	0.6000
					n	1			1.3	1.3	n	8
					Mult Factor =	6.20			1.4	1.4	Mult Factor =	1.90
					Max. Value	60.0 µg/L					Max. Value	172.00
					Max. Pred Cw	372.0 µg/L			0.55	0.55	Max. Pred Cw	326.80
									1.1	1.1		
									0.83	0.83		
									4.4	4.4		
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
32												
33												
34												
35												
36												
37												
38												
39												
40												
41												
42												
43												
44												
45												
46												
47												
48												
49												
50												
51												
52												
53												
54												
55												
56												
57												
58												

REASONABLE POTENTIAL ANALYSIS

SPECIAL COPY points	Par13					Par14				
	Fluoride					Lead				
	Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Date	BDL=1/2DL	Results	Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	
	1		0.38	0.38		1				
	2				Std Dev. 0.0000	2		80	80	
	3				Mean 0.3800	3		0.46	0.46	
	4				C.V. (default) 0.6000	4		0.2	0.2	
	5				n 1	5		0.3	0.3	
	6					6		0.37	0.37	
	7				Mult Factor = 6.20	7		0.14	0.14	
ug/L	8				Max. Value 0.4 ug/L	8		0.13	0.13	
ug/L	9				Max. Pred Cw 2.4 ug/L	9		0.23	0.23	
	10					10		0.55	0.55	
	11					11		0.27	0.27	
	12					12		1.9	1.9	
	13					13		0.23	0.23	
	14					14	<	1	0.5	
	15					15	<	1	0.5	
	16					16		0.12	0.12	
	17					17	<	0.18	0.18	
	18					18	<	0.1	0.05	
	19					19		0.41	0.41	
	20					20				
	21					21		0.1	0.1	
	22					22	<	1	0.5	
	23					23	<	1	0.5	
	24					24		0.16	0.16	
	25					25	<	0.11	0.11	
	26					26	<	0.1	0.05	
	27					27				
	28					28				
	29					29				
	30					30				
	31					31				
	32					32				
	33					33				
	34					34				
	35					35				
	36					36				
	37					37				
	38					38				
	39					39				
	40					40				
	41					41				
	42					42				
	43					43				
	44					44				
	45					45				
	46					46				
	47					47				
	48					48				
	49					49				
	50					50				
	51					51				
	52					52				
	53					53				
	54					54				
	55					55				
	56					56				
	57					57				
	58					58				

REASONABLE POTENTIAL ANALYSIS

SPECIAL COPY points	Par15					Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Par16					Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58
	Mercury						Molybdenum					
	Date	Data	BDL=1/2DL	Results		Date	Data	BDL=1/2DL	Results			
	1		39	39	Std Dev.	1		2750	2750	Std Dev.		
	2				Mean	2		53.9	53.9	Mean		
	3				C.V. (default)	3		98.8	98.8	C.V.		
	4				n	4		25.1	25.1	n		
	5					5		63.4	63.4			
	6				Mult Factor =	6		69.7	69.7	Mult Factor =		
ug/L	7				Max. Value	7		79.1	79.1	Max. Value		
ug/L	8				Max. Pred Cw	8		95.2	95.2	Max. Pred Cw		
	9					9		39.7	39.7			
	10					10		166	166			
	11					11		180	180			
	12					12		161	161			
	13					13		160	160			
	14					14		167	167			
	15					15		181	181			
	16					16		168	168			
	17					17		948	948			
	18					18		1250	1250			
	19					19		745	745			
	20					20		936	936			
	21					21		813	813			
	22					22		902	902			
	23					23		773	773			
	24					24		876	876			
	25					25						
	26					26		1020	1020			
	27					27		172	172			
	28					28		164	164			
	29					29		389	389			
	30					30		269	269			
	31					31		366	366			
	32					32						
	33					33						
	34					34						
	35					35						
	36					36						
	37					37						
	38					38						
	39					39						
	40					40						
	41					41						
	42					42						
	43					43						
	44					44						
	45					45						
	46					46						
	47					47						
	48					48						
	49					49						
	50					50						
	51					51						
	52					52						
	53					53						
	54					54						
	55					55						
	56					56						
	57					57						
	58					58						

REASONABLE POTENTIAL ANALYSIS

SPECIAL COPY points		Par17 & Par18				Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Par19			
		Nickel				Selenium				
		Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	
ug/L ug/L	1		72	72	Std Dev.	1		21.5	21.5	
	2		2.3	2.3	Mean	2				
	3		1.9	1.9	C.V.	3				
	4		6.2	6.2	n	4		6.6	6.6	
	5		6.8	6.8		5		4.4	4.4	
	6		3	3	Mult Factor =	6		2.7	2.7	
	7		1.7	1.7	Max. Value	7		2.3	2.3	
	8		10.3	10.3	Max. Pred Cw	8		1.4	1.4	
	9		3	3		9		1.6	1.6	
	10					10		1.5	1.5	
	11		1.2	1.2		11		0.76	0.76	
	12		0.74	0.74		12				
	13		8.2	8.2		13		0.56	0.56	
	14		0.96	0.96		14		10	10	
	15					15		11.6	11.6	
	16		1.3	1.3		16		0.56	0.56	
	17		3.5	3.5		17		0.69	0.69	
	18		1.9	1.9		18		0.76	0.76	
	19		5	2.5		19				
	20		5	2.5		20				
	21		1.8	1.8		21				
	22		2.8	2.8		22				
	23		2	2		23				
	24		1.4	1.4		24				
	25					25				
	26		0.83	0.83		26				
	27		5	2.5		27				
	28		5	2.5		28				
	29		0.97	0.97		29				
	30		1.1	1.1		30				
	31		1.1	1.1		31				
	32					32				
	33					33				
	34					34				
	35					35				
	36					36				
	37					37				
	38					38				
	39					39				
	40					40				
	41					41				
	42					42				
	43					43				
	44					44				
	45					45				
	46					46				
	47					47				
	48					48				
	49					49				
	50					50				
	51					51				
	52					52				
	53					53				
	54					54				
	55					55				
	56					56				
	57					57				
	58					58				

REASONABLE POTENTIAL ANALYSIS

Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58	Par20				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58	Par21			
	Boron					Zinc			
	Date	Data	BDL=1/2DL	Results		Date	Data	BDL=1/2DL	Results
5.8718	1			Std Dev.	2.6957	1		0.158	Std Dev.
4.4620	2			Mean	3.3556	2		0.158	Mean
1.3160	3			C.V.	0.8033	3			C.V. (default)
15	4	<	0.05	n	28	4			n
	5		3.55			5			
2.09	6		3.18	Mult Factor =	1.30	6			Mult Factor =
21.5 ug/L	7		2.99	Max. Value	11.300 mg/l	7			Max. Value
44.9 ug/L	8		2.46	Max. Pred Cw	14.690 mg/l	8			Max. Pred Cw
	9		2.46			9			
	10		3.07			10			
	11		0.92			11			
	12		0.97			12			
	13		0.895			13			
	14		0.948			14			
	15		0.984			15			
	16		1.01			16			
	17		0.975			17			
	18		3.3			18			
	19		4.6			19			
	20		2.94			20			
	21		3.8			21			
	22		3.85			22			
	23		4.05			23			
	24		3.44			24			
	25		8			25			
	26					26			
	27		11.3			27			
	28		1.96			28			
	29		2.14			29			
	30		3.35			30			
	31		7.56			31			
	32		9.23			32			
	33					33			
	34					34			
	35					35			
	36					36			
	37					37			
	38					38			
	39					39			
	40					40			
	41					41			
	42					42			
	43					43			
	44					44			
	45					45			
	46					46			
	47					47			
	48					48			
	49					49			
	50					50			
	51					51			
	52					52			
	53					53			
	54					54			
	55					55			
	56					56			
	57					57			
	58					58			

REASONABLE POTENTIAL ANALYSIS

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Par22					Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Par23			
	Antimony						Barium			
	Date	Data	BDL=1/2DL	Results		Date	Data	BDL=1/2DL		
0.0000	1		4.9	4.9	Std Dev.	1		1.29	1.29	
0.1580	2	<	0.39	0.195	Mean	2		0.07	0.07	
0.8000	3		0.63	0.63	C.V.	3	<	0.005	0.0025	
1	4	<	5	2.5	n	4		0.0767	0.0767	
	5	<	5	2.5		5		0.0708	0.0708	
6.20	6		0.52	0.52	Mult Factor =	6		0.0569	0.0569	
0.2 ug/L	7		0.55	0.55	Max. Value	7		0.0649	0.0649	
1.0 ug/L	8		0.68	0.68	Max. Pred Cw	8		0.0777	0.0777	
	9	<	0.39	0.195		9		0.0797	0.0797	
	10		3.3	3.3		10		0.17	0.17	
	11		4.2	4.2		11		0.19	0.19	
	12		3.1	3.1		12		0.199	0.199	
	13		3.4	3.4		13		0.193	0.193	
	14		3.6	3.6		14		0.24	0.24	
	15		4.4	4.4		15		0.181	0.181	
	16		3.5	3.5		16		0.179	0.179	
	17		1	1		17		0.21	0.21	
	18		0.64	0.64		18		0.26	0.26	
	19	^	5	2.5		19		0.196	0.196	
	20	^	5	2.5		20		0.234	0.234	
	21	^	0.83	0.83		21		0.273	0.273	
	22		1	1		22		0.258	0.258	
	23		0.81	0.81		23		0.23	0.23	
	24		0.72	0.72		24		0.15	0.15	
	25					25				
	26		0.61	0.61		26		0.24	0.24	
	27	^	2.6	1.3		27		0.142	0.142	
	28	^	3.8	1.9		28		0.303	0.303	
	29		1.7	1.7		29		0.277	0.277	
	30		0.58	0.58		30		0.25	0.25	
	31		0.8	0.8		31		0.23	0.23	
	32					32				
	33					33				
	34					34				
	35					35				
	36					36				
	37					37				
	38					38				
	39					39				
	40					40				
	41					41				
	42					42				
	43					43				
	44					44				
	45					45				
	46					46				
	47					47				
	48					48				
	49					49				
	50					50				
	51					51				
	52					52				
	53					53				
	54					54				
	55					55				
	56					56				
	57					57				
	58					58				

REASONABLE POTENTIAL ANALYSIS

		Par24						Par25			
		Sulfates						Thallium			
		Date	Data	BDL=1/2DL	Results		Date	Data	BDL=1/2DL		
Results											
Std Dev.	0.2185	1		712	712	235.5910	1		7.08	7.08	
Mean	0.2131	2	<	1	0.5	201.0724	2		0.56	0.56	
C.V.	1.0250	3		1060	1060	1.1717	3		0.6	0.6	
n	30	4		487	487		4		0.77	0.77	
		5		532	532		5		0.75	0.75	
Mult Factor =	1.33	6		234	234	1.39	6		0.69	0.69	
Max. Value	1.290000 mg/L	7		231	231	##### µg/L	7		0.5	0.5	
Max. Pred Cw	1.715700 mg/L	8		439	439	##### µg/L	8		0.47	0.47	
		9		76.3	76.3		9		0.76	0.76	
		10		79.8	79.8		10		0.24	0.24	
		11		76	76		11		0.12	0.12	
		12		72	72		12		0.093	0.093	
		13		67.8	67.8		13		0.11	0.11	
		14		70.6	70.6		14		0.11	0.11	
		15		68.3	68.3		15		0.1	0.1	
		16		105	105		16		0.085	0.085	
		17		118	118		17		0.18	0.18	
		18		111	111		18		0.11	0.11	
		19		98.2	98.2		19	<	1	0.5	
		20		74.6	74.6		20	<	1	0.5	
		21		72.2	72.2		21		0.095	0.095	
		22		70.9	70.9		22		0.13	0.13	
		23		172	172		23		0.069	0.069	
		24					24		0.04	0.04	
		25		307	307		25				
		26		95.1	95.1		26		0.023	0.023	
		27		99.3	99.3		27	<	1	0.5	
		28		127	127		28		0.54	0.54	
		29		107	107		29		0.25	0.25	
		30	<	135	67.5		30		0.063	0.063	
		31					31				
		32					32				
		33					33				
		34					34				
		35					35				
		36					36				
		37					37				
		38					38				
		39					39				
		40					40				
		41					41				
		42					42				
		43					43				
		44					44				
		45					45				
		46					46				
		47					47				
		48					48				
		49					49				
		50					50				
		51					51				
		52					52				
		53					53				
		54					54				
		55					55				
		56					56				
		57					57				
		58					58				

REASONABLE POTENTIAL ANALYSIS

	Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58
Results	
Std Dev.	1.2806
Mean	0.5530
C.V.	2.3156
n	29
Mult Factor =	1.62
Max. Value	7.080000 µg/L
Max. Pred Cw	11.469600 µg/L

Rogers Energy Complex
NC0005088

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Outfall 002 (decanting/normal operations)
Qw = 15.15 MGD

Ow (MGD) = 15.15
1Q10S (cfs) = 232.54
7Q10S (cfs) = 287.00
7Q10W (cfs) = 440.00
30Q2 (cfs) = NO 30Q2 DATA
Avg. Stream Flow, QA (cfs) = 1460.00
Receiving Stream: NO HUC NUMBER

WWT/PW/TP Class:
IWC% @ 1Q10S = 9.172045426
IWC% @ 7Q10S = 7.563228201
IWC% @ 7Q10W = 5.066534335
IWC% @ 30Q2 = N/A
IWC% @ QA = 1.582930705
Stream Class: WS-IV

COMBINED HARDNESS (mg/L)
Acute = 25 mg/L
Chronic = 25 mg/L
YOU HAVE DESIGNATED THIS RECEIVING
STREAM AS WATER SUPPLY
Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA		ID	UNITS	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION	
		Chronic Applied Standard	Acute			# Det.	Max Pred Cw	Allowable Cw		
Arsenic	C	150	FW(TQ10s) 340		ug/L	58	58	139.0	Acute (FW): 3,706.9 Chronic (FW): 1,983.3 No value > Allowable Cw Chronic (HH): 631.7 No value > Allowable Cw	No RP
Arsenic	C	10	HH/WS(Qavg)		ug/L			N/A	Acute: 708.68 Chronic: 85.94	No RP
Beryllium	NC	6.5	FW(TQ10s) 65		ug/L	0	0	N/A	Acute: 35.320 Chronic: 7.799 No value > Allowable Cw	No RP > 50% monitor
Cadmium	NC	0.5899	FW(TQ10s) 3.2396		ug/L	58	15	4.830	Acute: NO WQS Chronic: 3,305.5 No value > Allowable Cw	No RP
Chlorides	NC	250	WS(TQ10s)		mg/L	1	1	239.9	Acute: NO WQS Chronic: 85.9 No value > Allowable Cw	No RP
Aluminum	NC	6.5	WS(TQ10s)		mg/L	1	1	0.8	Acute: NO WQS Chronic: 9,867.8 No value > Allowable Cw	No RP
Total Dissolved Solids	NC	500	WS(TQ10s)		mg/L	1	1	1,178.0	Acute: NO WQS Chronic: 6,610.9 No value > Allowable Cw	No RP
Chromium III	NC	117.7325	FW(TQ10s) 905.0818		ug/L	0	0	N/A	Acute: 9,867.8 Chronic: 1,356.6	
Chromium VI	NC	11	FW(TQ10s) 16		ug/L	0	0	N/A	Acute: 174.4 Chronic: 145.4	
Chromium, Total	NC				ug/L	58	26	15.4	Acute: 114.17 Chronic: 145.4 Max reported value = 15.4	No RP
Copper	NC	7.8806	FW(TQ10s) 10.4720		ug/L	16	11	18.48	Acute: 114.17	No RP

Rogers Energy Complex
NC0005088

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Outfall 002 (decanting/normal operations)
QW = 15.15 MGD

Element	NC	FW(7Q10s)	WS(7Q10s)	FW(7Q10s)	WS(7Q10s)	ug/L	1	1	0.8	Chronic: 104.20	Acute: NO WQS	No RP
Fluoride	NC	1800	FW(7Q10s)			ug/L	Note: n ≤ 9 Limited data set		Default C.V.	No value > Allowable Cw		No RP
Lead	NC	2.9416	FW(7Q10s)	75.4871		ug/L	13	10	6.390	Acute: 823.013	Chronic: 38.894	No RP
Mercury	NC	12	FW(7Q10s)			ng/L	0	0	N/A	Acute: NO WQS	Chronic: 158.7	No RP
Molybdenum	NC	160	WS(7Q10s)			ug/L	Note: n ≤ 9 Limited data set		93.0	Acute: NO WQS	Chronic: 2,115.5	No RP
Nickel	NC	37.2313	FW(7Q10s)	335.2087		ug/L	58	58	11.1	Acute (FW): 3,654.7	Chronic (FW): 492.3	No RP
Nickel	NC	25.0000	WS(7Q10s)			ug/L	No value > Allowable Cw		330.5	Chronic (WS): 330.5	No value > Allowable Cw	No RP
Selenium	NC	5	FW(7Q10s)	56		ug/L	58	58	42.3	Acute: 610.6	Chronic: 66.1	No RP, > 50% monitor
Silver	NC	0.06	FW(7Q10s)	0.29639789		ug/L	58	0	NO DETECTS	Acute: 3.2	Chronic: 0.8	No RP
Zinc	NC	126.7335	FW(7Q10s)	125.7052		ug/L	58	40	42.2	Acute: 1,370.5	Chronic: 1,675.7	No RP
Antimony	NC	5.6	WS(7Q10s)			ug/L	Note: n ≤ 9 Limited data set		7.25400	Acute: NO WQS	Chronic: 74.04246	No RP
Barium	NC	1	WS(7Q10s)			mg/L	Note: n ≤ 9 Limited data set		0.39680	Acute: NO WQS	Chronic: 13.22187	No RP
Sulfates	NC	250	WS(7Q10s)			mg/L	15	15	128.87100	Acute: NO WQS	Chronic: 3305.46684	No RP
Thallium	NC	2	WS(7Q10s)			ug/L	15	14	5.23260	Acute: NO WQS	Chronic: 26.44373	No RP

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	Rogers Energy Complex
WWTP/WWTP Class	
NPDES Permit	NC0005088
Outfall	002 (decanting/normal operations)
Flow, Qw (MGD)	15.150
Receiving Stream	Broad River
HUC Number	
Stream Class	WS-IV
<input type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	287.00
7Q10w (cfs)	440.00
30Q2 (cfs)	
QA (cfs)	1460.00
1Q10s (cfs)	232.54
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	
<input type="checkbox"/> CHECK TO APPLY MODEL	

Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

REQUIRED DATA ENTRY

Table 2. Parameters of Concern

WQS	Name	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340	ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A	ug/L
Par03	Beryllium	Aquatic Life	NC	6.5	FW	65	ug/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396	ug/L
Par05	Chlorides	Water Supply	NC	250	WS		mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS		mg/L
Par07	Total Dissolved Solids	Water Supply	NC	500	WS		mg/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818	ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16	ug/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720	ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW		ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871	ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		ng/L
Par16	Molybdenum	Water Supply	NC	160	WS		ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087	ug/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A	ug/L
Par19	Selenium	Aquatic Life	NC	5	FW	56	ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964	ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052	ug/L
Par22	Antimony	Water Supply	NC	5.6	WS		ug/L
Par23	Barium	Water Supply	NC	1	WS		mg/L
Par24	Sulfates	Water Supply	NC	250	WS		mg/L
Par25	Thallium	Water Supply	NC	2	WS		ug/L

REASONABLE POTENTIAL ANALYSIS

H1		Effluent Hardness		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		H2		Upstream Hardness		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Part1 & Part2		Arsenic		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		
Date	Data	BDL=1/2DL	25	Results	0.0000	25.0000	Date	Data	BDL=1/2DL	25	Results	0.0000	25.0000	Date	Data	BDL=1/2DL	Results	24.6226
				Std Dev.	0.6000	1					Mean	25.0000	1				Std Dev.	40.7552
				C.V. (default)	0.6000	1					C.V. (default)	0.8000	1				Mean	0.6042
				10th Per Value	25.00 mg/L	25.00 mg/L					10th Per Value	25.00 mg/L	25.00 mg/L				C.V.	58
				Average Value	25.00 mg/L	25.00 mg/L					Average Value	25.00 mg/L	25.00 mg/L				Max. Value	1.00
				Max. Value	25.00 mg/L	25.00 mg/L					Max. Value	25.00 mg/L	25.00 mg/L				Max. Pred Cw	139.0 ug/L
1							1							1/1/2011	87.5	87.5		
2							2							6/12/2011	70.3	70.3		
3							3							3/1/2012	25.8	25.8		
4							4							7/2/2012	43.1	43.1		
5							5							7/3/2012	36.5	36.5		
6							6							3/4/2012	16.8	16.8		
7							7							1/6/2012	13.4	13.4		
8							8							5/6/2012	31.7	31.7		
9							9							2/7/2012	42.5	42.5		
10							10							7/8/2012	51.6	51.6		
11							11							4/9/2012	47.2	47.2		
12							12							1/10/2012	76.4	76.4		
13							13							6/1/2012	84	84		
14							14							4/12/2012	72.6	72.6		
15							15							2/1/2013	55.7	55.7		
16							16							5/2/2013	29.9	29.9		
17							17							5/3/2013	34.9	34.9		
18							18							2/4/2013	32	32		
19							19							7/5/2013	82.8	82.8		
20							20							4/6/2013	40.5	40.5		
21							21							2/7/2013	139	139		
22							22							6/8/2013	38.2	38.2		
23							23							3/6/2013	31.8	31.8		
24							24							1/10/2013	43.2	43.2		
25							25							5/1/2013	23.3	23.3		
26							26							3/12/2013	77.5	77.5		
27							27							7/1/2014	39.1	39.1		
28							28							4/2/2014	36.2	36.2		
29							29							4/3/2014	35.4	35.4		
30							30							1/3/2015	31.1	31.1		
31							31							1/4/2014	34.9	34.9		
32							32							6/5/2014	16.1	16.1		
33							33							3/6/2014	17.8	17.8		
34							34							1/7/2014	53.6	53.6		
35							35							8/7/2014	56.7	56.7		
36							36							5/8/2014	45.2	45.2		
37							37							2/9/2014	78.6	78.6		
38							38							7/10/2014	42.3	42.3		
39							39							4/1/2014	34.3	34.3		
40							40							2/12/2014	36.4	36.4		
41							41							6/1/2015	27.5	27.5		
42							42							3/2/2015	29.5	29.5		
43							43							3/3/2015	46.3	46.3		
44							44							7/4/2015	20.7	20.7		
45							45							5/5/2015	2.9	2.9		
46							46							2/6/2015	11.4	11.4		
47							47							7/7/2015	66.3	66.3		
48							48							9/7/2016	44.7	44.7		
49							49							4/8/2015	49.5	49.5		
50							50							1/9/2015	52.9	52.9		
51							51							4/9/2016	31.7	31.7		
52							52							6/10/2015	55.6	55.6		
53							53							3/1/2015	13.1	13.1		
54							54							1/12/2015	6.6	6.6		
55							55							5/1/2016	8.3	8.3		
56							56							2/2/2016	11.4	11.4		
57							57							1/3/2016	9.8	9.8		
58							58							5/4/2016	9.7	9.7		

REASONABLE POTENTIAL ANALYSIS

Part04

Cadmium

Use "PASTE SPECIAL" Values" then "CCPV" Maximum data points = 58

Date	Data	BDL=1/2DL	Results
1	3/31/2015	<	1
2	4/7/2015	<	0.5
3	4/14/2015	<	1.0618
4	4/21/2015	<	0.5
5	4/28/2015	<	1.1049
6	5/5/2015	<	57
7	5/12/2015	<	n
8	5/19/2015	<	Multi Factor =
9	5/26/2015	<	Max. Value
10	6/2/2015	<	Max. Pred Cw
11	6/9/2015	<	4.830 ug/L
12	6/16/2015	<	4.830 ug/L
13	6/23/2015	<	
14	6/30/2015	<	
15	7/7/2015	<	
16	7/14/2015	<	
17	7/21/2015	<	
18	7/28/2015	<	
19	8/4/2015	<	
20	8/11/2015	<	
21	8/18/2015	<	
22	8/25/2015	<	
23	9/1/2015	<	
24	9/8/2015	<	
25	9/15/2015	<	
26	9/16/2015	<	
27	9/22/2015	<	0.09
28	9/29/2015	<	ERR
29	10/6/2015	<	0.5
30	10/13/2015	<	4.02
31	10/20/2015	<	3.99
32	10/27/2015	<	4.55
33	11/3/2015	<	4.83
34	11/10/2015	<	3.79
35	11/17/2015	<	3.23
36	11/23/2015	<	2.81
37	12/1/2015	<	2.58
38	12/8/2015	<	2.29
39	12/15/2015	<	1.7
40	12/22/2015	<	1.52
41	12/29/2015	<	1.21
42	1/5/2016	<	1.04
43	1/12/2016	<	1.46
44	1/19/2016	<	0.5
45	1/26/2016	<	0.5
46	2/2/2016	<	0.5
47	2/9/2016	<	0.5
48	2/16/2016	<	0.5
49	2/23/2016	<	0.5
50	3/1/2016	<	0.5
51	3/8/2016	<	0.5
52	3/15/2016	<	0.5
53	3/22/2016	<	0.5
54	3/29/2016	<	0.5
55	4/5/2016	<	0.5
56	4/12/2016	<	0.5
57	4/19/2016	<	0.5
58	4/26/2016	<	0.5

Part0

Chromium, Total

Use "PASTE SPECIAL" Values" then "CCPV" Maximum data points = 58

Date	Data	BDL=1/2DL	Results
1	3/31/2015	<	2.1
2	4/7/2015	<	1.81
3	4/14/2015	<	1.81
4	4/21/2015	<	0.5
5	4/28/2015	<	0.5
6	5/5/2015	<	0.5
7	5/12/2015	<	0.5
8	5/19/2015	<	0.5
9	5/26/2015	<	0.5
10	6/2/2015	<	0.5
11	6/9/2015	<	0.5
12	6/16/2015	<	1.01
13	6/23/2015	<	3.37
14	6/30/2015	<	4.76
15	7/7/2015	<	4.92
16	7/14/2015	<	6.5
17	7/21/2015	<	11.7
18	7/28/2015	<	15.4
19	8/4/2015	<	11.6
20	8/11/2015	<	11.4
21	8/18/2015	<	10.2
22	8/25/2015	<	5.06
23	9/1/2015	<	5.06
24	9/8/2015	<	3.41
25	9/15/2015	<	2.29
26	9/16/2015	<	1.8
27	9/22/2015	<	2.09
28	9/29/2015	<	3.7
29	10/6/2015	<	3.24
30	10/13/2015	<	1.81
31	10/20/2015	<	1.66
32	10/27/2015	<	1.01
33	11/3/2015	<	1.01
34	11/10/2015	<	0.5
35	11/17/2015	<	0.5
36	11/23/2015	<	0.5
37	12/1/2015	<	0.5
38	12/8/2015	<	0.5
39	12/15/2015	<	0.5
40	12/22/2015	<	0.5
41	12/29/2015	<	0.5
42	1/5/2016	<	0.5
43	1/12/2016	<	0.5
44	1/19/2016	<	0.5
45	1/26/2016	<	0.5
46	2/2/2016	<	0.5
47	2/9/2016	<	0.5
48	2/16/2016	<	0.5
49	2/23/2016	<	1.68
50	3/1/2016	<	1.46
51	3/8/2016	<	1.46
52	3/15/2016	<	1.12
53	3/22/2016	<	0.5
54	3/29/2016	<	0.5
55	4/5/2016	<	0.5
56	4/12/2016	<	0.5
57	4/19/2016	<	0.5
58	4/26/2016	<	0.5

Part1

Copper

Use "PASTE SPECIAL" Values" then "CCPV" Maximum data points = 58

Date	Data	BDL=1/2DL	Results
1	10/28/2011	<	5
2	12/6/2011	<	5
3	3/13/2014	<	5
4	7/8/2014	<	5
5	9/16/2015	<	5
6		<	2.62
7		<	3.7
8		<	10
9		<	10
10		<	1.9
11		<	11.2
12		<	2.2
13		<	4
14		<	4
15		<	
16		<	
17		<	
18		<	8.1
19		<	0.5
20		<	3.4
21		<	3.4
22		<	2.2
23		<	2.2
24		<	
25		<	
26		<	
27		<	
28		<	
29		<	
30		<	
31		<	
32		<	
33		<	
34		<	
35		<	
36		<	
37		<	
38		<	
39		<	
40		<	
41		<	
42		<	
43		<	
44		<	
45		<	
46		<	
47		<	
48		<	
49		<	
50		<	
51		<	
52		<	
53		<	
54		<	
55		<	
56		<	
57		<	
58		<	

Part:

REASONABLE POTENTIAL ANALYSIS

3					Part14					Part17 & Part18					Part1				
Fluoride					Lead					Nickel									
Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL" Values "then" COPY" Maximum data points = 58	Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL" Values "then" COPY" Maximum data points = 58	Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL" Values "then" COPY" Maximum data points = 58					
	0.127	0.127	Sid Dev. Mean C.V. (default) n Mult Factor = Max. Value Max. Pred Cw	0.0000 0.1270 0.6000 1 6.20 0.1 ug/L 0.8 ug/L															
1			Sid Dev.	0.0000				Sid Dev.	0.0435	3/31/2015	1.83	1.83	Sid Dev.	2.3951					
2			Mean	0.1270			Mean	0.7323	0.7323	4/7/2015	2.87	2.87	Mean	5.3045					
3			C.V. (default)	0.6000			C.V.	1.1519	1.1519	4/14/2015	5.99	5.99	C.V.	0.5646					
4			n	1			n	13	13	4/21/2015	6.32	6.32	n	58					
5			Mult Factor =	6.20			Mult Factor =	2.13	2.13	4/28/2015	7.15	7.15	Mult Factor =	1.00					
6			Max. Value	0.1 ug/L			Max. Value	3.000 ug/L	3.000 ug/L	5/5/2015	8.94	8.94	Max. Value	9.14					
7			Max. Pred Cw	0.8 ug/L			Max. Pred Cw	6.390 ug/L	6.390 ug/L	5/12/2015	9.14	9.14	Max. Value	11.1 ug/L					
8										5/19/2015	6.78	6.78	Max. Pred Cw	11.1 ug/L					
9										5/26/2015	5.71	5.71							
10										6/2/2015	3.31	3.31							
11										6/9/2015	2.84	2.84							
12										6/16/2015	3.06	3.06							
13										6/23/2015	2.15	2.15							
14										6/30/2015	3.23	3.23							
15										7/7/2015	4.42	4.42							
16										7/14/2015	2.49	2.49							
17										7/21/2015	1.99	1.99							
18										7/28/2015	1.82	1.82							
19										8/4/2015	1.4	1.4							
20										8/11/2015	1.73	1.73							
21										8/18/2015	1.32	1.32							
22										8/25/2015	1.38	1.38							
23										9/1/2015	1.37	1.37							
24										9/8/2015	1.06	1.06							
25										9/15/2015	1.68	1.68							
26										9/16/2015	1	1							
27										9/22/2015	2.03	2.03							
28										9/29/2015	2.2	2.2							
29										10/6/2015	4.34	4.34							
30										10/13/2015	4.73	4.73							
31										10/20/2015	5.16	5.16							
32										10/27/2015	6.26	6.26							
33										11/3/2015	6.14	6.14							
34										11/10/2015	7.09	7.09							
35										11/17/2015	7.07	7.07							
36										11/23/2015	8.36	8.36							
37										12/1/2015	8.51	8.51							
38										12/8/2015	8.44	8.44							
39										12/15/2015	7.91	7.91							
40										12/21/2015	7.88	7.88							
41										12/29/2015	7.67	7.67							
42										1/5/2016	9.2	9.2							
43										1/12/2016	10.3	10.3							
44										1/19/2016	11.1	11.1							
45										1/26/2016	10.4	10.4							
46										2/2/2016	9.77	9.77							
47										2/9/2016	9.85	9.85							
48										2/16/2016	9.02	9.02							
49										2/23/2016	9.05	9.05							
50										3/1/2016	8.38	8.38							
51										3/8/2016	7.03	7.03							
52										3/15/2016	5.5	5.5							
53										3/22/2016	3.98	3.98							
54										3/29/2016	3.95	3.95							
55										4/5/2016	3.8	3.8							
56										4/12/2016	3.27	3.27							
57										4/19/2016	3.91	3.91							
58										4/26/2016	4.58	4.58							

REASONABLE POTENTIAL ANALYSIS

9		Selenium		Silver		Zinc	
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
			Std Dev.				Std Dev.
			Mean				Mean
			C.V.				C.V.
			n				n
			Multi Factor =				Multi Factor =
			Max. Value				Max. Value
			Max. Pred Cw				Max. Pred Cw
			42.3 ug/L				42.2 ug/L
			8.4627				0.0000
			13.3652				0.5000
			0.6337				0.0000
			58				58
			1.00				1.00
			42.3 ug/L				0.500 ug/L
			42.3 ug/L				0 DETECTS ug/L
3/31/2015	42.3	BDL=1/2DL	Results	3/31/2015	<	BDL=1/2DL	Results
4/7/2015	31.8	31.8	Std Dev.	4/7/2015	<	0.5	0.0000
4/14/2015	21.6	42.3	Mean	4/14/2015	<	0.5	0.5000
4/21/2015	15.4	21.6	C.V.	4/21/2015	<	0.5	0.0000
4/28/2015	14.9	15.4	n	4/28/2015	<	0.5	58
5/5/2015	8.6	14.9	Multi Factor =	5/5/2015	<	0.5	26
5/12/2015	6.6	8.6	Max. Value	5/12/2015	<	0.5	28.9
5/19/2015	24	6.6	Max. Value	5/19/2015	<	0.5	25.5
5/26/2015	26.4	24	Max. Pred Cw	5/26/2015	<	0.5	14.3
6/2/2015	15.7	26.4	42.3 ug/L	6/2/2015	<	0.5	8.94
6/9/2015	15.7	15.7	1.00	6/9/2015	<	0.5	5.43
6/16/2015	11.2	11.2	42.3 ug/L	6/16/2015	<	0.5	5
6/23/2015	14.6	11.2	42.3 ug/L	6/23/2015	<	0.5	5
6/30/2015	10.2	10.2	42.3 ug/L	6/30/2015	<	0.5	5
7/7/2015	14.1	10.2	42.3 ug/L	7/7/2015	<	0.5	5
7/14/2015	12.2	14.1	42.3 ug/L	7/14/2015	<	0.5	5
7/21/2015	11.7	12.2	42.3 ug/L	7/21/2015	<	0.5	5
7/28/2015	19.1	11.7	42.3 ug/L	7/28/2015	<	0.5	5
8/4/2015	18.3	19.1	42.3 ug/L	8/4/2015	<	0.5	5
8/11/2015	16.8	18.3	42.3 ug/L	8/11/2015	<	0.5	5
8/18/2015	7.4	16.8	42.3 ug/L	8/18/2015	<	0.5	5
8/25/2015	16.9	7.4	42.3 ug/L	8/25/2015	<	0.5	5
9/1/2015	7.6	16.9	42.3 ug/L	9/1/2015	<	0.5	5
9/8/2015	4.6	7.6	42.3 ug/L	9/8/2015	<	0.5	8.43
9/15/2015	4	4.6	42.3 ug/L	9/15/2015	<	0.5	8.07
9/22/2015	3.5	4	42.3 ug/L	9/22/2015	<	0.5	5
9/29/2015	9.8	3.5	42.3 ug/L	9/29/2015	<	0.5	2.5
10/6/2015	6.2	9.8	42.3 ug/L	10/6/2015	<	0.5	6.9
10/13/2015	7.7	6.2	42.3 ug/L	10/13/2015	<	0.5	12
10/20/2015	8.4	7.7	42.3 ug/L	10/20/2015	<	0.5	5
10/27/2015	3.7	8.4	42.3 ug/L	10/27/2015	<	0.5	10.5
11/3/2015	2.3	3.7	42.3 ug/L	11/3/2015	<	0.5	7.6
11/10/2015	28	2.3	42.3 ug/L	11/10/2015	<	0.5	12.2
11/17/2015	30.7	28	42.3 ug/L	11/17/2015	<	0.5	15.4
11/23/2015	24.1	30.7	42.3 ug/L	11/23/2015	<	0.5	16.3
12/1/2015	26.9	24.1	42.3 ug/L	12/1/2015	<	0.5	20.7
12/8/2015	20.5	26.9	42.3 ug/L	12/8/2015	<	0.5	21.6
12/15/2015	13.3	20.5	42.3 ug/L	12/15/2015	<	0.5	24.9
12/21/2015	20	13.3	42.3 ug/L	12/21/2015	<	0.5	25.4
12/29/2015	13	20	42.3 ug/L	12/29/2015	<	0.5	23.4
1/5/2016	11.9	13	42.3 ug/L	1/5/2016	<	0.5	18.6
1/12/2016	22.3	11.9	42.3 ug/L	1/12/2016	<	0.5	23.7
1/19/2016	11.5	22.3	42.3 ug/L	1/19/2016	<	0.5	22.5
1/26/2016	5.1	11.5	42.3 ug/L	1/26/2016	<	0.5	23.5
2/2/2016	4.1	5.1	42.3 ug/L	2/2/2016	<	0.5	28.7
2/9/2016	17	4.1	42.3 ug/L	2/9/2016	<	0.5	42.2
2/16/2016	14.7	17	42.3 ug/L	2/16/2016	<	0.5	38.1
2/23/2016	15.7	14.7	42.3 ug/L	2/23/2016	<	0.5	37.1
3/1/2016	12.4	15.7	42.3 ug/L	3/1/2016	<	0.5	40.3
3/8/2016	6.2	12.4	42.3 ug/L	3/8/2016	<	0.5	31.6
3/15/2016	12.9	6.2	42.3 ug/L	3/15/2016	<	0.5	27.9
3/22/2016	7.2	12.9	42.3 ug/L	3/22/2016	<	0.5	23.9
3/29/2016	5.8	7.2	42.3 ug/L	3/29/2016	<	0.5	18.1
4/5/2016	4.8	5.8	42.3 ug/L	4/5/2016	<	0.5	11
4/12/2016	5.2	4.8	42.3 ug/L	4/12/2016	<	0.5	5.29
4/19/2016	5.9	5.2	42.3 ug/L	4/19/2016	<	0.5	5
4/26/2016	2.4	5.9	42.3 ug/L	4/26/2016	<	0.5	6.25
		2.4	42.3 ug/L				11.1

REASONABLE POTENTIAL ANALYSIS

Antimony		Barium		Sulfates	
Date	BDL=1/2DL	Date	BDL=1/2DL	Date	BDL=1/2DL
1.17	1.17	0.064	0.064		
Results Std Dev.	0.00000	Results Std Dev.	0.00000	Results Std Dev.	20.8523
Mean	1.1700	Mean	0.0640	Mean	58.3200
C.V. (default)	0.6000	C.V. (default)	0.6000	C.V.	0.3541
n	1	n	1	n	15
Multi Factor =	6.20	Multi Factor =	6.20	Multi Factor =	1.29
Max. Value	1.170000 µg/L	Max. Value	0.064000 mg/L	Max. Value	99.900000 mg/L
Max. Pred Cw	7.254000 µg/L	Max. Pred Cw	0.396800 mg/L	Max. Pred Cw	128.871000 mg/L
Use "PASTE SPECIAL" Values" then "COPY" Maximum data points = 58					
1		1		1	
2		2		2	52.6
3		3		3	68.1
4		4		4	36
5		5		5	72.8
6		6		6	41.8
7		7		7	83.1
8		8		8	25.4
9		9		9	99.9
10		10		10	70.1
11		11		11	39.4
12		12		12	63.1
13		13		13	43.6
14		14		14	62.6
15		15		15	39.7
16		16		16	76.6
17		17		17	
18		18		18	
19		19		19	
20		20		20	
21		21		21	
22		22		22	
23		23		23	
24		24		24	
25		25		25	
26		26		26	
27		27		27	
28		28		28	
29		29		29	
30		30		30	
31		31		31	
32		32		32	
33		33		33	
34		34		34	
35		35		35	
36		36		36	
37		37		37	
38		38		38	
39		39		39	
40		40		40	
41		41		41	
42		42		42	
43		43		43	
44		44		44	
45		45		45	
46		46		46	
47		47		47	
48		48		48	
49		49		49	
50		50		50	
51		51		51	
52		52		52	
53		53		53	
54		54		54	
55		55		55	
56		56		56	
57		57		57	
58		58		58	

REASONABLE POTENTIAL ANALYSIS

5		Thallium		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 50	
Date	Data	BDL=1/2DL	Results	Std Dev.	Mean
	3.06	3.06	0.9497	1.1213	
	0.71	0.71	0.8470	15	
	0.43	0.43			
	1.9	1.9			
	0.24	0.24			
	2.2	2.2			
	0.13	0.13			
	2.6	2.6			
	1.3	1.3			
	0.58	0.58			
	0.53	0.53			
	0.1	0.05			
	1.2	1.2			
	0.39	0.39			
	1.5	1.5			

Multi Factor = 1.71
 Max. Value 3.060000 µg/L
 Max. Pred Cw 5.232600 µg/L

MAXIMUM DATA POINTS = 58

Ow (MGD) = 1.30
 1Q10S (cfs) = 232.54
 7Q10S (cfs) = 287.00
 7Q10W (cfs) = 440.00
 30Q2 (cfs) = 365.00
 Avg. Stream Flow, QA (cfs) = 1460.00
 Receiving Stream: NO HUC NUMBER

WWTTP/WTP Class:
 IWC% @ 1Q10S = 0.859073565
 IWC% @ 7Q10S = 0.697195647
 IWC% @ 7Q10W = 0.45586882
 IWC% @ 30Q2 = 0.549023882
 IWC @ QA = 0.137823483
 Stream Class: WS-IV

COMBINED HARDNESS (mg/L)
 Acute = 25.64 mg/L
 Chronic = 25.52 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
 Effluent Hard: 1 value > 100 mg/L
 default: 99 mg/L -Vvs (Eff Hard Avg = 100 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			POL	UNITS	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION	
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw		Allowable Cw
Arsenic	C	150	FW(7Q10s)	340		ug/L	10	10	72.1	Acute (FW): 39,577.5 Chronic (FW): 21,514.8 <i>No value > Allowable Cw</i> Chronic (HH): 7,255.7 <i>No value > Allowable Cw</i>	No RP
Arsenic	C	10	HH/WS(Qavg)			ug/L			N/A	Acute: 7,566.29 Chronic: 932.31	
Beryllium	NC	6.5	FW(7Q10s)	65		ug/L	0	0	N/A	Acute: 385.466 Chronic: 85.925 <i>No value > Allowable Cw</i>	No RP
Cadmium	NC	0.5991	FW(7Q10s)	3.3114		ug/L	10	4	0.960	Acute: 35,857.9 Chronic: 932.3 <i>No value > Allowable Cw</i>	No RP
Chlorides	NC	250	WS(7Q10s)			mg/L	10	10	50.2	Acute: NO WQS Chronic: 35,857.9 <i>No value > Allowable Cw</i>	No RP
Aluminum	NC	6.5	WS(7Q10s)			mg/L	10	5	1.1	Acute: NO WQS Chronic: 932.3 <i>No value > Allowable Cw</i>	No RP
Total Dissolved Solids	NC	500	WS(7Q10s)			mg/L	10	10	570.6	Acute: NO WQS Chronic: 71,715.9 <i>No value > Allowable Cw</i>	No RP
Chromium III	NC	119.7187	FW(7Q10s)	923.8881		ug/L	0	0	N/A	Acute: 107,544.7 Chronic: 17,171.3	
Chromium VI	NC	11	FW(7Q10s)	16		ug/L	0	0	N/A	Acute: 1,862.5 Chronic: 1,577.7	All values < detection
Chromium, Total	NC					ug/L	10	5	#REPI #REF! #REF!	#REPI	No RP
Copper	NC	8.0194	FW(7Q10s)	10.7227		ug/L	10	2	6.05	Acute: 1,248.17 Chronic: 1,150.24 <i>No value > Allowable Cw</i>	No RP

Element	NC	1800	FW(7Q10s)	ug/L	0	0	N/A	Chronic:	Acute:	No RP
Fluoride	NC	1800	FW(7Q10s)	ug/L	0	0	N/A	Chronic: 258,177.2	Acute: 9,039,029	No RP
Lead	NC	3.0101	FW(7Q10s)	ug/L	10	1	2.640	Chronic: 431,740	Acute: 431,740	No RP
Mercury	NC	12	FW(7Q10s)	ng/L	7	7	10.7	Chronic: 1,721.2	Acute: NO WQS	No RP
Molybdenum	NC	160	WS(7Q10s)	ug/L	10	9	4.4	Chronic: 22,949.1	Acute: NO WQS	No RP
Nickel	NC	37.8803	FW(7Q10s)	ug/L	10	5	4.7	Chronic (FW): 5,433.2	Acute (FW): 39,857.6	No RP
Nickel	NC	25.0000	WS(7Q10s)	ug/L				Chronic (WS): 3,585.8	Acute (WS): 3,585.8	No RP
Selenium	NC	5	FW(7Q10s)	ug/L	10	4	5.8	Chronic: 717.2	Acute: 6,518.7	No RP
Boron	NC	7	FW(7Q10s)	mg/l	0	0	N/A	Chronic: 1,004.0	Acute: 0.0	No RP
Zinc	NC	128.9460	FW(7Q10s)	ug/L	10	4	148.1	Chronic: 18,495.0	Acute: 14,947.3	No RP
Antimony	NC	5.6	WS(7Q10s)	ug/L	11	0	NO DETECTS	Chronic: 803,217.87	Acute: NO WQS	No RP
Barium	NC	1	WS(7Q10s)	mg/L	10	10	0.14224	Chronic: 143,431.76	Acute: NO WQS	No RP
Sulfates	NC	250	WS(7Q10s)	mg/L	10	10	224,94000	Chronic: 35857.9	Acute: NO WQS	No RP
Thallium	NC	2	WS(7Q10s)	ug/L	11	5	1.14000	Chronic: 286,863.52	Acute: NO WQS	No RP

REASONABLE POTENTIAL ANALYSIS

H1		H2		Par01 & Par02	
Effluent Hardness		Upstream Hardness		Arsenic	
Date	Data	Date	Data	Date	Data
BDL=1/2DL 100		BDL=1/2DL 25		BDL=1/2DL 48.4	
Results Std Dev. Mean C.V. (default) n		Results Std Dev. Mean C.V. (default) n		Results Std Dev. Mean C.V. n	
10th Per Value Average Value Max. Value		10th Per Value Average Value Max. Value		Multi Factor = Max. Value Max. Pred Cw	
0.0000 100.0000 0.6000 1		0.0000 25.0000 0.6000 1		13.7766 33.0400 0.4170 10	
100.00 mg/L 99.00 mg/L 100.00 mg/L		25.00 mg/L 25.00 mg/L 25.00 mg/L		1.49 48.4 ug/L 72.1 ug/L	
1		1		1	
2		2		2	
3		3		3	
4		4		4	
5		5		5	
6		6		6	
7		7		7	
8		8		8	
9		9		9	
10		10		10	
11		11		11	
12		12		12	
13		13		13	
14		14		14	
15		15		15	
16		16		16	
17		17		17	
18		18		18	

REASONABLE POTENTIAL ANALYSIS

Part03				Part04				Part05				Part0			
Beryllium				Cadmium				Chlorides							
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1			NO DATA	1	<	0.5	0.2082	1	18	18	8.7490	1			
2			NO DATA	2	<	0.5	0.2850	2	27	27	30.9	2			
3			NO DATA	3	<	0.05	0.7306	3	13	13	0.2831	3			
4			0	4	<	0.1	n	4	34	34	n	4			
5				5	<	0.5	10	5	35	35	10	5			
6			Multi Factor =	6	<	0.4	1.92	6	34	34	1.3	6			
7			Max. Value	7	<	0.5	0.500 ug/L	7	36	36	38.0 mg/L	7			
8			Max. Pred Cw	8	<	0.1	0.960 ug/L	8	38	38	50.2 mg/L	8			
9			N/A ug/L	9	<	0.1	0.1	9	37	37		9			
10			N/A ug/L	10		0.1	0.1	10				10			
11				11				11				11			
12				12				12				12			
13				13				13				13			
14				14				14				14			
15				15				15				15			
16				16				16				16			
17				17				17				17			
18				18				18				18			

REASONABLE POTENTIAL ANALYSIS

5		Par07		Par08		Par09	
Aluminum		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
	0.03	0.03	Std Dev.	1			NO DATA
	0.05	0.05	Mean	2			NO DATA
	0.4	0.4	C.V.	3			NO DATA
	0.1	0.05	n	4			0
	0.02	0.02	Multi Factor =	5			
	0.1	0.05	Max. Value	6			
	0.12	0.12	Max. Pred Cw	7			
	0.1	0.05		8			
	0.1	0.05		9			
	0.1	0.05		10			
				11			
				12			
				13			
				14			
				15			
				16			
				17			
				18			
Total Dissolved Solids		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
	300	300	Std Dev.	1			NO DATA
	92	92	Mean	2			NO DATA
	344	344	C.V.	3			NO DATA
	350	350	n	4			0
	335	335	Multi Factor =	5			
	340	340	Max. Value	6			
	280	280	Max. Pred Cw	7			
	362	362		8			
	422	422		9			
	429	429		10			
				11			
				12			
				13			
				14			
				15			
				16			
				17			
				18			
Chromium III		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
			Std Dev.	1			NO DATA
			Mean	2			NO DATA
			C.V.	3			NO DATA
			n	4			0
			Multi Factor =	5			
			Max. Value	6			
			Max. Pred Cw	7			
				8			
				9			
				10			
				11			
				12			
				13			
				14			
				15			
				16			
				17			
				18			

REASONABLE POTENTIAL ANALYSIS

		Part10		Part11		Part12	
		Chromium VI		Chromium, Total		Copper	
		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	
Date	BDL=1/2DL	Results	Std Dev.	Mean	C.V.	n	Mult Factor =
1	<	1	0.5	0.5	Mean	8	1.74
2	<	1	0.5	2.5	C.V. (default)	8	1.74
3	<	0.47	0.5	0.5	n	8	1.74
4	<	0.22	0.5	0.5	n	8	1.74
5	<	1	0.35	0.14	Mult Factor =	8	1.74
6	<	1	0.14	0.25	Max. Value	8	1.74
7	<	0.35	0.25	0.14	Max. Pred Cw	8	1.74
8	<	0.14	#REF!	0.25	#REF!	8	1.74
9	<	0.25	#REF!	0.25	#REF!	8	1.74
10	<						
11	<						
12	<						
13	<						
14	<						
15	<						
16	<						
17	<						
18	<						

REASONABLE POTENTIAL ANALYSIS

	Part3	Part4	Part5
Cyanide	Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58
Fluoride	BDL=1/2DL	BDL=1/2DL	BDL=1/2DL
Lead	BDL=1/2DL	BDL=1/2DL	BDL=1/2DL
Mercury	BDL=1/2DL	BDL=1/2DL	BDL=1/2DL
Results	NO DATA	NO DATA	NO DATA
Std Dev.	NO DATA	NO DATA	NO DATA
Mean	NO DATA	NO DATA	NO DATA
C.V.	NO DATA	NO DATA	NO DATA
n	0	0	0
Multi Factor =	N/A	N/A	N/A
Max. Value	N/A ug/L	N/A ug/L	N/A ug/L
Max. Pred Cw	N/A ug/L	N/A ug/L	N/A ug/L
Date			
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
Results			
Std Dev.			
Mean			
C.V.			
n			
Multi Factor =			
Max. Value			
Max. Pred Cw			
Date			
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			

REASONABLE POTENTIAL ANALYSIS

Part6		Part7 & Part8		Part9	
Molybdenum		Nickel		Selenium	
Date	Data	Date	Data	Date	Data
1	2.4	1	0.7	1	1
2	2.9	2	0.6	2	1
3	0.5	3	1	3	0.5
4	3.1	4	1	4	0.22
5	3.2	5	5	5	1
6	2.4	6	1	6	5
7	2.6	7	1	7	1
8	2.8	8	1.1	8	0.41
9	2.9	9	1	9	0.42
10	3.2	10	1	10	0.73
11		11		11	
12		12		12	
13		13		13	
14		14		14	
15		15		15	
16		16		16	
17		17		17	
18		18		18	

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 50

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 50

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 50

Results
Std Dev. 1.0078
Mean 4.0286
C.V. (default) 0.6000
n 7

Results
Std Dev. 0.8663
Mean 2.5750
C.V. 0.3372
n 10

Results
Std Dev. 0.6136
Mean 0.8900
C.V. 0.6895
n 10

BDL=1/2DL
2.4
2.9
0.25
3.1
3.2
2.4
2.6
2.8
2.9
3.2

BDL=1/2DL
0.7
0.6
0.5
0.5
2.5
0.5
0.5
1.1
1
1

BDL=1/2DL
0.5
0.5
0.25
0.22
0.5
2.5
0.5
0.41
0.42
0.73

Mult Factor = 2.01
Max. Value 5.3 ng/L
Max. Pred Cw 10.7 ng/L

Mult Factor = 1.39
Max. Value 3.2 ug/L
Max. Pred Cw 4.4 ug/L

Mult Factor = 1.86
Max. Value 2.5 ug/L
Max. Pred Cw 4.7 ug/L

REASONABLE POTENTIAL ANALYSIS

Par20		Par21		Par22	
Boron		Zinc		Antimony	
Date	Data	Date	Data	Date	Data
Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58 Results Std Dev. 0.6645 Mean 0.6530 C.V. 1.0176 n 10 Mult Factor = 2.32 Max. Value 2.5 ug/L Max. Pred Cw 5.8 ug/L		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58 Results Std Dev. NO DATA Mean NO DATA C.V. NO DATA n 0 Mult Factor = N/A Max. Value N/A mg/l Max. Pred Cw N/A mg/l		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58 Results Std Dev. 13.4656 Mean 7.8500 C.V. 1.7154 n 10 Mult Factor = 3.22 Max. Value 46.0 ug/L Max. Pred Cw 148.1 ug/L	
1		1		1	
2		2		2	
3		3		3	
4		4		4	
5		5		5	
6		6		6	
7		7		7	
8		8		8	
9		9		9	
10		10		10	
11		11		11	
12		12		12	
13		13		13	
14		14		14	
15		15		15	
16		16		16	
17		17		17	
18		18		18	

REASONABLE POTENTIAL ANALYSIS

Par23		Par24		Par25	
Barium		Sulfates		Thallium	
Date	Results	Date	Results	Date	Results
1	0.1	90	90	<	0.2
2	0.1	104	104	<	0.2
3	0.03	31	31	<	0.04
4	0.1	119	119	<	0.08
5	0.1	120	120	<	0.2
6	0.1	115	115	<	1
7	0.1	130	130	<	0.2
8	0.112	148	148	<	0.1
9	0.1	160	160	<	0.07
10	0.1	163	163	<	0.02
11				<	0.2
12					
13					
14					
15					
16					
17					
18					

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 56

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 56

Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 56

Results
Std Dev. 0.6528
Mean 0.5682
C.V. 1.1489
n 11
Mult Factor = 2.35
Max. Value 2.5000000 µg/L
Max. Pred Cw 0 DETECTS µg/L

Results
Std Dev. 0.0229
Mean 0.0942
C.V. 0.2428
n 10
Mult Factor = 1.27
Max. Value 0.1120000 mg/L
Max. Pred Cw 0.142240 mg/L

Results
Std Dev. 38.5804
Mean 118.0000
C.V. 0.3270
n 10
Mult Factor = 1.38
Max. Value 163.0000000 mg/L
Max. Pred Cw 224.9400000 mg/L

REASONABLE POTENTIAL ANALYSIS

	Use "PASTE SPECIAL Values" from "COPY" Maximum data points = 58
Results	
Std Dev.	0.1293
Mean	0.1191
C.V.	1.0861
n	11
Multi Factor =	2.28
Max. Value	0.500000 µg/L
Max. Pred Cw	1.140000 µg/L

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	Rogers Energy Complex
WWTP/MP/TP Class	
NPDES Permit	NC00005088
Outfall	Seep 104
Flow, Qw (MGD)	1.300
Receiving Stream	Broad River
HUC Number	
Stream Class	WS-IV
<input type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	287.00
7Q10w (cfs)	440.00
30Q2 (cfs)	365.00
QA (cfs)	1460.00
1Q10s (cfs)	232.54
Effluent Hardness	default 99 mg/L -Ws (Eff Hard Avg = 100 mg/L)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25.52 mg/L
Combined Hardness Acute	25.64 mg/L
Data Source(s)	
<input type="checkbox"/> CHECK TO APPLY MODEL	

Follow directions for data entry. In some cases a dropdown menu will provide a list of available choices or a list you may select from. Error message occur if data entry does not meet input criteria.

Table 2. Parameters of Concern

Part	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Part01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Part02	Arsenic	Human Health Water Supply	C	10	HHWS	N/A		ug/L
Part03	Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Part04	Cadmium	Aquatic Life	NC	0.5991	FW	3.3114		ug/L
Part05	Chlorides	Water Supply	NC	250	WS			mg/L
Part06	Aluminum	Water Supply	NC	6.5	WS			mg/L
Part07	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Part08	Chromium III	Aquatic Life	NC	119.7187	FW	923.8881		ug/L
Part09	Chromium VI	Aquatic Life	NC	11	FW	16		ug/L
Part10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Part11	Copper	Aquatic Life	NC	8.0194	FW	10.7227		ug/L
Part12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Part13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Part14	Lead	Aquatic Life	NC	3.0101	FW	77.6519		ug/L
Part15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Part16	Molybdenum	Water Supply	NC	160	WS			ug/L
Part17	Nickel	Aquatic Life	NC	37.8803	FW	342.4059		ug/L
Part18	Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Part19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Part20	Boron	Aquatic Life	NC	7	FW			mg/l
Part21	Zinc	Aquatic Life	NC	128.9460	FW	128.4084		ug/L
Part22	Antimony	Water Supply	NC	5.6	WS			ug/L
Part23	Barium	Water Supply	NC	1	WS			mg/L
Part24	Sulfates	Water Supply	NC	250	WS			mg/L
Part25	Thallium	Water Supply	NC	2	WS			ug/L

MAXIMUM DATA POINTS = 58

Qw (MGD) = 1.90
 1Q10S (cfs) = 0.00
 7Q10S (cfs) = 0.00
 7Q10W (cfs) = 0.00
 30Q2 (cfs) = 0.00
 Avg. Stream Flow, QA (cfs) = 0.00
 Receiving Stream: NO HUC NUMBER

WWT/PTP Class:
 IWC% @ 1Q10S = 100
 IWC% @ 7Q10S = 100
 IWC% @ 7Q10W = 100
 IWC% @ 30Q2 = 100
 IW% @ QA = 100
 Stream Class: WS-IV

COMBINED HARDNESS (mg/L)
 Acute = 99 mg/L
 Chronic = 99 mg/L
 YOU HAVE DESIGNATED THIS RECEIVING
 STREAM AS WATER SUPPLY
 Effluent Hard: 1 value > 100 mg/L
 default: 99 mg/L -Ws (Eff Hard Avg = 100 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA		P	UNITS	REASONABLE POTENTIAL RESULTS			ALLOWABLE Cw	RECOMMENDED ACTION
		Chronic	Applied Standard			Acute	n	# Det.		
Arsenic	C	150	FW	340	ug/L	9	5	2.9	Acute (FW): 340.0 Chronic (FW): 150.0 No value > Allowable Cw Chronic (HH): 10.0 No value > Allowable Cw	No RP
Arsenic	C	10	HH/WS		ug/L	Note: n ≤ 9 Limited data set			Acute: 65.00 Chronic: 6.50 No value > Allowable Cw	No RP
Beryllium	NC	6.5	FW	65	ug/L	6	1	1.07	Acute: 65.00 Chronic: 6.50 No value > Allowable Cw	No RP
Cadmium	NC	1.6678	FW	10.7582	ug/L	10	1	1.130	Acute: 10.758 Chronic: 1.668 No value > Allowable Cw	No RP
Chlorides	NC	250	WS		mg/L	9	9	126.7	Acute: NO WQS Chronic: 250.0 No value > Allowable Cw	No RP
Aluminum	NC	6.5	WS		mg/L	9	4	11.1	Acute: NO WQS Chronic: 6.5 No value > Allowable Cw	RP
Total Dissolved Solids	NC	500	WS		mg/L	9	9	894.1	Acute: NO WQS Chronic: 500.0 No value > Allowable Cw	RP
Chromium III	NC	363.4201	FW	2793.8313	ug/L	0	0	N/A	Acute: 2,793.8 Chronic: 363.4	
Chromium VI	NC	11	FW	16	ug/L	0	0	N/A	Acute: 16.0 Chronic: 11.0	Max reported value < 11
Chromium, Total	NC				ug/L	Total Cr value(s) < 50 and < Cr VI Allowable Cw Note: n ≤ 9 Default C.V. Limited data set			Max reported value = 6.14	
Copper	NC	25.5442	FW	38.2981	ug/L	9	4	7.38	Acute: 38.30 Chronic: 25.54 No value > Allowable Cw	No RP

Element	NC	1800	FW	FW	FW	403.4414	ug/L	0	0	N/A	Chronic: 1,800.0	
Fluoride	NC	1800	FW	FW	FW	403.4414	ug/L	0	0	N/A	Chronic: 1,800.0	
Lead	NC	13.5358	FW	FW	FW	347.3518	ug/L	9	2	6,950 Default C.V.	Acute: 347.352 Chronic: 13.536 No value > Allowable Cw	No RP
Mercury	NC	12	FW	FW	FW	0.5	ng/L	7	7	9.0 Default C.V.	Acute: NO WQS Chronic: 12.0 No value > Allowable Cw	No RP
Molybdenum	NC	160	WS	WS	WS		ug/L	9	4	4.5 Default C.V.	Acute: NO WQS Chronic: 160.0 No value > Allowable Cw	No RP
Nickel	NC	119.2776	FW	FW	FW	1073.9039	ug/L	9	8	5.5 Default C.V.	Acute (FW): 1,073.9 Chronic (FW): 119.3 No value > Allowable Cw Chronic (WS): 25.0 No value > Allowable Cw	No RP
Nickel	NC	25.0000	WS	WS	WS		ug/L	9	0	NO DETECTS	Acute: 56.0 Chronic: 5.0 Max MDL = 5	No RP
Selenium	NC	5	FW	FW	FW	56	ug/L	9	0	NO DETECTS	Acute: 3.2 Chronic: 0.1	No RP
Silver	NC	0.06	FW	FW	FW	3.1616284	ug/L	0	0	N/A	Acute: 403.4 Chronic: 406.7 No value > Allowable Cw	No RP
Zinc	NC	406.7415	FW	FW	FW	403.4414	ug/L	9	2	30.8 Default C.V.	Acute: 403.4 Chronic: 406.7 No value > Allowable Cw	No RP
Antimony	NC	5.6	WS	WS	WS		ug/L	9	0	NO DETECTS	Acute: NO WQS Chronic: 5.60000 Max MDL = 5	No RP
Barium	NC	1	WS	WS	WS		mg/L	9	9	0.12670 Default C.V.	Acute: NO WQS Chronic: 1.00000 No value > Allowable Cw	No RP
Sulfates	NC	250	WS	WS	WS		mg/L	9	9	119.46000 Default C.V.	Acute: NO WQS Chronic: 250.00000 No value > Allowable Cw	No RP
Thallium	NC	2	WS	WS	WS		ug/L	9	4	0.90500 Default C.V.	Acute: NO WQS Chronic: 2.00000 No value > Allowable Cw	No RP

REASONABLE POTENTIAL ANALYSIS

H1				H2				Par01 & Par02							
Effluent Hardness				Upstream Hardness				Arsenic							
Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 58				Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 58				Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 58							
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1		100	Std Dev.	1		25	0.0000	1	<	0.5	Std Dev.	1	<	0.5	0.3983
2		100	Mean	2		25	25.0000	2	<	0.5	Mean	2	<	0.5	0.6022
3			C.V. (default)	3			0.6000	3	0.3	0.3	C.V. (default)	3	0.3	0.3	0.6000
4			n	4			1	4	1.62	1.62	n	4	1.62	0.5	9
5			10th Per value	5			25.00 mg/L	5	<	0.5	10th Per value	5	<	0.5	1.81
6			Average Value	6			25.00 mg/L	6	<	0.69	Average Value	6	<	0.69	1.6 ug/L
7			Max. Value	7			25.00 mg/L	7	0.49	0.49	Max. Value	7	0.49	0.49	2.9 ug/L
8				8				8	0.32	0.32	Max. Pred Cw	8	0.32	0.32	
9				9				9							
10				10				10							
11				11				11							
12				12				12							
13				13				13							
14				14				14							
15				15				15							
16				16				16							
17				17				17							
18				18				18							

REASONABLE POTENTIAL ANALYSIS

Par03										Par04										Par05									
Beryllium										Cadmium										Chlorides									
Use "PASTE SPECIAL Values" then "COPY" . Maximum data points = 58										Use "PASTE SPECIAL Values" then "COPY" . Maximum data points = 58																			
Date	Data	BDL=1/2DL	Results							Date	Data	BDL=1/2DL	Results							Date	Data	BDL=1/2DL	Results						
1	<	0.2	0.1	0.1772						1	<	0.1	0.05	0.2286						1			49	49					
2	<	0.1	0.1	0.1417						2	<	0.1	0.05	0.2350						2			55	55					
3	<	1	Mean	0.6000						3	<	0.1	0.05	0.9727						3			62	62					
4	<	0.1	C.V. (default)	6						4	<	0.1	n	10						4			70	70					
5	<	0.1	n							5	<	0.1	0.05							5			58	58					
6	<	0.1	0.05	2.14						6	<	0.1	0.05	2.26						6			61.3	61.3					
7			Multi Factor =	0.50 ug/L						7	<	1	0.5	0.500 ug/L						7			66.5	66.5					
8			Max. Value	1.07 ug/L						8	<	1	0.5	1.130 ug/L						8			64.9	64.9					
9			Max. Pred Cw							9	<	1	0.5							9			63.9	63.9					
10										10										10									
11										11										11									
12										12										12									
13										13										13									
14										14										14									
15										15										15									
16										16										16									
17										17										17									
18										18										18									

REASONABLE POTENTIAL ANALYSIS

Par06		Aluminum		Par07		Total Dissolved Solids		Par10		Chromium, Tot	
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1	0.121	0.121	Std Dev.	1	280	280	Std Dev.	1	<	1	0.5
2	0.009	0.0045	Mean	2	280	280	Mean	2	<	1	0.5
3	6.1	6.1	C.V. (default)	3	494	494	C.V. (default)	3	<	0.5	0.25
4	0.1	0.05	n	4	300	300	n	4	6.14	6.14	6.14
5	6.15	6.15		5	250	250		5	<	1	0.5
6	0.8	0.8	Multi Factor =	6	236	236	Multi Factor =	6	<	1	0.5
7	0.1	0.05	Max. Value	7	230	230	Max. Value	7	0.62	0.62	0.62
8	0.1	0.05	Max. Pred Cw	8	284	284	Max. Pred Cw	8	0.76	0.76	0.76
9	0.1	0.05		9	258	258		9	0.26	0.26	0.26
10				10				10			
11				11				11			
12				12				12			
13				13				13			
14				14				14			
15				15				15			
16				16				16			
17				17				17			
18				18				18			

Use "PASTE SPECIAL" Values" then "COPY" Maximum data points = 50

Use "PASTE SPECIAL" Values" then "COPY" Maximum data points = 50

Use "PASTE SPECIAL" Values" then "COPY" Maximum data points = 50

REASONABLE POTENTIAL ANALYSIS

		Use "PASTE SPECIAL" Values" then "COPY" - Maximum data points = 58						Use "PASTE SPECIAL" Values" then "COPY" - Maximum data points = 58					
		Copper						Lead					
Par11		Date	Data	BDL=1/2DL	Results	Results	Date	Data	BDL=1/2DL	Results	Results	Date	Data
					Sid Dev.	Mean				Sid Dev.	Mean		
					C.V. (default)	n				C.V. (default)	n		
					1.81	6.1 ug/L				1.81	3.840 ug/L		
					Max. Value	11.1 ug/L				Max. Value	7.38 ug/L		
					Max. Pred Cw					Max. Pred Cw			
1	<	<	1	0.5	1.8912	1.3594	<	1	0.5	1.2063	1.81	<	<
2	<	<	1	0.5	1.1144	1.0056	<	1	0.5	0.6767	3.81	<	<
3	<	<	1	0.25	0.6000	0.6000	<	1	0.1	0.6000	4.5	<	<
4	<	<	1	4.08	9	9	<	1	3.84	9	3.8	<	<
5	<	<	1	0.5			<	1	0.5			<	<
6	<	<	5	2.5			<	1	0.5			<	<
7	<	<	5	0.26			<	1	0.05			<	<
8	<	<	5	0.21			<	1	0.05			<	<
9	<	<	0.5	0.25			<	1	0.05			<	<
10													
11													
12													
13													
14													
15													
16													
17													
18													

REASONABLE POTENTIAL ANALYSIS

Mercury		Part 16		Molybdenum		Part 17 & Part 18		Nickel		Part 19	
		Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58				Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58				Use "PASTE SPECIAL Values" then "COPY" Maximum data points = 58	
BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	
2.3	Std Dev. 3.3143	<	1	0.5	Std Dev. 0.7433	1	1.82	1.82	Std Dev. 2.1367	1	
3.8	Mean 0.6000	<	1	0.5	Mean 0.6000	2	1.89	1.69	Mean 0.6000	2	
3.7	C.V. (default) n	<	1	0.5	C.V. (default) n	3	1.9	1.9	C.V. (default) n	3	
4.5	3.8	<	1	0.5	3.8	4	3.03	3.03	3.03	4	
3.2	3.7	<	1	0.5	3.7	5	1.99	1.99	1.99	5	
2.7	4.5	<	5	2.5	4.5	6	5	2.5	4.5	6	
3	3.2	<	7	0.57	3.2	7	2.2	2.2	3.0	7	
	2.7	<	8	0.47	2.7	8	2.4	2.4	5.5	8	
	3	<	9	0.52	3	9	1.7	1.7		9	
			10			10				10	
			11			11				11	
			12			12				12	
			13			13				13	
			14			14				14	
			15			15				15	
			16			16				16	
			17			17				17	
			18			18				18	

REASONABLE POTENTIAL ANALYSIS

Selenium		Zinc		Antimony	
Date	BDL=1/2DL	Date	BDL=1/2DL	Date	BDL=1/2DL
1	0.5	1	2.5	1	0.5
2	0.5	2	2.5	2	0.5
3	0.25	3	5	3	0.25
4	0.5	4	17	4	0.5
5	0.5	5	2.5	5	0.5
6	2.5	6	5	6	2.5
7	0.25	7	5	7	0.25
8	0.25	8	3.4	8	0.25
9	0.25	9	5	9	0.25
10		10		10	
11		11		11	
12		12		12	
13		13		13	
14		14		14	
15		15		15	
16		16		16	
17		17		17	
18		18		18	

Selenium		Zinc		Antimony	
Results	Results	Results	Results	Results	Results
Sid Dev.	Sid Dev.	Sid Dev.	Sid Dev.	Sid Dev.	Sid Dev.
0.7193	4.5329	0.7193	5.3222	0.7193	0.6111
Mean	Mean	Mean	Mean	Mean	0.6111
0.6111	5.3222	0.6111	0.6000	0.6111	0.6000
C.V. (default)	C.V. (default)	C.V. (default)	C.V. (default)	C.V. (default)	C.V. (default)
0.6000	0.6000	0.6000	0.6000	0.6000	0.6000
n	n	n	n	n	n
9	9	9	9	9	9
Multi Factor =	Multi Factor =	Multi Factor =	Multi Factor =	Multi Factor =	Multi Factor =
1.81	1.81	1.81	17.0 ug/L	1.81	2.500000 ug/L
Max. Value	Max. Value	Max. Value	30.8 ug/L	Max. Value	Max. Value
2.5 ug/L	17.0 ug/L	2.5 ug/L	30.8 ug/L	2.5 ug/L	2.5 ug/L
Max. Pred Cw	Max. Pred Cw	Max. Pred Cw	Max. Pred Cw	Max. Pred Cw	Max. Pred Cw
0 DETECTS	0 DETECTS	0 DETECTS	0 DETECTS	0 DETECTS	0 DETECTS
ug/L	ug/L	ug/L	ug/L	ug/L	ug/L

REASONABLE POTENTIAL ANALYSIS

3		Par24		Par25	
		Barium		Sulfates	
		Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 98		Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 98	
Date	Data	BDL=1/2DL	Results	Date	Data
0.05	0.05	0.05	Std Dev.	1	63
0.05	0.05	0.05	Mean	2	59
0.05	0.05	0.05	C.V. (default)	3	62
0.07	0.07	0.07	n	4	66
0.06	0.06	0.06		5	59
0.05	0.05	0.05	Multi Factor =	6	57.1
0.052	0.052	0.052	Max. Value	7	54.5
0.05	0.05	0.05	Max. Pred Cw	8	53.5
0.04	0.04	0.04		9	54
				10	
				11	
				12	
				13	
				14	
				15	
				16	
				17	
				18	
		Thallium			
		Use "PASTE SPECIAL Values" then "COPY" - Maximum data points = 4			
Date	Data	BDL=1/2DL	Results	Date	Data
			Std Dev.	1	<
			Mean	2	<
			C.V. (default)	3	0.08
			n	4	<
				5	<
			Multi Factor =	6	<
			Max. Value	7	0.1
			Max. Pred Cw	8	0.1
				9	0.05
				10	
				11	
				12	
				13	
				14	
				15	
				16	
				17	
				18	

REASONABLE POTENTIAL ANALYSIS

REGAL
COPY™
data
8

µg/L
µg/L

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	Rogers Energy Complex	<input type="checkbox"/> CHECK IF HOW OR ORW WQS
WWTP/WWTP Class		
NPDES Permit	NC00005088	
Outfall	Seep 106	
Flow, Qw (MGD)	1.900	
Receiving Stream	UT Broad River	
HUC Number		
Stream Class	WS-IV	
<input type="checkbox"/> Apply WS Hardness WQC		
7Q10s (cfs)	0.00	
7Q10w (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	default 99 mg/L -Ws (Eff Hard Avg = 100 mg/L)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	99 mg/L	
Combined Hardness Acute	99 mg/L	
Data Source(s)		
<input type="checkbox"/> CHECK TO APPLY MODEL		

Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Table 2. Parameters of Concern

Part	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Part1	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Part2	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Part3	Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Part4	Cadmium	Aquatic Life	NC	1.6678	FW	10.7582		ug/L
Part5	Chlorides	Water Supply	NC	250	WS			mg/L
Part6	Aluminum	Water Supply	NC	6.5	WS			mg/L
Part7	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Part8	Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313		ug/L
Part9	Chromium VI	Aquatic Life	NC	11	FW	16		ug/L
Part10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Part11	Copper	Aquatic Life	NC	25.5442	FW	38.2981		ug/L
Part12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Part13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Part14	Lead	Aquatic Life	NC	13.5358	FW	347.3518		ug/L
Part15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Part16	Molybdenum	Water Supply	NC	160	WS			ug/L
Part17	Nickel	Aquatic Life	NC	119.2776	FW	1073.9039		ug/L
Part18	Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Part19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Part20	Silver	Aquatic Life	NC	0.06	FW	3.1616		ug/L
Part21	Zinc	Aquatic Life	NC	406.7415	FW	403.4414		ug/L
Part22	Antimony	Water Supply	NC	5.6	WS			ug/L
Part23	Barium	Water Supply	NC	1	WS			mg/L
Part24	Sulfates	Water Supply	NC	250	WS			mg/L
Part25	Thallium	Water Supply	NC	2	WS			ug/L

NPDES Implementation of Instream Dissolved Metals Standards – Freshwater Standards

The NC 2007-2015 Water Quality Standard (WQS) Triennial Review was approved by the NC Environmental Management Commission (EMC) on November 13, 2014. The US EPA subsequently approved the WQS revisions on April 6, 2016, with some exceptions. Therefore, metal limits in draft permits out to public notice after April 6, 2016 must be calculated to protect the new standards - as approved.

Table 1. NC Dissolved Metals Water Quality Standards/Aquatic Life Protection

Parameter	Acute FW, µg/l (Dissolved)	Chronic FW, µg/l (Dissolved)	Acute SW, µg/l (Dissolved)	Chronic SW, µg/l (Dissolved)
Arsenic	340	150	69	36
Beryllium	65	6.5	---	---
Cadmium	Calculation	Calculation	40	8.8
Chromium III	Calculation	Calculation	---	---
Chromium VI	16	11	1100	50
Copper	Calculation	Calculation	4.8	3.1
Lead	Calculation	Calculation	210	8.1
Nickel	Calculation	Calculation	74	8.2
Silver	Calculation	0.06	1.9	0.1
Zinc	Calculation	Calculation	90	81

Table 1 Notes:

1. FW= Freshwater, SW= Saltwater
2. Calculation = Hardness dependent standard
3. Only the aquatic life standards listed above are expressed in dissolved form. Aquatic life standards for Mercury and selenium are still expressed as Total Recoverable Metals due to bioaccumulative concerns (as are all human health standards for all metals). It is still necessary to evaluate total recoverable aquatic life and human health standards listed in 15A NCAC 2B.0200 (e.g., arsenic at 10 µg/l for human health protection; cyanide at 5 µg/L and fluoride at 1.8 mg/L for aquatic life protection).

Table 2. Dissolved Freshwater Standards for Hardness-Dependent Metals

The Water Effects Ratio (WER) is equal to one unless determined otherwise under 15A NCAC 02B .0211 Subparagraph (11)(d)

Metal	NC Dissolved Standard, µg/l
Cadmium, Acute	$WER * \{1.136672 - [\ln \text{hardness}](0.041838)\} \cdot e^{\{0.9151 [\ln \text{hardness}] - 3.1485\}}$
Cadmium, Acute Trout waters	$WER * \{1.136672 - [\ln \text{hardness}](0.041838)\} \cdot e^{\{0.9151 [\ln \text{hardness}] - 3.6236\}}$
Cadmium, Chronic	$WER * \{1.101672 - [\ln \text{hardness}](0.041838)\} \cdot e^{\{0.7998 [\ln \text{hardness}] - 4.4451\}}$
Chromium III, Acute	$WER * 0.316 \cdot e^{\{0.8190 [\ln \text{hardness}] + 3.7256\}}$
Chromium III, Chronic	$WER * 0.860 \cdot e^{\{0.8190 [\ln \text{hardness}] + 0.6848\}}$
Copper, Acute	$WER * 0.960 \cdot e^{\{0.9422 [\ln \text{hardness}] - 1.700\}}$
Copper, Chronic	$WER * 0.960 \cdot e^{\{0.8545 [\ln \text{hardness}] - 1.702\}}$
Lead, Acute	$WER * \{1.46203 - [\ln \text{hardness}](0.145712)\} \cdot e^{\{1.273 [\ln \text{hardness}] - 1.460\}}$
Lead, Chronic	$WER * \{1.46203 - [\ln \text{hardness}](0.145712)\} \cdot e^{\{1.273 [\ln \text{hardness}] - 4.705\}}$
Nickel, Acute	$WER * 0.998 \cdot e^{\{0.8460 [\ln \text{hardness}] + 2.255\}}$
Nickel, Chronic	$WER * 0.997 \cdot e^{\{0.8460 [\ln \text{hardness}] + 0.0584\}}$

Silver, Acute	$WER * 0.85 \cdot e^{\{1.72[\ln \text{hardness}] - 6.59\}}$
Silver, Chronic	Not applicable
Zinc, Acute	$WER * 0.978 \cdot e^{\{0.8473[\ln \text{hardness}] + 0.884\}}$
Zinc, Chronic	$WER * 0.986 \cdot e^{\{0.8473[\ln \text{hardness}] + 0.884\}}$

General Information on the Reasonable Potential Analysis (RPA)

The RPA process itself did not change as the result of the new metals standards. However, application of the dissolved and hardness-dependent standards requires additional consideration in order to establish the numeric standard for each metal of concern of each individual discharge.

The hardness-based standards require some knowledge of the effluent and instream (upstream) hardness and so must be calculated case-by-case for each discharge.

Metals limits must be expressed as 'total recoverable' metals in accordance with 40 CFR 122.45(c). The discharge-specific standards must be converted to the equivalent total values for use in the RPA calculations. We will generally rely on default translator values developed for each metal (more on that below), but it is also possible to consider case-specific translators developed in accordance with established methodology.

RPA Permitting Guidance/WOBELs for Hardness-Dependent Metals - Freshwater

The RPA is designed to predict the maximum likely effluent concentrations for each metal of concern, based on recent effluent data, and calculate the allowable effluent concentrations, based on applicable standards and the critical low-flow values for the receiving stream.

If the maximum predicted value is greater than the maximum allowed value (chronic or acute), the discharge has reasonable potential to exceed the standard, which warrants a permit limit in most cases. If monitoring for a particular pollutant indicates that the pollutant is not present (i.e. consistently below detection level), then the Division may remove the monitoring requirement in the reissued permit.

1. To perform a RPA on the Freshwater hardness-dependent metals the Permit Writer compiles the following information:
 - Critical low flow of the receiving stream, 7Q10 (the spreadsheet automatically calculates the 1Q10 using the formula $1Q10 = 0.843 (s7Q10, cfs)^{0.993}$)
 - Effluent hardness and upstream hardness, site-specific data is preferred
 - Permitted flow
 - Receiving stream classification
2. In order to establish the numeric standard for each hardness-dependent metal of concern and for each individual discharge, the Permit Writer must first determine what effluent and instream (upstream) hardness values to use in the equations.

The permit writer reviews DMR's, Effluent Pollutant Scans, and Toxicity Test results for any hardness data and contacts the Permittee to see if any additional data is available for instream hardness values, upstream of the discharge.

If no hardness data is available, the permit writer may choose to do an initial evaluation using a default hardness of 25 mg/L (CaCO₃ or (Ca + Mg)). Minimum and maximum limits on the hardness value used for water quality calculations are 25 mg/L and 400 mg/L, respectively.

If the use of a default hardness value results in a hardness-dependent metal showing reasonable potential, the permit writer contacts the Permittee and requests 5 site-specific effluent and upstream hardness samples over a period of one week. The RPA is rerun using the new data.

The overall hardness value used in the water quality calculations is calculated as follows:
Combined Hardness (chronic)

$$= \frac{(\text{Permitted Flow, cfs} * \text{Avg. Effluent Hardness, mg/L}) + (s7Q10, \text{ cfs} * \text{Avg. Upstream Hardness, mg/L})}{(\text{Permitted Flow, cfs} + s7Q10, \text{ cfs})}$$

The Combined Hardness for acute is the same but the calculation uses the 1Q10 flow.

3. The permit writer converts the numeric standard for each metal of concern to a total recoverable metal, using the EPA Default Partition Coefficients (DPCs) or site-specific translators, if any have been developed using federally approved methodology.

EPA default partition coefficients or the "Fraction Dissolved" converts the value for dissolved metal at laboratory conditions to total recoverable metal at in-stream ambient conditions. This factor is calculated using the linear partition coefficients found in *The Metals Translator: Guidance for Calculating a Total Recoverable Permit Limit from a Dissolved Criterion* (EPA 823-B-96-007, June 1996) and the equation:

$$\frac{C_{\text{diss}}}{C_{\text{total}}} = \frac{1}{1 + \{ [K_{\text{po}}] [ss^{(1+a)}] [10^{-6}] \}}$$

Where:

ss = in-stream suspended solids concentration [mg/l], minimum of 10 mg/L used, and

K_{po} and a = constants that express the equilibrium relationship between dissolved and adsorbed forms of metals. A list of constants used for each hardness-dependent metal can also be found in the RPA program under a sheet labeled DPCs.

4. The numeric standard for each metal of concern is divided by the default partition coefficient (or site-specific translator) to obtain a Total Recoverable Metal at ambient conditions.

In some cases, where an EPA default partition coefficient translator does not exist (ie. silver), the dissolved numeric standard for each metal of concern is divided by the EPA conversion factor to obtain a Total Recoverable Metal at ambient conditions. This method presumes that the metal is dissolved to the same extent as it was during EPA's criteria development for metals. For more information on conversion factors see the June, 1996 EPA Translator Guidance Document.

5. The RPA spreadsheet uses a mass balance equation to determine the total allowable concentration (permit limits) for each pollutant using the following equation:

$$Ca = \frac{(s7Q10 + Qw) (Cwqs) - (s7Q10) (Cb)}{Qw}$$

Where: Ca = allowable effluent concentration (µg/L or mg/L)

Cwqs = NC Water Quality Standard or federal criteria (µg/L or mg/L)

Cb = background concentration: assume zero for all toxicants except NH₃* (µg/L or mg/L)

Qw = permitted effluent flow (cfs, match s7Q10)

s7Q10 = summer low flow used to protect aquatic life from chronic toxicity and human health through the consumption of water, fish, and shellfish from noncarcinogens (cfs)

* Discussions are on-going with EPA on how best to address background concentrations

Flows other than s7Q10 may be incorporated as applicable:

1Q10 = used in the equation to protect aquatic life from acute toxicity

QA = used in the equation to protect human health through the consumption of water, fish, and shellfish from carcinogens

30Q2 = used in the equation to protect aesthetic quality

6. The permit writer enters the most recent 2-3 years of effluent data for each pollutant of concern. Data entered must have been taken within four and one-half years prior to the date of the permit application (40 CFR 122.21). The RPA spreadsheet estimates the 95th percentile upper concentration of each pollutant. The Predicted Max concentrations are compared to the Total allowable concentrations to determine if a permit limit is necessary. If the predicted max exceeds the acute or chronic Total allowable concentrations, the discharge is considered to show reasonable potential to violate the water quality standard, and a permit limit (Total allowable concentration) is included in the permit in accordance with the U.S. EPA Technical Support Document for Water Quality-Based Toxics Control published in 1991.
7. When appropriate, permit writers develop facility specific compliance schedules in accordance with the EPA Headquarters Memo dated May 10, 2007 from James Hanlon to Alexis Strauss on 40 CFR 122.47 Compliance Schedule Requirements.
8. The Total Chromium NC WQS was removed and replaced with trivalent chromium and hexavalent chromium Water Quality Standards. As a cost savings measure, total chromium data results may be used as a conservative surrogate in cases where there are no analytical results based on chromium III or VI. In these cases, the projected maximum concentration (95th %) for total chromium will be compared against water quality standards for chromium III and chromium VI.
9. Effluent hardness sampling and instream hardness sampling, upstream of the discharge, are inserted into all permits with facilities monitoring for hardness-dependent metals to ensure the accuracy of the permit limits and to build a more robust hardness dataset.
10. Hardness and flow values used in the Reasonable Potential Analysis for this permit included:

Parameter	Value	Comments (Data Source)
Average Effluent Hardness (mg/L) [Total as, CaCO ₃ or (Ca+Mg)]	25	No data (002)
Average Upstream Hardness (mg/L) [Total as, CaCO ₃ or (Ca+Mg)]	25	No data
7Q10 summer (cfs)	849	
1Q10 (cfs)	232	
Permitted Flow (MGD)		15.5 MGD

Date: 4/20/2018

Permit Writer: Teresa Rodriguez