

STATE OF NORTH CAROLINA
DEPARTMENT OF ENVIRONMENTAL QUALITY
DIVISION OF WATER RESOURCES

PERMIT

TO DISCHARGE WASTEWATER UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provision of North Carolina General Statute 143-215.1, other lawful standards and regulations promulgated and adopted by the North Carolina Environmental Management Commission, and the Federal Water Pollution Control Act, as amended,

Town of Typicalville

is hereby authorized to discharge wastewater from a facility located at the

Town of Typicalville WWTP
1234 Carolina Road (NCSR 1000)
South of Typicalville
Typical County

to receiving waters designated as the Carolina River in the Carolina River Basin
in accordance with effluent limitations, monitoring requirements, and other
conditions set forth in Parts I, II, III and IV hereof.

This permit shall become effective November 1, 2016.

This permit and authorization to discharge shall expire at midnight on April 30, 2020.

Signed this day October 7, 2016.

Tab 3-B, page 12

S. Jay Zimmerman

S. Jay Zimmerman, Director
Division of Water Resources
By Authority of the Environmental Management Commission

SUPPLEMENT TO PERMIT COVER SHEET

All previous NPDES Permits issued to this facility, whether for operation or discharge are hereby revoked. As of this permit issuance, any previously issued permit bearing this number is no longer effective. Therefore, the exclusive authority to operate and discharge from this facility arises under the permit conditions, requirements, terms, and provisions included herein.

The Town of Typicalville is hereby authorized to:

1. Continue to operate the existing 6.0 MGD wastewater treatment facility consisting of the following:
 - Influent Sampler
 - Flow Meter
 - Bar Screens
 - Grit Separator
 - Two Extended Aeration Basins
 - Two Circular Secondary Clarifiers
 - Chlorine Contact Chamber
 - Dechlorination
 - Post Aeration
 - Aerobic Digester

Facility is located at the Town of Typicalville Wastewater Treatment Plant on 1234 Carolina Road (NCSR 1000), south of Typicalville, in Typical County, and

2. Discharge from said treatment works at the location specified on the attached map into the Carolina River, classified WS-IV waters in the Carolina River Basin.

A. (1.) EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning on the effective date of this permit and lasting until expiration, the Permittee is authorized to discharge from outfall 001. Such discharges shall be limited and monitored¹ by the Permittee as specified below:

EFFLUENT CHARACTERISTICS	LIMITS			MONITORING REQUIREMENTS		
	Monthly Average	Weekly Average	Daily Maximum	Measurement Frequency	Sample Type	Sample Location ²
Flow	6.0 MGD			Continuous	Recording	E or I
BOD ₅ ³	30.0 mg/L	45.0 mg/L		Daily	Composite	E & I
Total Suspended Solids ³	30.0 mg/L	45.0 mg/L		Daily	Composite	E & I
NH ₃ - N	6.0 mg/L	18.0 mg/L		3/week	Composite	E
pH ⁴				Daily	Grab	E
Fecal Coliform	200 / 100 ml	400 / 100 ml		Daily	Grab	E
Total Residual Chlorine ⁵			28 µg/L	Daily	Grab	E
Temperature, °C				Daily	Grab	E
Conductivity, µohm/cm				Daily	Grab	E
Dissolved Oxygen				Daily	Grab	E
Total Copper ⁶				Quarterly	Composite	E
Total Zinc ⁶				Quarterly	Composite	E
Total Cadmium ^{6,7}				Quarterly	Composite	E
Total Silver ^{6,8}				Quarterly	Composite	E
Hardness - Total as [CaCO ₃ or Ca + Mg] ⁶ (mg/l)				Quarterly	Composite	E
Hardness - Total as [CaCO ₃ or Ca + Mg] ⁶ (mg/l)				Quarterly	Grab	U
Total Nitrogen (NO ₂ + NO ₃ + TKN)	Monitor and Report, mg/l			Monthly	Composite	E
Total Phosphorus	Monitor and Report, mg/l			Monthly	Composite	E
Dissolved Oxygen ⁹				Variable	Grab	U, D
Temperature, °C ⁹				Variable	Grab	U, D
Conductivity ⁹				Variable	Grab	U, D
Chronic Toxicity ¹⁰				Quarterly	Composite	E
Effluent Pollutant Scan	Monitor and Report			Footnote 11	Footnote 11	E

Notes:

- Effective December 21, 2016 begin submitting discharge monitoring reports electronically using NC DWR's eDMR application system. See Special Condition A. (5)
- Sample locations: E-effluent, I-influent, U-Upstream at NCSR 1000, D-One mile downstream of the outfall
- The monthly average effluent BOD₅ and Total Suspended Solids concentrations shall not exceed 15% of the respective influent value (85% removal).
- The pH shall not be less than 6.0 standard units nor greater than 9 standard units.
- The Division shall consider all effluent TRC values reported below 50 µg/l to be in compliance with the permit. However, the Permittee shall continue to record and submit all values reported by a North Carolina certified laboratory (including field certified), even if these values fall below 50 µg/l.
- Sampling for hardness, copper, cadmium, silver and zinc shall coincide with sampling for chronic toxicity.
- Cadmium shall be tested to its lowest reporting level of 0.5 µg/l.
- Silver shall be tested to its lowest reporting level of 1.0 µg/l.
- Variable is defined as follows: Samples collected three times per week during June 1 through September 30 and once per week October 1 through May 31.
- Chronic Toxicity (Ceriodaphnia) P/F at 13%.; January, April, July, and October. See Special Condition A. (2) of this permit
- The permittee shall perform three Effluent Pollutant Scans during the term of this permit [See Special Condition A.(3)]

There shall be no discharge of floating solids or visible foam in other than trace amounts.

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	
1	INFLUENT																					
2	NPDES PERMIT NO.			NC0012345			MONTH: <u>October</u>			YEAR: <u>2016</u>												
3	FACILITY NAME			Town of Typicalville WWTP																		
4																						
5																			Typicalville LTMP - 1/month influent for many POCs			01092
6	DATE	Composite Time	Time	50050	00400	50060	00310	00610	00530	01002	01027	01002	01002	01002	01002	01002	01002	01002	01002	01002	01002	
7				FLOW	pH	Temperature (Celcius)	BOD5 20 Degrees C	Ammonia Nitrogen	Total Suspended Residual	Arsenic	Cadmium	Chromium	Copper	Cyanide	Lead	Mercury	Molybdenum	Nickel	Selenium	Silver	Zinc	
8	HRS			MGD	UNITS		MG/L	MG/L	MG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	
9	1			2.1																		
10	2			2.2																		
11	3	24	0727	2.4	6.7	23	243		245													
12	4	24	0649	2.4	6.7	22	223		273													
13	5	24	0620	2.3	6.6	22	219	28.8	302	<10	<1	<5	47.6	9	0.5200	<0.20	7.000	<5	<10	<5	494	
14	6	24	0610	2.4	6.8	23	268		250													
15	7	24	0555	2.9	6.8	23	239		258													
16	8			2.7																		
17	9			2.4																		
18	10	24	0730	2.4	6.6	20	237		270													
19	11	24	0640	2.4	6.6	18	252		266													
20	12	24	0630	2.4	6.6	18	243		268													
21	13	24	0620	2.4	6.8	22	271		276													
22	14	24	0600	2.3	6.4	21	252		284													
23	15			2.2																		
24	16			2.3																		
25	17	24	0725	2.4	6.6	21	301		290													
26	18	24	0645	2.4	6.5	20	264		295													
27	19	24	0615	2.4	6.4	21	257		318													
28	20	24	06101	2.5	6.6	22	287		256													
29	21	24	0620	2.4	6.5	22	304		260													
30	22			2.2																		
31	23			2.2																		
32	24	24	0720	2.4	6.8	18	306		268													
33	25	24	0700	2.2	6.6	18	263		268													
34	26	24	0630	2.2	6.7	18	275		308													
35	27	24	0620	2.2	6.8	22	277		266													
36	28	24	0605	2.3	6.7	20	325		292													
37	29			2.2																		
38	30			2.2																		
39	31	24	0730	2.3	6.6	19	250		273													
40	AVERAGE			2.345		21	265	28.80	276	0	0	0	47.6	0	0	0	0	0	0	0	494.0	
41	MAXIMUM			2.900	6.8	23	325	28.80	318	<0.010	<0.002	<0.005	47.6	<0.005	<0.010	<0.0002	<0.005	<0.010	<0.010	<0.005	494.0	
42	MINIMUM			2.100	6.4	18	219	28.8	245	<0.010	<0.002	<0.005	47.6	<0.005	<0.010	<0.0002	<0.005	<0.010	<0.010	<0.005	494.0	
43	Comp/Grab				G	G	C	C	C	C	C	C	C	C	C	C	C	C	C	C	C	
44	Monthly Limit			13.5																		
45	16																					
46																						

EFFLUENT, Page 1

1
 2 NPDES PERMIT NO. NC0012345 DISCHARGE NO.: 001 MONTH: October YEAR: 2016
 3 FACILITY NAME Town of Typicalville WWTP COUNTY: Typical
 4 Certified Labs: (1)Typicalville WWTP Lab (Cert #1234) (2) Neighborhood Lab (Cert. #6789)
 5 OPERATOR IN RESPONSIBLE CHARGE (ORC): Jane Wastewater CERTIFICATION NO.: 12345
 6 PERSON(S) COLLECTING SAMPLES: John Basin
 7 CHECK BOX IF ORC HAS CHANGED

9 Mail ORIGINAL and ONE COPY to:
 10 ATTN: CENTRAL FILES
 11 DIVISION OF WATER RESOURCES
 12 1617 MAIL SERVICE CENTER
 13 RALEIGH, NC 27699-1617

BOD & TSS- No
 NH3 Has BDL


OF OPERATOR IN RESPONSIBLE CHARGE) DATE
 AT THIS REPORT IS
 TO THE BEST OF MY KNOWLEDGE.

DATE	Operator Arrival Time	Operator Time	ORC On Site	50050	00010	00400	50060	00310	00530	00610	00610	31616	00300	00600	00665	TGP3B	HARDNESS
				FLOW	Temperature Celsius	pH	RESIDUAL CHLORINE	BOD5 20 Deg. C - BDLs=0	TOTAL SUSPENDED SOLIDS	Nitrogen - BDLs = 0	Ammonia Nitrogen = BDLs = 1/2 DL	FECAL COLIFORM (Geometric)	DISSOLVED OXYGEN	TOTAL NITROGEN	TOTAL PHOSPHORUS	CHRONIC TOXICITY	
HRS	HRS	Y/B/N	MGD	° C	UNITS	UG/L	MG/L	MG/L	MG/L	MG/L	MG/L	#/100ML	MG/L	MG/L	MG/L	P/F	mg/l
1			N	2.1													
2			N	2.2													
3	0600	24	Y	2.4	23	6.7	<10	4.5	4.1	0.11	0.11	1	6.1				
4	0600	24	Y	2.4	22	6.7	<10	4.1	3.3			<1	6.4				
22	5 0600	24	Y	2.3	22	6.6	<10	4.4	2.7	0.14	0.14	<1	6.4	3	0.72		28.7
23	6 0600	24	Y	2.4	23	6.8	<10	4.4	3.3			2	6.5				
24	7 0600	24	Y	2.9	23	6.8	<10	3.2	3.3	<0.1	0.05	<1	6.4				
25	8		N	2.7													
26	9		N	2.4													
27	10 0600	24	Y	2.4	20	6.6	<10	3.7	3.7	<0.1	0.05	1	6.6				
28	11 0600	24	Y	2.4	18	6.6	<10	5.6	4			<1	6.5				
29	12 0600	24	Y	2.4	18	6.6	<10	5.2	4.7	<0.1	0.05	<1	6.5				
30	13 0600	24	Y	2.4	22	6.8	<10	5	3.9			<1	6.6				
31	14 0600	24	Y	2.3	21	6.4	<10	5.3	4.4	0.13	0.13	<1	6.4				
32	15		N	2.2													
33	16		N	2.3													
34	17 0600	24	Y	2.4	21	6.6	<10	5.2	5.2	<0.1	0.05	<1	6.4				
35	18 0600	24	Y	2.4	20	6.5	<10	5.2	5.3			<1	6.6				
36	19 0600	24	Y	2.4	21	6.4	<10	5.6	4.7	<0.1	0.05	1	6.5				
37	20 0600	24	Y	2.5	22	6.6	<10	5.4	4.4			<1	6.7				
38	21 0600	24	Y	2.4	22	6.5	<10	5.2	4.1	<0.1	0.05	<1	6.5				
39	22		N	2.2													
40	23		N	2.2													
41	24 0600	24	B	2.4	18	6.8	<10	6	4.5	<0.1	0.05	<1	6.6				
42	25 0600	24	B	2.2	18	6.6	<10	5.8	4.1			<1	6.6				
43	26 0600	24	Y	2.2	18	6.7	<10	5.3	4.3	<0.1	0.05	<1	6.6				
44	27 0600	24	Y	2.2	22	6.8	<10	5.6	4.5			2	6.6				
45	28 0600	24	Y	2.3	20	6.7	<10	5.6	4.3	0.1	0.1	1	6.5				
46	29		N	2.2													
47	30		N	2.2													
48	31 0600	24	Y	2.3	19	6.6	<10	4.6	3.3	0.11	0.11	25	7.4				
49	AVERAGE			2.345	21		0	5.0	4.1	0.045	0.076	1	6.5	3.00	0.720		28.7
50	MAXIMUM			2.900	23	6.8	0	6.0	5.3	0.14	0.14	25	7.4	3.00	0.720		28.700
51	MINIMUM			2.100	18	6.4	<10	<2.0	2.7	<0.10	0.05	<1	6.1	3.00	0.720		28.700
52	Comp/Grab				G	G	G	C	C	C	C	G	G	C	C	C	C
53	Monthly Limit			6.0			28	30	30	6	6	200					

54 **1st NH3 column treat BDLs as zero; 2nd NH3 column redone to use 1/2 DL for BDLs**
 55 **USE Recalculated DMR Aves using 1/2 DL for all BDL in YOUR HWA!! -See Guidance on web-site**
 56
 57
 58
 59

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P
1	EFFLUENT, Page 2															
2	NPDES PERMIT NON COMPLIANCE MONTH: <u>October</u> YEAR: 2016															
3	FACILITY NAME <u>Tow</u> <u>Typicalville WWTP</u>															
4																
5																
6		01002	01027	01035	01042	00720	01051	71900		01067	01147	01077	01092			
7	DATE	Arsenic	Cadmium	Chromium	Copper	Cyanide	Lead	Mercury	Molybdenum	Nickel	Selenium	Silver	Zinc			
8		UG/L	UG/L	UG/L	UG/L	UG/L	UG/L	NG/L	UG/L	UG/L	UG/L	UG/L	UG/L			
9	1															
10	2															
11	3															
12	4															
13	5	<10	<1	<5	<5	<5	0.19	2.05	<5	<5	<10	<5	73.3			
14	6															
15	7															
16	8															
17	9															
18	10															
19	11															
20	12															
21	13															
22	14															
23	15															
24	16															
25	17															
26	18															
27	19															
28	20															
29	21															
30	22															
31	23															
32	24															
33	25															
34	26															
35	27															
36	28															
37	29															
38	30															
39	31															
40	AVE	0	0	0	0	0	0.19	2.05	0	0	0	0	73.3			
41	MAX	<10	<1	<5	<5	<5	0.19	2.05	<5	<5	<10	<5	73.3			
42	MIN	<10	<1	<5	<5	<5	0.19	2.05	<5	<5	<10	<5	73.3			
43	C/G	C	C	C	C	G	C	G	C	C	C	C	C			
44																
45																
46																
47																

- NPDES Limits Page requires quarterly sampling for Cd, Cu, Ag & Zn.
 - Typicalville's LTMP requires 1/quarter for cyanide, plus several other POCs
 - Typicalville preforms LTMP sampling 1/month the year before the HWA is due
 - Remember - required to list all



EFFLUENT, Page 1

Tab 3-B, page 19:

Second copy of DMR
Effluent Page 1 to show
Inhibition Evaluation

DISCHARGE NO.: 001 MONTH: October YEAR: 2016
 COUNTY: Typical
34) (2) Neighborhood Lab (Cert. #6789)
Jane Wastewater CERTIFICATION NO.: 12345

☐

x
 (SIGNATURE OF OPERATOR IN RESPONSIBLE CHARGE) DATE
 BY THIS SIGNATURE, I CERTIFY THAT THIS REPORT IS
 ACCURATE AND COMPLETE TO THE BEST OF MY KNOWLEDGE.

DATE	Operator Arrival Time	Operator Time	ORC On Site:	50050		00010	00400	50060	00310	00530	00610	00610	31616	00300	00600	00665	TGP3B	HARDNESS
				FLOW	EFF	Temperature Celsius	pH	RESIDUAL CHLORINE	BOD5 20 Deg. C - BDLs=0	TOTAL SUSPENDED SOLIDS	Nitrogen - BDLs = 0	Ammonia Nitrogen = BDLs = 1/2 DL	FECAL COLIFORM (Geometric)	DISSOLVED OXYGEN	TOTAL NITROGEN	TOTAL PHOSPHORUS	CHRONIC TOXICITY	
HRS	HRS	Y/B/N	MGD	° C	UNITS	UG/L	MG/L	MG/L	MG/L	MG/L	#/100ML	MG/L	MG/L	MG/L	P/F	mg/l		
1			N	2.1														
2			N	2.2														
3	0600	24	Y	2.4	23	6.7	<10	4.5	4.1	0.11	0.11	1	6.1					
4	0600	24	Y	2.4	22	6.7	<10	4.1	3.3			<1	6.4					
5	0600	24	Y	2.3	22	6.6	<10	4.4	2.7	0.14	0.14	<1	6.4	3	0.72		28.7	
6	0600	24	Y	2.4	23	6.8	<10	4.4	3.3			2	6.5					
7	0600	24	Y	2.9	23	6.8	<10	3.2	3.3	<0.1	0.05	<1	6.4					
8			N	2.7														
9			N	2.4														
10	0600	24	Y	2.4	20	6.6	<10	3.7	3.7	<0.1	0.05	1	6.6					
11	0600	24	Y	2.4	18	6.6	<10	5.6	4			<1	6.5					
12	0600	24	Y	2.4	18	6.6	<10	5.2	4.7	<0.1	0.05	<1	6.5					
13	0600	24	Y	2.4	22	6.8	<10	5	3.9			<1	6.6					
14	0600	24	Y	2.3	21	6.4	<10	5.3	4.4	0.13	0.13	<1	6.4					
15			N	2.2														
16			N	2.3														
17	0600	24	Y	2.4	21	6.6	<10	5.2	5.2	<0.1	0.05	<1	6.4					
18	0600	24	Y	2.4	20	6.5	<10	5.2	5.3			<1	6.6					
19	0600	24	Y	2.4	21	6.4	<10	5.6	4.7	<0.1	0.05	1	6.5					
20	0600	24	Y	2.5	22	6.6	<10	5.4	4.4			<1	6.7					
21	0600	24	Y	2.4	22	6.5	<10	5.2	4.1	<0.1	0.05	<1	6.5					
22			N	2.2														
23			N	2.2														
24	0600	24	B	2.4	18	6.8	<10	6	4.5	<0.1	0.05	<1	6.6					
25	0600	24	B	2.2	18	6.6	<10	5.8	4.1			<1	6.6					
26	0600	24	Y	2.2	18	6.7	<10	5.3	4.3	<0.1	0.05	<1	6.6					
27	0600	24	Y	2.2	22	6.8	<10	5.6	4.5			2	6.6					
28	0600	24	Y	2.3	20	6.7	<10	5.6	4.3	0.1	0.1	1	6.5					
29			N	2.2														
30			N	2.2														
31	0600	24	Y	2.3	19	6.6	<10	4.6	3.3	0.11	0.11	25	7.4					
32	AVERAGE			2.345	21		0	5.0	4.1	0.045	0.076	1	6.5	3.00	0.720		28.7	
33	MAXIMUM			2.900	23	6.8	0	6.0	5.3	0.14	0.14	25	7.4	3.00	0.720		28.700	
34	MINIMUM			2.100	18	6.4	<10	<2.0	2.7	<0.10	0.05	<1	6.1	3.00	0.720		28.700	
35	Comp/Grab				G	G	G	C	C	C	C	G	G	C	C	C	C	
36	Monthly Limit			6.0			28	30	30	6	6	200						

Removal Rate Calculations

Sample Date	FLOW		BOD			TSS			AMMONIA					
	mgd	Influent mg/L	Used in Calculation	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation	Effluent mg/L	Used in Calculation	
11/2016 DMR Average	2.267	270	270	5.12	5.12	269	269	3.9	3.9	28.6	28.6	0.35	0.35	
11/2016 LTMP														
10/2016 DMR Average	2.345	265	265	5	5	276	276	4.1	4.1	28.8	28.8	0.076	0.076	
10/2016 LTMP														
9/2016 DMR Average	2.5	245	245	6.1	6.1	280	280	5.4	5.4	26.5	26.5	0.83	0.83	
9/2016 LTMP														
8/2016 DMR Average	2.6	224	224	5	5	334	334	10.3	10.3	31.7	31.7	0.011	0.011	
8/3/2016 LTMP														
7/2016 DMR Average	2.7	205	205	5.6	5.6	216	216	5.3	5.3	17.6	17.6	0.1	0.1	
7/6/2016 LTMP														
6/2016 DMR Average	2.5	219	219	5.5	5.5	211	211	5.5	5.5	46.8	46.8	0.07	0.07	
6/1/2016 LTMP														
5/2016 DMR Average	3.1	224	224	7.1	7.1	230	230	7.4	7.4	16.3	16.3	0.57	0.57	
5/4/2016 LTMP														
4/2016 DMR Average	2.7	250	250	6.9	6.9	254	254	4.5	4.5	24.8	24.8	1.04	1.04	
4/6/2016 LTMP														
3/2016 DMR Average	2.7	247	247	9.6	9.6	234	234	6.3	6.3	23	23	4.96	4.96	
3/2/2016 LTMP														
2/2016 DMR Average	3.4	211	211	8.3	8.3	213	213	7	7	25.2	25.2	1.62	1.62	
2/3/2016 LTMP														
1/2016 DMR Average	3	256	256	5.4	5.4	254	254	5.1	5.1	26.8	26.8	0.24	0.24	
1/6/2016 LTMP														
12/2015 DMR Average	3.9	226	226	5.1	5.1	246	246	4.4	4.4	18.4	18.4	0.21	0.21	
12/1/2015 LTMP														
Column Averages =>	2.809333		236.8333	6.226667	6.226667	251.4167	251.4167	5.766667	5.766667	26.20833	26.20833	0.83975	0.83975	
			Unpaired Site Specific RR =>			Unpaired Site Specific RR =>			Unpaired Site Specific RR =>			Unpaired Site Specific RR =>		
			Literature/Default RR =>			Literature/Default RR =>			Literature/Default RR =>			Literature/Default RR =>		
			0 % of data is BDL			0 % of data is BDL			0 % of data is BDL			0 % of data is BDL		
			RR for this HWA =>			RR for this HWA =>			RR for this HWA =>			RR for this HWA =>		
			97.37 %			97.37 %			97.71 %			96.80 %		
			85.00 %			85.00 %			85.00 %			85.00 %		
			97.37 %			97.37 %			97.71 %			96.80 %		

Removal Rate Calculations

Sample Date	ARSENIC				CADMIUM				CHROMIUM			
	Influent mg/L	Used in Calculation <	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation <	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation <	Effluent mg/L	Used in Calculation
11/2016 DMR Average												
11/1/2016 LTMP	0.01	0.005	0.01	0.0050	0.00013	0.00013	0.00008	0.00004	0.005	0.0025	0.005	0.0025
10/2016 DMR Average												
10/5/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
9/2016 DMR Average												
9/7/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
8/2016 DMR Average												
8/2016 DMR Average	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
8/3/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
7/2016 DMR Average												
7/2016 DMR Average	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
6/2016 DMR Average												
6/1/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
5/2016 DMR Average												
5/4/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
4/2016 DMR Average												
4/6/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
3/2016 DMR Average												
3/2/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.001	0.005	0.0025	0.005	0.0025
2/2016 DMR Average												
2/3/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
1/2016 DMR Average												
1/6/2016 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
12/2015 DMR Average												
12/1/2015 LTMP	0.01	0.005	0.01	0.0050	0.001	0.0005	0.001	0.0005	0.005	0.0025	0.005	0.0025
Column Averages =>	21	0.0050		0.0050	0.0005	0.0005		0.0005	0.0025	0.0025		0.0025

Unpaired Site Specific RR => **50% BDL**
 Literature/Default RR => **82.00%**
 100% of data is BDL
 RR for this HWA => **82.00%**

Unpaired Site Specific RR => **50% BDL**
 Literature/Default RR => **67.00%**
 92% of data is BDL
 RR for this HWA => **67.00%**

Unpaired Site Specific RR => **50% BDL**
 Literature/Default RR => **45.00%**
 100% of data is BDL
 RR for this HWA => **45.00%**

Removal Rate Calculations

Sample Date	COPPER				CYANIDE				LEAD			
	Influent mg/L	Used in Calculation <	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation <	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation <	Effluent mg/L	Used in Calculation
11/2016 DMR Average												
11/1/2016 LTMP	0.0414	0.0414 <	0.005	0.0025	0.015	0.015 <	0.006	0.006	0.0026	0.0026 <	0.00019	0.00019
10/2016 DMR Average												
10/5/2016 LTMP	0.0476	0.0476 <	0.005	0.0025	0.009	0.009 <	0.005	0.0025	0.00052	0.00052 <	0.00019	0.00019
9/2016 DMR Average												
9/7/2016 LTMP	0.0548	0.0548 <	0.005	0.0025	0.008	0.008 <	0.005	0.0025	0.0026	0.0026 <	0.00028	0.00028
8/2016 DMR Average												
8/3/2016 LTMP	0.051	0.051 <	0.005	0.0025	0.01	0.01 <	0.005	0.0025	0.0035	0.0035 <	0.0002	0.0002
7/2016 DMR Average												
7/6/2016 LTMP	0.0705	0.0705 <	0.005	0.0025	0.013	0.013 <	0.007	0.007	0.0065	0.0065 <	0.00021	0.00021
6/2016 DMR Average												
6/1/2016 LTMP	0.0547	0.0547 <	0.005	0.0025	0.011	0.011 <	0.007	0.0035	0.0043	0.0043 <	0.00035	0.00035
5/2016 DMR Average												
5/4/2016 LTMP	0.0163	0.0163 <	0.005	0.0025	0.013	0.013 <	0.006	0.006	0.0035	0.0035 <	0.00026	0.00026
4/2016 DMR Average												
4/6/2016 LTMP	0.0395	0.0395 <	0.005	0.0025	0.013	0.013 <	0.007	0.007	0.002	0.002 <	0.0002	0.0002
3/2016 DMR Average												
3/2/2016 LTMP	0.061	0.061 <	0.008	0.008	0.011	0.011 <	0.006	0.006	0.0032	0.0032 <	0.00028	0.00028
2/2016 DMR Average												
2/3/2016 LTMP	0.0477	0.0477 <	0.005	0.005	0.013	0.013 <	0.005	0.0025	0.0034	0.0034 <	0.00024	0.00024
1/2016 DMR Average												
1/6/2016 LTMP	0.0537	0.0537 <	0.0052	0.0052	0.009	0.009 <	0.006	0.006	0.0022	0.0022 <	0.00018	0.00018
12/2015 DMR Average												
12/1/2015 LTMP	0.033	0.033 <	0.005	0.0025	0.012	0.012 <	0.006	0.006	0.002	0.002 <	0.00019	0.00019
Column Averages =>		0.0476		0.0034	0.0114			0.0048	0.0030			0.0002
	22	Unpaired Site Specific RR =>	92.87 %		Unpaired Site Specific RR =>	58.03 %		58.03 %	Unpaired Site Specific RR =>	92.37 %		92.37 %
		Literature/Default RR =>	86.00 %		Literature/Default RR =>	69.00 %		69.00 %	Literature/Default RR =>	61.00 %		61.00 %
		38 % of data is BDL			21 % of data is BDL				0 % of data is BDL			
		RR for this HWA =>	92.87 %		RR for this HWA =>	58.03 %		58.03 %	RR for this HWA =>	92.37 %		92.37 %

Removal Rate Calculations

Sample Date	MERCURY				MOLYBDENUM				NICKEL			
	Influent mg/L	Used in Calculation	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation	Effluent mg/L	Used in Calculation
11/2016 DMR Average	<				<				<			
11/1/2016 LTMP	<	0.0002	1.83E-06	0.0001	<	0.0005	1.83E-06	0.0005	<	0.0025	0.0005	0.0025
10/2016 DMR Average	<				<				<			
10/5/2016 LTMP	<	0.0002	2.05E-06	0.0001	<	0.007	2.05E-06	0.005	<	0.0025	0.005	0.0025
9/2016 DMR Average	<				<				<			
9/7/2016 LTMP	<	0.0002	2.99E-06	0.0001	<	0.005	2.99E-06	0.005	<	0.0025	0.005	0.0025
8/2016 DMR Average	<				<				<			
8/3/2016 LTMP	<	0.0002	1.65E-06	0.0001	<	0.005	1.65E-06	0.005	<	0.0025	0.005	0.0025
7/2016 DMR Average	<				<				<			
7/6/2016 LTMP	<	1.64E-05	2.66E-06	1.64E-05	<	0.0051	2.66E-06	0.005	<	0.0025	0.005	0.0025
6/2016 DMR Average	<				<				<			
6/1/2016 LTMP	<	0.00066	4.27E-06	0.00066	<	0.005	4.27E-06	0.005	<	0.0025	0.005	0.0025
5/2016 DMR Average	<				<				<			
5/4/2016 LTMP	<	0.0002	4.52E-06	0.0001	<	0.005	4.52E-06	0.005	<	0.0025	0.005	0.0025
4/2016 DMR Average	<				<				<			
4/6/2016 LTMP	<	2.68E-05	2.15E-06	2.68E-05	<	0.005	2.15E-06	0.005	<	0.0025	0.005	0.0025
3/2/2016 LTMP	<				<				<			
3/2/2016 DMR Average	<	0.00026	4.48E-06	0.00026	<	0.005	4.48E-06	0.005	<	0.0025	0.005	0.0025
2/2016 DMR Average	<				<				<			
2/3/2016 LTMP	<	0.00028	3.22E-06	0.00028	<	0.005	3.22E-06	0.005	<	0.0025	0.005	0.0025
1/2016 DMR Average	<				<				<			
1/6/2016 LTMP	<	.00000935	2.3E-06	.00000935	<	0.005	2.3E-06	0.005	<	0.0025	0.005	0.0025
12/2015 DMR Average	<				<				<			
12/1/2015 LTMP	<	0.0002	2.23E-06	0.0001	<	0.005	2.23E-06	0.005	<	0.0025	0.005	0.0025
Column Averages =>	23	0.00017	0.00000	0.00017	0.0031	0.0025	0.00000	0.0025	0.0025	0.0025	0.0025	0.0025

Unpaired Site Specific RR => **98.29 %**
 Literature/Default RR => **60.00 %**
 26 % of data is BDL
 RR for this HWA => **86.75 %**

Unpaired Site Specific RR => **50 % BDL**
 Literature/Default RR => **33.00 %**
 92 % of data is BDL
 RR for this HWA => **33.00 %**

Unpaired Site Specific RR => **50 % BDL**
 Literature/Default RR => **42.00 %**
 100 % of data is BDL
 RR for this HWA => **42.00 %**

Removal Rate Calculations

Sample Date	SELENIUM			SILVER			ZINC		
	Influent mg/L	Used in Calculation <	Effluent mg/L	Influent mg/L	Used in Calculation <	Effluent mg/L	Influent mg/L	Used in Calculation <	Effluent mg/L
11/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.476	0.476	0.104
11/1/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.476	0.476	0.104
10/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.494	0.494	0.0753
10/5/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.494	0.494	0.0753
9/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.416	0.416	0.0824
9/7/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.416	0.416	0.0824
8/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.354	0.354	0.0565
8/3/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.354	0.354	0.0565
7/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.47	0.47	0.0725
7/6/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.47	0.47	0.0725
6/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.448	0.448	0.0921
6/1/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.448	0.448	0.0921
5/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.156	0.156	0.0697
5/4/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.156	0.156	0.0697
4/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.371	0.371	0.0711
4/6/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.371	0.371	0.0711
3/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.458	0.458	0.12
3/2/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.458	0.458	0.12
2/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.374	0.374	0.106
2/3/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.374	0.374	0.106
1/2016 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.471	0.471	0.128
1/6/2016 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.471	0.471	0.128
12/2015 DMR Average	<	0.0050	<	0.00063	<	0.00063	0.21	0.21	0.0864
12/1/2015 LTMP	<	0.01	0.01	0.00063	0.00063	0.00063	0.21	0.21	0.0864
Column Averages =>		0.0050	0.0050	0.00063	0.00063	0.00063	0.3915	0.3915	0.0887

Unpaired Site Specific RR => 50.00 %	Unpaired Site Specific RR => 77.35 %	Unpaired Site Specific RR => 77.35 %
Literature/Default RR => 50.00 %	Literature/Default RR => 75.00 %	Literature/Default RR => 79.00 %
100 % of data is BDL	96 % of data is BDL	0 % of data is BDL
RR for this HWA => 50.00 %	RR for this HWA => 75.00 %	RR for this HWA => 77.35 %

Removal Rate Calculations

Sample Date	Hardness		Total Nitrogen		Total Phosphorus		Upstream Hardness	
	Effluent mg/L	Used in Calculation	Influent mg/L	Used in Calculation	Influent mg/L	Used in Calculation	Upstream mg/L	Used in Calculation
11/2016 DMR Average								
11/1/2016 LTMP	30.6	30.6	37.2	37.2	5.4	5.4	14.2	14.2
10/2016 DMR Average								
10/5/2016 LTMP	28.7	28.7	40.6	40.6	5.4	5.4	14.5	14.5
9/2016 DMR Average								
9/7/2016 LTMP	27.7	27.7	45.6	45.6	5.3	5.3	13.9	13.9
8/2016 DMR Average								
8/3/2016 LTMP	28.1	28.1	7.4	7.4	4.7	4.7	13.2	13.2
7/2016 DMR Average								
7/6/2016 LTMP	27.5	27.5	29.3	29.3	4.1	4.1	11.8	11.8
6/2016 DMR Average								
6/1/2016 LTMP	28.4	28.4	35.1	35.1	4.5	4.5	13.9	13.9
5/2016 DMR Average								
5/4/2016 LTMP	27.2	27.2	12.8	12.8	1.2	1.2	13.5	13.5
4/2016 DMR Average								
4/6/2016 LTMP	24.7	24.7	40.7	40.7	4.7	4.7	13.4	13.4
3/2016 DMR Average								
3/2/2016 LTMP	21.2	21.2	37	37	4.3	4.3	11.9	11.9
2/2016 DMR Average								
2/3/2016 LTMP	27.5	27.5	35.8	35.8	4.7	4.7	15.3	15.3
1/2016 DMR Average								
1/6/2016 LTMP	31.7	31.7	43.2	43.2	4.5	4.5	12.6	12.6
12/2015 DMR Average								
12/1/2015 LTMP	29.8	29.8	20.9	20.9	2.7	2.7	12.7	12.7
Column Averages =>	27.7583	27.7583	32.1333	32.1333	4.2917	4.2917	13.4083	13.4083

Column Averages => 25	Unpaired Site Specific RR => 86.18%	Unpaired Site Specific RR => 82.83%	Unpaired Site Specific RR => #REF!
Default RR =>	Literature/Default RR =>	Literature/Default RR =>	Literature/Default RR =>
this HWA =>	RR for this HWA => 86.18%	RR for this HWA => 82.83%	RR for this HWA =>

0 % of data is BDL
 8 % of data is BDL

Calculator: Estimate NPDES Permit Limitations based on the Dissolved Water Quality Standards and Stream & Effluent Hardness

FACILITY:

Typicalville

PERMIT #:

NC0012345

DATE:

1/4/2017

CALC BY:

DG

Average Stream Flow (CFS)	225.00	Receiving Stream summer 7Q10 (CFS)	60.00	Receiving Stream summer 7Q10 (MGD)	38.7097	Rec. Stream 1Q10 [MGD]	31.81	NPDES Flow Limit [MGD]	6.00	Total Suspended Solids (mg/L)	10.00	Total Hardness (CaCO ₃ , mg/L)	25	IWC - Instream Wastewater Concentration (Chronic)	0.13	IWC - Instream Wastewater Concentration (Acute)	0.16	Average Upstream Hardness	13.40	Average Effluent Hardness	27.80
---------------------------	--------	------------------------------------	-------	------------------------------------	---------	------------------------	-------	------------------------	------	-------------------------------	-------	---	----	---	------	---	------	---------------------------	-------	---------------------------	-------

Class C, C-NSW, C-Swamp, and B streams

PARAMETER*	2		3		4		5		6		7		8		9		10		
	Dissolved Water Quality Criteria (function of total hardness)		Receiving Water Quality		Translators- using EPA Default Partition Coefficients (streams)		Total Metal (allocated to permittee) Diss. Metal + Translator		Total Metal		Total Hardness (CaCO ₃ , mg/L)		IWC - Instream Wastewater Concentration (Chronic)		IWC - Instream Wastewater Concentration (Acute)		Average Effluent Hardness		
	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]	Acute [ug/l]	Chronic	Acute	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]	Acute [ug/l]	Chronic [ug/l]
Arsenic	150	340	150	340	1.000	1.000	150	340	1117.74	2142.44	25	0.13	0.16	558.87	1071.22	13.40	27.80	558.87	1071.22
Arsenic (Human Health)	10	N/A	10	N/A	1.000	1.000	10	N/A	251.94	N/A	25	0.13	0.16	37.26	N/A	13.40	27.80	37.26	N/A
Beryllium	6.5	65	6.5	65	1.000	1.000	6.5	65	48.44	409.58	25	0.13	0.16	24.22	204.79	13.40	27.80	24.22	204.79
Cadmium (a)	0.15	0.82	0.15	0.82	0.252	0.252	0.5899	3.2396	4.4	20.41	25	0.13	0.16	2.2	10.21	13.40	27.80	2.2	10.21
Chlorides (WS)	250000	N/A	250000	N/A	1.000	1.000	250000	N/A	1862903	N/A	25	0.13	0.16	931451.6	N/A	13.40	27.80	931451.6	N/A
Chromium III (a)	24	183	24	183	0.202	0.202	117.7325	905.082	877.3	5703.18	25	0.13	0.16	438.6	2851.59	13.40	27.80	438.6	2851.59
Chromium VI	11	16	11	16	1.000	1.000	11	16	82.0	100.82	25	0.13	0.16	41.0	50.41	13.40	27.80	41.0	50.41
Chromium, Total	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	25	0.13	0.16	N/A	N/A	13.40	27.80	N/A	N/A
Copper (a)	2.7	3.6	2.7	3.6	0.348	0.348	7.8806	10.4720	58.7	65.99	25	0.13	0.16	29.4	32.99	13.40	27.80	29.4	32.99
Cyanide	5.0	22.0	5.0	22.0	1.000	1.000	5.0000	22.0000	37.3	138.63	25	0.13	0.16	18.6	69.31	13.40	27.80	18.6	69.31
Flouride	1800.0	N/A	1800.0	N/A	1.000	1.000	1800.0	N/A	13412.9	N/A	25	0.13	0.16	6706.5	N/A	13.40	27.80	6706.5	N/A
Lead (a)	0.54	14	0.54	14	0.184	0.184	2.9416	75.4871	21.92	475.67	25	0.13	0.16	10.96	237.83	13.40	27.80	10.96	237.83
Mercury	0.012000	N/A	0.012000	N/A	1.000	1.000	0.012000	N/A	0.089419	N/A	25	0.13	0.16	0.0447097	N/A	13.40	27.80	0.0447097	N/A
Molybdenum (WS)	160.00	N/A	160.00	N/A	1.000	1.000	160.0000	N/A	1192.26	N/A	25	0.13	0.16	596.13	N/A	13.40	27.80	596.13	N/A
Nickel (a)**	16	145	16	145	0.432	0.432	37.2313	335.2087	277	2112.25	25	0.13	0.16	139	1056.12	13.40	27.80	139	1056.12
Nickel (WS)	25	N/A	25	N/A	1.000	1.000	25.0000	N/A	186	N/A	25	0.13	0.16	93	N/A	13.40	27.80	93	N/A
Selenium	5	56	5	56	1.000	1.000	5.0000	56.0000	37	352.87	25	0.13	0.16	19	176.44	13.40	27.80	19	176.44
Silver (a)	0.06	0.30	0.06	0.30	1.000	1.000	0.06	0.2964	0.45	1.87	25	0.13	0.16	0.22	0.93	13.40	27.80	0.22	0.93
Zinc (a)	36	36	36	36	0.288	0.288	126.7335	125.7052	944	792.10	25	0.13	0.16	472	396.05	13.40	27.80	472	396.05

Cadmium(trout streams)	0.15	0.51	0.252	0.59	2.02	4.4	12.73
------------------------	------	------	-------	------	------	-----	-------

CARROUSEL® A²C™ SYSTEM DESIGN CALCULATIONS
for
North Carolina WWTP (6 MGD / TWO TRAINS)

A. DESIGN CONDITIONS

AVERAGE FLOW (MGD).....	6.00
DESIGN BOD (mg/l).....	265
DESIGN TSS (mg/l).....	320
DESIGN TKN (mg/l).....	35
DESIGN TP (mg/l)	7
EFFLUENT BOD (mg/l).....	10
EFFLUENT TSS (mg/l).....	15
EFFLUENT NH ₃ -N (mg/l)	1.0
EFFLUENT NO ₃ -N (mg/l)	5.0
EFFLUENT TKN (mg/l)	2.0
EFFLUENT TP (mg/l)	1.0*

*Chemical polishing may be required

100-21

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V
1	Sample Location:																				
2	NORTH AERATION																				
3	Sample Date																				
4	0/5/2016																				
5	4/6/2016																				
6	9/8/2015																				
7	3/10/2015																				
8	10/7/2014																				
9	4/8/2014																				
10	9/19/2013																				
11	2/12/2013																				
28																					
29	SOUTH AERATION																				
30	Sample Date																				
31	0/5/2016																				
32	4/6/2016																				
33	9/8/2015																				
34	3/10/2015																				
35	10/7/2014																				
36	4/8/2014																				
37	9/19/2013																				
38	2/12/2013																				
40	Column Averages =>																				
41																					
42																					

	A	B	W	X	Y	Z	AAAB	AC	AD	AFAF	AG	AH	AI/AJ	AK	AL	AM	
1	Sample Location:																
2	NORTH AERATION																
3	Sample Date																
4	0/5/2016	Spreadsheet Instructions: 1) Data entered only in Heavy Bordered cells. Rest of worksheet is protected, password is "2". 2) For below	<	mg/L	0.079	Used in Calculation	<	mg/L	0.0002	Used in Calculation	<	mg/L	0.0066	Used in Calculation	<	mg/L	
5	4/6/2016		0.027	0.079	0.0001	0.0066	0.063										
6	9/8/2015		0.088	0.027	0.0032	0.0025	0.024										
7	3/10/2015		0.04	0.088	0.0015	0.016	0.05										
8	10/7/2014		0.362	0.04	0.0014	0.0025	0.028										
9	4/8/2014		0.336	0.362	0.003	0.025	0.158										
10	9/19/2013		0.188	0.336	0.004	0.011	0.129										
11	2/12/2013		0.167	0.188	0.0015	0.086	0.133										
28																	
29	SOUTH AERATION																
30	Sample Date																
31	0/5/2016	Spreadsheet Instructions: 1) Data entered only in Heavy Bordered cells. Rest of worksheet is protected, password is "2". 2) For below	<	mg/L	0.06	Used in Calculation	<	mg/L	0.0002	Used in Calculation	<	mg/L	0.0088	Used in Calculation	<	mg/L	
32	4/6/2016		0.072	0.06	0.0029	0.011	0.052										
33	9/8/2015		0.079	0.072	0.0027	0.012	0.037										
34	3/10/2015		0.1	0.079	0.0013	0.012	0.058										
35	10/7/2014		0.339	0.1	0.003	0.012	0.053										
36	4/8/2014		0.324	0.339	0.0024	0.025	0.13										
37	9/19/2013		0.209	0.324	0.002	0.011	0.126										
38	2/12/2013		0.188	0.209	0.0025	0.074	0.13										
40																	
41	Column Averages =>			29	0.16613	0.00210	0.02659	0.08538									
42																	

	A	B	AN	AO	AP	ACAR	AS	AT	AUAJ	AW	AX	AY	
1	Sample Location:												
2	NORTH AERATION												
3	Sample Date												
4	0/5/2016	Spreadsheet Instructions: 1) Data entered only in Heavy Bordered cells, Rest of worksheet is protected, password is "2". 2) For below	<	mg/L	Used in Calculation	<	mg/L	Used in Calculation	<	mg/L	Used in Calculation		
5	4/6/2016		0.011	0.011	0.0067	1.4	1.4	1.4					
6	9/8/2015		0.005	0.0025	0.002	1.3	1.3	1.3					
7	3/10/2015		0.0066	0.0066	0.016	1.6	1.6	1.6					
8	10/7/2014		0.005	0.0025	0.0031	1.7	1.7	1.7					
9	4/8/2014		0.1	0.05	0.025	3.87	3.87	3.87					
10	9/19/2013		0.01	0.005	0.025	3.9	3.9	3.9					
11	2/12/2013		0.058	0.058	0.054	2.96	2.96	2.96					
28			0.05	0.025	0.026	2.21	2.21	2.21					
29	SOUTH AERATION												
30	Sample Date												
31	0/5/2016	Spreadsheet Instructions: 1) Data entered only in Heavy Bordered cells, Rest of worksheet is protected, password is "2". 2) For below	<	mg/L	Used in Calculation	<	mg/L	Used in Calculation	<	mg/L	Used in Calculation		
32	4/6/2016		0.0078	0.0078	0.0092	3.85	3.85	3.85					
33	9/8/2015		0.005	0.0025	0.0076	1.5	1.5	1.5					
34	3/10/2015		0.0082	0.0082	0.01	1.6	1.6	1.6					
35	10/7/2014		0.005	0.0025	0.014	1.6	1.6	1.6					
36	4/8/2014		0.1	0.05	0.025	1.5	1.5	1.5					
37	9/19/2013		0.01	0.005	0.023	3.71	3.71	3.71					
38	2/12/2013		0.067	0.067	0.025	2.1	2.1	2.1					
40	Column Averages =>		0.05	0.025	0.025	2.6	2.6	2.6					
41			30	0.02054	0.01691	2.33750	2.33750	2.33750					
42													

