

High Hazard Service Connections

September 19, 2024

1. Lawn sprinkler systems with chemical injection or booster pump
2. Wastewater treatment plants
3. Connection to an unapproved water system or unapproved auxiliary water supply
4. Connection to tanks, pumps, lines, steam boilers or vessels that handle sewage, lethal substances, toxic or radioactive substances
5. Fire sprinkler systems with booster pump facilities or chemical additives
6. Buildings with five or more stories above ground level
7. Hospitals and other medical facilities
8. Morgues, mortuaries and autopsy facilities
9. Metal plating facilities
10. Bottling plants (subject to back pressure)
11. Canneries
12. Battery manufacturers
13. Exterminators and lawn care companies
14. Chemical processing plants
15. Dairies
16. Film laboratories
17. Car wash facilities
18. Dye works
19. Laundries
20. Swimming pools
21. Waterfront facilities

*This table is based on a table contained in Appendix B of previously published versions of the North Carolina Rules Governing Public Water Systems [15A NCAC 18C] and is subject to change as additional information becomes available.